

## **Copyright Warning & Restrictions**

The copyright law of the United States (Title 17, United States Code) governs the making of photocopies or other reproductions of copyrighted material.

Under certain conditions specified in the law, libraries and archives are authorized to furnish a photocopy or other reproduction. One of these specified conditions is that the photocopy or reproduction is not to be “used for any purpose other than private study, scholarship, or research.” If a user makes a request for, or later uses, a photocopy or reproduction for purposes in excess of “fair use” that user may be liable for copyright infringement,

This institution reserves the right to refuse to accept a copying order if, in its judgment, fulfillment of the order would involve violation of copyright law.

**Please Note: The author retains the copyright while the New Jersey Institute of Technology reserves the right to distribute this thesis or dissertation**

Printing note: If you do not wish to print this page, then select “Pages from: first page # to: last page #” on the print dialog screen

The Van Houten library has removed some of the personal information and all signatures from the approval page and biographical sketches of theses and dissertations in order to protect the identity of NJIT graduates and faculty.

EFFECT OF COLUMN DIAMETER ON  
THE FREQUENCY RESPONSE OF  
WATER FLUIDIZED BEDS

BY

EDWARD C. MAIURO

A THESIS

PRESENTED IN PARTIAL FULFILLMENT OF  
THE REQUIREMENTS FOR THE DEGREE

OF

MASTER OF SCIENCE IN CHEMICAL ENGINEERING

AT

NEWARK COLLEGE OF ENGINEERING

This thesis is to be used only with due regard to the rights of the author. Bibliographical references may be noted, but passages may not be copied without permission of the College and without credit being given in subsequent written or published work.

Newark, New Jersey  
1968

APPROVAL OF THESIS  
FOR  
DEPARTMENT OF CHEMICAL ENGINEERING  
NEWARK COLLEGE OF ENGINEERING

BY  
FACULTY COMMITTEE

APPROVED: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

NEWARK, NEW JERSEY  
JUNE, 1968

### ABSTRACT

The effect of column diameter on the frequency response of water fluidized beds was investigated.

Studies were made on four columns ranging from four to ten inches in diameter. Water was used to fluidize the beds which consisted of spherical glass beads .0185 inches in diameter. A trace solution of sodium chloride was sinusoidally introduced into the beds. Inlet and outlet concentrations were continuously measured by an electrical conductivity recorder. Separate frequency response tests were conducted on the inlet calming section in an attempt to obtain the frequency response of this region alone. Results of the tests were expressed as Bode plots.

As the bed diameter was increased, the system became more backmixed in nature. In an attempt to quantify this data, theoretical frequency response curves were calculated based on the mixing cell model. However, over the range of frequencies tested, poor correlation was obtained between this theoretical model and the empirical data.

### ACKNOWLEDGMENTS

The author wishes to express his indebtedness to Dr. Deran Hanesian for his guidance during the course of this study; and to his wife, Agnes Maiuro, for her encouragement and patient endurance, as well as her aid in typing the manuscript.

## TABLE OF CONTENTS

|   | <u>Page No.</u> |
|---|-----------------|
| TITLE PAGE.....                           | i               |
| APPROVAL PAGE.....                        | ii              |
| ABSTRACT.....                             | iii             |
| ACKNOWLEDGEMENTS.....                     | iv              |
| TABLE OF CONTENTS.....                    | v               |
| LIST OF FIGURES.....                      | vii             |
| LIST OF TABLES.....                       | viii            |
| INTRODUCTION.....                         | 1               |
| APPROACH TO THE PROBLEM.....              | 4               |
| EXPERIMENTAL APPARATUS AND EQUIPMENT..... | 6               |
| THEORETICAL ANALYSIS.....                 | 11              |
| General Theory.....                       | 11              |
| Application of General Theory.....        | 14              |
| RESULTS AND DISCUSSION.....               | 18              |
| CONCLUSIONS.....                          | 28              |
| RECOMMENDATIONS.....                      | 29              |
| FOOTNOTES.....                            | 30              |
| BIBLIOGRAPHICAL ENTRIES.....              | 31              |
| APPENDIX.....                             | 33              |
| Instrument List.....                      | 34              |
| Rotameter Calibration Curve.....          | 35              |

TABLE OF CONTENTS  
(cont.)

|   | <u>Page No.</u> |
|---|-----------------|
| Experimental Data.....  | 36              |
| Numerical Computations.....   | 38              |
| Computer Program Statement for<br>Determination of N.....   | 42              |
| Theoretical Computations of Total System<br>Gain (AR) at Values of N from 1-10 for<br>the Four Columns (4 Time Constants).... | 46              |
| Computer Program Statement for<br>Determination of N <sub>2</sub> .....   | 56              |
| Computer Data for Determination<br>of N <sub>2</sub> .....  | 60              |



LIST OF FIGURES

| <u>Figure No.</u> |   | <u>Page No.</u> |
|-------------------|---|-----------------|
| 1                 | Experimental Equipment Layout                       | 9               |
| 2                 | Column Assembly                                     | 10              |
| 3                 | Block Diagram of System                             | 16              |
| 4                 | Typical Frequency Response Test<br>(High Frequency) | 19              |
| 5                 | Typical Frequency Response Test<br>(Low Frequency)  | 20              |
| 6                 | Experimental Amplitude Ratio Curves                 | 22              |
| 7                 | Amplitude Ratio Curves (3.75 inch<br>Column)        | 23              |
| 8                 | Amplitude Ratio Curves (5.75 inch<br>Column)        | 24              |
| 9                 | Amplitude Ratio Curves (7.75 inch<br>Column)        | 25              |
| 10                | Amplitude Ratio Curves (9.75 inch<br>Column)        | 26              |
| 11                | Rotameter Calibration Curve                         | 35              |

LIST OF TABLES

| <u>Table No.</u> |   | <u>Page No.</u> |
|------------------|---|-----------------|
| 1                | Experimentally Determined Overall System Amplitude Ratio (3.75 inch Column) | 36              |
| 2                | Experimentally Determined Overall System Amplitude Ratio (5.75 inch Column) | 36              |
| 3                | Experimentally Determined Overall System Amplitude Ratio (7.75 inch Column) | 37              |
| 4                | Experimentally Determined Overall System Amplitude Ratio (9.75 inch Column) | 37              |
| 5                | Calculated Data   | 41              |
| 6                | Computer Data for Determination of N <sub>2</sub> (3.75 inch Column)        | 60              |
| 7                | Computer Data for Determination of N <sub>2</sub> (5.75 inch Column)        | 61              |
| 8                | Computer Data for Determination of N <sub>2</sub> (7.75 inch Column)        | 62              |
| 9                | Computer Data for Determination of N <sub>2</sub> (9.75 inch Column)        | 63              |

## INTRODUCTION

Scaling up results from small to large size fluidized beds is an important and difficult problem. It has been recognized that large units generally give results differing from small scale laboratory units. A basic problem facing the designer of a fluidized system is that the flow behavior of large beds differs substantially from small units.(1)

The purpose of this study was to investigate the effect of column diameter on the frequency response of the fluidized bed.

The dynamic characteristics of tubular flow systems, including fluidized systems, may be conveniently expressed in terms of frequency response data. The frequency response method yields results which are reproducible and relatively easy to compare with those obtained from theoretical models.

In frequency response testing a sine wave of a given amplitude and frequency is used as the input signal to the system being studied. The output signal should also be a sine wave with the same frequency; but the amplitude and angular displacement of the wave will be altered in accordance with the dynamics of the system. The ratio of the output wave amplitude to the input wave amplitude, coupled with the angular displacement between the two waves constitute the data of frequency response.

In reality, the flow in a fluidized bed, as well as most other physical processes, is extremely complex and non-linear in nature. However, a system will respond linearly for a given amplitude and range of frequencies. A linear system is one that may be described by linear differential equations. In frequency response terms, a system is linear if the frequency of the output wave equals the frequency of the input wave. Therefore, to employ the frequency response technique readily, it is imperative to remain within the linear bounds of the system.

The purpose of this study was to investigate the effect of bed diameter on the frequency response of fluidized beds, not to develop a rigorous fluid bed model. In an attempt to quantify the empirical data obtained, a rather simplified model was used, the mixing cell model. In this model, one attempts to account for the longitudinal mixing by assuming that the bed acts as a series of noninteracting perfect mixers.<sup>(2)</sup> Theoretical frequency response curves were calculated based on the mixing cell flow model. These theoretical curves were then compared to the experimental curves to arrive at the number of perfect mixers for each column.

Much work has been performed on the dynamic analysis of fluid bed systems by step, pulse and frequency response techniques. However, an exhaustive search of the literature has revealed that the bulk of this work has been performed on small size columns, 4 inch diameter and less. There is a lack

of data for a broad range of column diameters. It is for this reason that the 4 to 10 inch beds were evaluated.

A listing and summarization of previous work on longitudinal dispersion of liquid in fixed and fluidized beds is presented in AIChE Preprint 33E, November 26-30, 1967.

### APPROACH TO THE PROBLEM

Theoretical responses were calculated for each column over the range of frequencies tested by use of the mixing cell model. A computer was employed in the calculation of the theoretical responses for N perfect mixing cells. Bode plot data was obtained for values of N ranging from 1 to 200.

A frequency response analysis was performed on each column and the results plotted on Bode diagrams. These experimental results were then compared to the theoretical frequency responses.

Each column consisted of two sections, the packed calming section and the fluidized section. As it was the intent of this work to develop a scale-up correlation for fluidized beds, only the response of the fluidized section was desired. Therefore, the inlet conductivity cell was placed as close as possible to the base of the fluidized bed. (See Fig. 2) However, due to the construction of the cell, the signal measured was not the conductivity directly at the base of the fluidized bed. But rather, it was the conductivity 3-3/4 inches below the fluid-bed base. It was therefore necessary to determine the response of this section alone. The response of the fluidized section could then be obtained by subtracting the packed calming section response from the overall system response.

To obtain the response of the calming section alone, one must run frequency response tests on each column with the fluidized section emptied. This was attempted. However, when the

glass beads were removed from the columns, air bubbles formed on the conductivity electrodes. This resulted in completely meaningless conductivity readings and prevented experimental determination of the calming section response. This difficulty necessitated a different approach to the problem. As experimental determination of the calming section response was impossible, a theoretical response based on the mixing cell model was calculated for this region.

### EXPERIMENTAL APPARATUS AND EQUIPMENT

The experimental equipment included a low frequency sine wave generator which applied a 3-15 psig. air signal to a Mason Neilon control valve. This control valve was placed in the tracer inlet line. The control valve's opening and closing varied the amount of salt solution feed into the fluidized bed, thus causing the electrical conductivity of the bed to rise and fall.

The apparatus used for the experimentation is shown in Figures 1 and 2. The range of column diameters studied required the construction of an apparatus which was adaptable to all four columns.

Two 14 inch square steel plates were drilled and tapped at the centers to afford an entrance and exit for the liquid. Also, each plate was covered with soft rubber. This rubber functioned as a gasket at the plate and column interfaces. Each column consisted of two sections, the 8 inch calming section and the 4.5 foot fluidizing section. In assembling each column, the calming section was set down on the plate and filled with Raching Rings. A gasket and bed support screen were then placed over this first section. Another gasket followed and next the fluidizing section was bolted and clamped



to the calming section. The entire column was then clamped between the two steel plates. Dow Hi-Vac grease was applied between the gaskets, column and plates to insure a water-tight seal. The glass beads for the fluidizing section were added after the column was assembled, through the fitting in the top plate. To change columns with this system, only loosening the clamps and a replacement of the column was required. All four columns were made of Lucite with a wall thickness of 1/8 inch.


The apparatus was constructed so that one conductivity cell was placed within the calming section, and measured the conductivity at the base of the fluidized bed. The second conductivity cell was lowered through the top plate and positioned at the upper edge of the fluidized bed. These two cells transmitted the signals to a Beckmann Honeywell two pen electrolytic conductivity indicator recorder. The recorder range was 0-10,000 micromhos, with a linear 0-10 scale.

A pneumatic recorder was positioned in parallel with the control valve as a check on the air signal being supplied to the valve by the sine wave generator.

A saturated solution of sodium chloride was used for the trace signal. The salt solution was stored in a 55 gallon polyethylene drum. This solution was delivered to the bed by means of a centrifugal pump which provided a nearly constant head of 22 psig.

The fluidizing water for the system was checked for variations in static pressure, only slight fluctuations were noted. The water was fed into the columns by a 3/4 inch pipe through a rotameter. The overflow was carried to the sewer by a one inch rubber hose. The rotameters used for the fluidizing liquid were two Fischer-Porter rotameters. These meters were rated at 2.7 and 8.8 gallons per minute at 100% flow. The meters were calibrated and found to be linear.

FIGURE 1  
EXPERIMENTAL EQUIPMENT LAYOUT






Figure 2  
COLUMN ASSEMBLY

THEORETICAL ANALYSIS

General Theory

In the mixing cell model the system is represented as a series of finite, perfectly mixed cells. By definition the concentration in a perfect mixer has a value at every point equal to the concentration at the outlet  $C_0$ . For continuous flow through the mixer we have the material balance:

$$C_1 = C_0 + T \frac{dC_0}{dT} \quad (1)$$

where  $T$  is the average time of residence (volume of the mixer divided by the constant volumetric flow rate). If  $C_1$  is varied sinusoidally, then the value of the signal at any place in the system is given by:

$$C = X e^{j\omega t} \quad (2)$$

$X$  is a complex number which can be represented by a radius vector in the complex plane, having a certain length (magnitude) and a phase angle with respect to the positive real axis. In the frequency response analysis, the relationship between two signals  $C$  and their vectors  $X$  is of interest. It can be expressed by the ratio of their respective magnitudes (amplitude ratio) and the difference between their respective phase angle (phase lag). If the concentrations for the two signals are recorded, the complex ratio between  $X_0$  and  $X_1$  is called the harmonic response

function of the entire system (transfer function). This function depends on the frequency  $w$  of the applied signal in a way which is characteristic of the system.

Substitution of equation 2 into equation 1 yields:

$$X_1 = X_0 + jwTX_0 \quad (3)$$

and for the transfer function of one perfect mixer

$$\frac{X_0}{X_1} = \frac{1}{1 + jwT} \quad (4)$$

The value of the amplitude ratio (AR) and phase angle ( $\phi$ ) are:

$$AR = (1 + w^2T^2)^{-\frac{1}{2}}$$

$$\phi = -\text{arc tan } (wT)$$

Applying the result of equation 4 to a system containing  $N$  perfect mixers in cascade having equal times of residence ( $T/N$ ), the transfer function is:

$$G(s) = \left[ \frac{1}{\frac{T}{N}s + 1} \right]^N \quad (5)$$

or

$$G(j\omega) = \left[ \frac{1}{\frac{T}{N}j\omega + 1} \right]^N$$

where

$T$  = Time Constant (min.) =  $V/q$

$V$  = Total volume of  $N$  mixers ( $\text{ft}^3$ )

$q$  = Flow rate ( $\text{ft}^3/\text{min.}$ )

$N$  = Number of perfect mixing cells

From the transfer function, the amplitude ratio and phase angle may be obtained.

$$G(j\omega) = \left[ \frac{1}{\sqrt{1 + (\omega T/N)^2}} \right]^N \quad (6)$$

$$G(j\omega) = -N \text{ arc tan } (\omega T/N) \quad (7)$$

where

$G(j\omega)$  = amplitude ratio = AR

$G(j\omega)$  = phase angle =  $\phi$

$\omega$  = frequency (cycles/min)

When a sinusoidal disturbance is introduced into a flow system, the outgoing signal is smaller in amplitude and exhibits a phase lag with respect to the entering signal. In general, the amplitude ratio is  $\leq 1$  and the phase angle  $\leq 0.3$ .

#### Application of General Theory

The system studied consisted of two regions, the packed calming section and the fluidized section, each with its own transfer function. The mixing cell model assumes that the response of each element is independent of conditions in the other elements. The elements are considered non-interacting and the total system transfer function is the product of the individual transfer functions.

$$G = G_1 \cdot G_2 \quad (8)$$

where

$G$  = total system transfer function

$G_1$  = packed calming section transfer function

$G_2$  = fluidized bed transfer function

Also,

$$AR = AR_1 \cdot AR_2$$

$$\phi = \phi_1 + \phi_2$$

Amplitude ratios will be utilized throughout this discussion, to obtain the number of mixing cells in each section. Values for  $N$  can be obtained from the phase angle curves of Bode plots, since a system with  $N$  mixing cells exhibits a phase lag of



$N\pi/2$  as the frequency approaches  $\infty$ . However as real systems exhibit dead time, which effects the phase angle but not the amplitude ratio, the experimental determination of  $N$  from phase angle diagrams was not attempted.

$$AR = AR_1 \cdot AR_2$$

$$\left[1 + \left(\frac{wT}{N}\right)^2\right]^{-N/2} = \left[1 + \left(\frac{wT_1}{N_1}\right)^2\right]^{-N_1/2} \cdot \left[1 + \left(\frac{wT_2}{N_2}\right)^2\right]^{-N_2/2} \quad (9)$$

where

$N$  = number of mixing cells in total system.

This value is determined from the experimental frequency response curve of the total system.

$N_1$  = number of mixing cells in section 1 (packed calming section)

$N_2$  = number of mixing cells in section 2 (fluidized bed)

$T, T_2, T_3, w$

= are known quantities.

$N, N_2$

= unknown quantities

but

$$N = N_1 + N_2 \quad (10)$$

therefore

$$N_2 = N - N_1 \quad (11)$$




Figure 3  
BLOCK DIAGRAM OF SYSTEM


Equations 9 and 10 comprise two equations in two unknowns which were solved for  $N_2$ , the number of mixing cells in the fluidized region. The solution was performed by a trial and error technique on a computer. This calculation yielded the amplitude ratio of the fluidized bed and in turn the number of perfect mixing cells.

## RESULTS AND DISCUSSION

The frequency response tests were conducted to obtain the total system amplitude ratio curve, from which by a comparison with the theoretical model N could be obtained.


These tests were run on each column over a range of frequencies ranging from 7.50 cycles/min to 0.12 cycles/min. The input signal to the bed was sinusoidal in shape, while the outlet wave was less sinusoidal, in appearance it was more triangular. This effect was more noticeable at the lower frequencies. Typical experimental frequency response tests are presented in Figures 4 and 5. The system responded linearly over the range of frequencies tested. Figures 7, 8, 9, 10 are amplitude ratio plots obtained from the experimental data superimposed over the theoretical amplitude ratio plot for the N value which best fit the experimental data. Figure 6 contains the experimental amplitude ratio curves for all four bed diameters, computed from curves similar to those in Figures 4 and 5. It can be seen from Figure 6 that for a given frequency as bed diameter increases the amplitude ratio decreases.

Perfect plug flow is postulated for a system where no amplitude attenuation of the incoming sinusoidal occurs. A plug flow system can be thought of as consisting of an infinite number of infinitesimally small perfect mixing cells, which would result in



TYPICAL FREQUENCY RESPONSE TEST  
(HIGH FREQUENCY)

Figure 4




TYPICAL FREQUENCY RESPONSE TEST  
(LOW FREQUENCY)

Figure 5

an amplitude ratio equivalent to unity. For a given frequency as the amplitude ratio decreases, more attenuation of the input sinusoidal, the system becomes less plug flow in nature, i.e., exhibits more backmixing. Hence, the experimental data tabulated in Figure 6 indicates that an increase in bed diameter results in increased backmixing. Kramer and Alberda<sup>4</sup> have demonstrated that the frequency response diagrams of real systems generally lie between those for one perfect mixer and for perfect plug flow. However, it is not at all necessary that the diagram for a real system coincides with one for a certain number of perfect mixers.


A theoretical model, the mixing cell model, was employed in an attempt to quantify the empirical data obtained. However, attempts to represent the mixing phenomena of the total system by the mixing cell model proved unfruitful. The model yielded amplitude ratio curves whose shapes did not agree with the plots of the experimental values. It is perhaps significant however, that the curves did approach each other at the highest test frequency, 7.5 cycles/min. It seems logical to test at still higher frequencies to see if this trend is continued. This was attempted. A sinusoidal input of 15 cycles/min was introduced into the system. However, the noise inherent in the system obscured the outlet sine wave making a computation of the amplitude for this higher frequency impossible.




EXPERIMENTAL AMPLITUDE RATIO CURVES

FIGURE 6







AMPLITUDE RATIO CURVES (3.75 INCH COLUMN)  
FIGURE 7



AMPLITUDE RATIO CURVES (5.75 INCH COLUMN)  
FIGURE 8



AMPLITUDE RATIO CURVES (7.75 INCH COLUMN)  
FIGURE 9



AMPLITUDE RATIO CURVES (9.75 INCH COLUMN)  
FIGURE 10

Hence, the theoretical values of  $N$  which yielded the best fit to the experimental data were chosen for the number of mixing cells for the total system, fluidized section and packed calming section.

It is felt that better correlation between model and experimental data could have been obtained, if the response of the empty column could be obtained. It appears that at the low flow velocity utilized, a correction to the amplitude is required for interaction with the bed support and column wall. As was mentioned previously, this was attempted. The low flows had to be maintained due to the fact that the small beads chosen, .0185 in. diameter, were easily driven from the column. At these low flows, air bubbles entering the system dissolved in the water would accumulate on the conductivity electrode. This was not too severe a problem when beads were in the column, as they would circulate through the cell and displace the air bubbles. But when attempts were made at running the column empty, to measure entrance, column wall and bed support responses, bubbles accumulated on the electrodes and made conductivity measurement impossible.

The interaction with the bed support and column wall undoubtedly contributed to the disagreement between empirical results and theoretical predictions.

The values of  $N$  for the total system are listed in tables 6-9. As the  $N$  values were extremely low, computation of meaningful  $N_1$  and  $N_2$  values was impractical.

### CONCLUSIONS

For the flow rate employed in this study, as bed diameter increased the flow pattern in the bed became less plug flow in nature and exhibited increased backmixing.

The fluidized and packed bed systems used in this study were linear.

It is believed that the poor correlation between experimental data and the theoretical mixing cell model, is in part due to the interaction of the wall and bed support.

The theoretical model used did not accurately describe the mixing phenomena in the fluidized beds studied. It is obvious that a different model, perhaps more sophisticated than the mixing cell model is required to describe the system.

RECOMMENDATIONS

1--

This study may be performed using a considerably larger bead size. This will allow the use of higher flow rates, without the fear of displacing beads from the column. At higher flow rates air bubbles do not accumulate on the conductivity cells, which tend to introduce noise into the system. Also, the higher flows and the resulting lower noise level will allow testing at higher frequencies. At the higher flow rate it will also be possible to test the effect of the empty column response, the wall response and bed support response, without having air bubbles hindering the measurement.

2--

A study similar to the one performed over a range of flow rates may be of value.

3--

Utilization of a different model perhaps the axial diffusion model in arriving at a scale-up factor for fluidized beds.

FOOTNOTES

<sup>1</sup>Olaf Winter, Gas Mixing In Fluidized Beds: Model Experiments For Scaling-Up Purposes, Chemical Engineering Progress, Volume 62, 1966, pp. 1-9

<sup>2</sup>Gray R. I. and J. W. Prados, AICHE Journal 9, 211 (1963)

<sup>3-4</sup>H. Kramers and G. Alberda, Frequency Response of Continuous Flow Systems, Laboratorium voor Fysische Technologie, Technological University, Delft, Netherlands, June, 1953

<sup>5</sup>P. V. Danckwerts, Chem. Eng. Sci. 2, 1 (1953)

<sup>6</sup>M. Leva, Fluidization, N. Y. McGraw Hill, 1959, pp 64-87



BIBLIOGRAPHICAL ENTRIES

Perlmutter, Daniel D., Introduction to Chemical Process Control, New York, John Wiley & Sons Inc. 1965

Liang-Tseng Fan, Yong-Kee Ahn, Frequency Response of Tubular Flow Systems, Chem. Eng. Progress, Process System Engineering

Barnstone L.A. and Harriot P., Frequency Response of Gas Mixing in a Fluidized-Bed Reactor, AIChE Journal, Vol. 13, No. 3 May 1967, pp. 465-474

Adler I. L. and Happel J., The Fluidization of Uniform Smooth Spheres in Liquid Media, Chem. Eng. Progress, Vol. 58 (1962)

Gray, R. I., The Dynamics of a Packed Gas Absorber by Frequency Response Analysis, AIChE Journal, Vol. 9, No. 2, March 1963, pp. 211-215

Gabor J. D., Axial Solids Mixing In Fluidized-Packed Beds, Chem. Eng. Progress, Vol. 62 (1966)

Staffin H. K. and Staffin R., Approximating Transfer Functions from Frequency Response Data, Instruments and Control Systems, Vol. 38, February 1965, pp. 137-144

Harriot, P., Process Control, New York, McGraw-Hill, 1964

Coughanowr, D. R., Process Systems Analysis and Control, New York, McGraw-Hill, 1965

Caldwell, W. I., Coon, G. A., and Zoss, L. M., Frequency Response for Process Control, New York, McGraw-Hill, 1959

Chemical Engineer Handbook, Third Edition, John H. Perry (ed.) New York: McGraw-Hill, 1950

Heimlich, B. N., and Gruet, I. C., Transfer Function Analysis of Fluidized-Bed, Chem. Eng. Progress, Vol. 62 (1966) pp. 28-34

Littman, H., and Stone A. P., Gas-Particle Heat Transfer Coefficients in Fluidized Beds by Frequency Response Techniques, Chem. Eng. Progress, Vol. 62, (1966) pp. 47-55

Gallier, P. W., Sliepcevich, C. M., and Fuckett, T. H.  
Practical Limitations on Correlation Techniques in Determining  
Process Frequency Response, Chem. Eng. Progress, Vol. 57  
(1961) pp. 59-67

Ceaglske, N. H., Transient Vs. Frequency Response in Analyzing  
Chemical Process Systems, Vol. 57 (1961) pp. 53-58

Othmer, D. F., Fluidization, New York, Reinhold Publishing  
Corporation (1956) pp. 1-19

APPENDIX

|   | <u>Page</u> |
|---|-------------|
| Instrument List   | 34          |
| Rotameter Calibration Curve   | 35          |
| Experimental Data   | 36          |
| Numerical Computations  | 38          |
| Computer Program Statement for Determination<br>of N  | 42          |
| Theoretical Computations of Total System<br>Gain (AR) at Values of N from 1-10<br>for the Four Columns (4 Time Constants) | 46          |
| Computer Program Statement for Determination<br>of N <sub>2</sub> for the Four Columns (4 Time Constants)                 | 56          |
| Computer Data for Determination of N <sub>2</sub>   | 60          |

INSTRUMENT LIST

1. Conductivity Cells, Type Cel-VH20KFT and Cel-VH20KFT-Y-15  
Beckman Instruments
2. Ultra Low Frequency Sinusoidal Signal Generator,  
Model SG-101P, Procedyne Associates Inc., New Brunswick,  
New Jersey
3. Consotrol Controller, Mode 58, Foxboro Co.,  
Foxboro, Massachusetts
4. Control Valve, Model #37-24681, Mason Neilon Inc.,  
Norwood, Massachusetts
5. Electrolytic Conductivity Recorder, Model Y15302816-02-99  
Beckman/Honeywell
6. Rotameters -- Three -- .68 gpm., 2.7 gpm., 8.8 gpm.,  
Fischer-Porter, Warminster, Pennsylvania




Figure 11  
ROTAMETER CALIBRATION CURVES

TABLE 1  
 EXPERIMENTALLY DETERMINED  
 OVERALL SYSTEM AMPLITUDE RATIO  
 3.75 INCH COLUMN

| w (Cycles/min) | Amplitude Ratio (AR) |
|----------------|----------------------|
| 7.50           | .24                  |
| 3.75           | .38                  |
| 1.88           | .43                  |
| 0.94           | .69                  |
| 0.47           | .86                  |
| 0.23           | .94                  |
| 0.12           | .96                  |

TABLE 2  
 EXPERIMENTALLY DETERMINED  
 OVERALL SYSTEM AMPLITUDE RATIO  
 5.75 INCH COLUMN

| w (Cycles/min) | Amplitude Ratio (AR) |
|----------------|----------------------|
| 7.50           | .19                  |
| 3.75           | .31                  |
| 1.88           | .35                  |
| 0.94           | .51                  |
| 0.47           | .76                  |
| 0.23           | .86                  |
| 0.12           | .92                  |

TABLE 3  
 EXPERIMENTALLY DETERMINED  
 OVERALL SYSTEM AMPLITUDE RATIO  
 7.75 INCH COLUMN

| w (Cycles/min) | Amplitude Ratio (AR) |
|----------------|----------------------|
| 7.50           | .15                  |
| 3.75           | .20                  |
| 1.88           | .26                  |
| 0.94           | .46                  |
| 0.47           | .69                  |
| 0.23           | .82                  |
| 0.12           | .85                  |

TABLE 4  
 EXPERIMENTALLY DETERMINED  
 OVERALL SYSTEM AMPLITUDE RATIO  
 9.75 INCH COLUMN

| w (Cycles/min) | Amplitude Ratio (AR) |
|----------------|----------------------|
| 7.50           | .09                  |
| 3.75           | .12                  |
| 1.88           | .23                  |
| 0.94           | .40                  |
| 0.47           | .64                  |
| 0.23           | .76                  |
| 0.12           | .79                  |

## NUMERICAL COMPUTATIONS

### Time Constant Calculation

Danckwerts<sup>5</sup> has shown that if a volume  $V$  is fed with a flow rate  $q$ , regardless of the transfer function of the region, the average time of travel through the region is  $V/q$ . This is the time constant ( $T$ ) for a mixing process.

The time constant of the overall system studied is equal to the sum of the time constants of two sections.

$$T = T_1 + T_2$$

$$T = V/q$$

$$q = \text{constant to each section.}$$

Hence, in order to calculate the time constants for each section it is necessary to compute the void volume in each section.

### Fluidized Section

$$V_2 = V_s \cdot (E_2) + V_E$$

where


$V_2$  = void volume of fluidized region

$V_s$  = volume of static bed

$E_2$  = calculated voidage factor (.44)

$V_E$  = expanded volume





Packed Section

$$V_1 = V_p(E_1)$$

where

$V_1$  = void volume of packed region

$V_p$  = volume of packed region

$E_1$  = calculated voidage factor for packing section

(.65)

The voidage factor ( $E_1$ ) for the static bed was experimentally determined by filling a cylinder with a known volume of water. To this the beads were added up to a given volume. The total

volume of beads and water was then read, from this data the voidage factor was easily calculated. In a similar fashion, the voidage factor ( $E_1$ ) for the packed calming section was obtained.

#### Minimum Fluidization Mass Velocity Calculation

The mass flow rate ( $G_{mf}$ ) at minimum fluidization<sup>6</sup> is given by:

$$G_{mf} = \frac{688 D_p^{1.82} \left( f_f [f_s - f_f] \right)^{.94}}{u^{.88}}$$

where

$G_{mf}$  = mass flow rate (lb/hr-ft<sup>2</sup>)

$D_p$  = diameter of beads (in)

$f$  = density of fluidizing medium (lb/ft<sup>3</sup>)

$s$  = density of beads (lb/ft<sup>3</sup>)

$u$  = viscosity of fluidizing medium (lb/hr-sec)

$$G_{mf} = \frac{688 (.0185)^{1.8} [62.3 (155.7-62.3)]^{.94}}{(1.3)^{.88}}$$

$$G_{mf} = 1,310 \text{ lb/hr-ft}^2$$

The four columns were operated at approximately three times (2.96) this value. The study was limited to low flows because beads were driven out of the smaller columns at flows higher than three times the minimum fluidization velocity.

TABLE 5

| Columns                                   | Inside Diameter<br>In | 3.75" | 5.75" | 7.75" | 9.75" |
|---|-----------------------|-------|-------|-------|-------|
| V   | ft <sup>3</sup>       | .0404 | .1097 | .2300 | .4235 |
| V <sub>1</sub>                            | ft <sup>3</sup>       | .0155 | .0366 | .0664 | .1050 |
| V <sub>2</sub>                            | ft <sup>3</sup>       | .0249 | .0731 | .1636 | .3189 |
| q   | ft <sup>3</sup> /min  | .09   | .20   | .36   | .57   |
| T   | min                   | .45   | .54   | .64   | .75   |
| T <sub>1</sub>                            | min                   | .17   | .18   | .19   | .19   |
| T <sub>2</sub>                            | min                   | .28   | .36   | .45   | .56   |
| Height of<br>Static Bed                   | in                    | 4"    | 6"    | 8"    | 10"   |
| Height of<br>Fluidized Bed<br>(Section 2) | in                    | 6"    | 8.25" | 10.5" | 11"   |
| Height of<br>Packed Bed<br>(Section 1)    | in                    | 3.75" | 3.75" | 3.75" | 3.75" |

PHASE ANGLE CALCULATIONS, ED M

FORTRAN SOURCE LIST

ISN

SOURCE STATEMENT

```

0 $IBFTC PHANGL NOLIST,NODECK,REF
1     DIMENSION TO%5[
2     DATA TO/0.45,0.54,0.64,0.75,0.0/
3     I1#1
4     I2#5
5     I3#4
6     XXI#1000,
7     PRINT 102
10    IWT#0
11    5 DO 20 I#I1,I2,I3
12    W#15,
13    XI#I
14    XI#XI/XXI
15    DO 15 IW#1,9
16    DO 10 IT#1,4
17    G#%1.0/SQRT%1.0&%W*TO%IT[/XI]**2[[**XI
20    WTX#W*TO%IT[/XI
21    A#-XI*ATAN%WTX[
22    A#A*57.29578
23    PRINT 101,XI,W,TO%IT[,G,A
24    IWT#IWT&1
25    IF%IWT.NE.36[ GO TO 10
30    IWT#0
31    PRINT 102
32    10 CONTINUE
34    W#W/2,
35    15 CONTINUE
37    20 CONTINUE
41    IF%XXI.GT.10.[ GO TO 30
44    IF%I2.EQ.5[ GO TO 35
47    IF%I2.EQ.25[ GO TO 25
52    GO TO 200
C
53    25 I1#30
54    I2#200
55    I3#10
56    GO TO 5
C
57    30 XXI#XXI/10,
60    GO TO 5
61    35 I1#1
62    I2#25
63    I3#1
64    XXI#1,
65    GO TO 5
66    200 CALL EXIT
67    101 FORMAT%7X,5%F12.4,6X[[
70    102 FORMAT%1H1,7X,12HNO. REACTORS,7X,11HCYCLES/MIN.,7X,10HTIME%MIN.,[
111X,4HGAIN,10X,11HPHASE ANGLE,7X,12H-----,7X,11H-----
2-,7X,10H-----,11X,4H-----,10X,11H-----,/[
71    END

```

PHASE ANGLE CALCULATIONS, ED M  
CROSS-REFERENCE DICTIONARY

IBMAP ASSEMBLY PHANGL

## REFERENCES TO DEFINED SYMBOLS

| VALUE   | NAME   | STATEMENT NUMBERS   |
|---------|--------|---|
| 00236   | 101S   | 194   |
| 00250   | 102S   | 125,217   |
| 00145   | 10S    | 212   |
| 00154   | 15S    |   |
| 00226   | 200S   | 254   |
| 00160   | 20S    |   |
| 00202   | 25S    | 252   |
| 00211   | 30S    | 242   |
| 00215   | 35S    | 247   |
| 00016   | 5S     | 261,265,274   |
| 00401   | A      | 188,189,191,203   |
| VIRTUAL | ATAN   | 180   |
| VIRTUAL | EXIT   | 275   |
| VIRTUAL | FILIO. | 126,205,218   |
| VIRTUAL | FILPR. | 124,193,216   |
| 00371   | G      | 175,201   |
| VIRTUAL | HNLIO. | 196,198,200,202,204   |
| 00375   | I      | 129,137,234,236   |
| 00376   | I1     | 116,128,256,267   |
| 00374   | I2     | 118,132,244,249,258,269                                     |
| 00370   | I3     | 120,130,260,271   |
| VIRTUAL | IOHEF. | 37,93   |
| VIRTUAL | IOHFC. | 32  |
| VIRTUAL | IOHHC. | 38,43,48,53,58,63,69,74,79,84,89                            |
| VIRTUAL | IOHIO. | 66,92   |
| VIRTUAL | IOHLP. | 31  |
| VIRTUAL | IOHRP. | 36  |
| VIRTUAL | IOHXC. | 28,34,41,46,51,56,61,67,72,77,82,87                         |
| 00411   | IT     | 152   |
| 00372   | IW     | 149,229,231   |
| 00373   | IWT    | 127,206,208,209,214   |
| VIRTUAL | .EXP3. | 174   |
| VIRTUAL | LITCT. | 115,162,169,207,266,270,272                                 |
| VIRTUAL | LTCR2. |   |
| VIRTUAL | SETFP. | 114   |
| VIRTUAL | S.JXIT | 278   |
| 00353   | SNGCT. | 117,119,121,135,190,210,226,239,245,250,255,257,259,263,268 |
| VIRTUAL | SQRT   | 164   |
| VIRTUAL | STHIO. | 123,192,215   |
| 00404   | TO     | 21,158,178,199  |
| 00400   | W      | 136,156,176,197,225,227                                     |
| 00377   | WTX    | 179,183   |
| 00403   | XI     | 144,145,147,157,172,177,186,195                             |
| 00402   | XXI    | 122,146,238,262,264,273                                     |
| 00232   | D.0000 | 140,143,159,160,161,163,167,168,170,171,173,184,185         |
| 00140   | P.0026 | 211   |
| 00171   | P.0042 | 240,241   |
| 00175   | P.0045 | 246   |
| 00201   | P.0050 | 251   |
| 00161   | S.0073 | 131   |

PHASE ANGLE CALCULATIONS, ED M  
CROSS-REFERENCE DICTIONARY

IBMAP ASSEMBLY

|       |        |         |
|-------|--------|---------|
| 00163 | S.0074 | 133     |
| 00024 | S.0075 | 237     |
| 00043 | S.0076 | 232     |
| 00145 | S.0077 | 154,223 |
| 00047 | S.0100 | 224     |
| 00350 | P.0101 | 304     |
| 00353 | P.0102 | 6       |
| 00350 | P.0103 | 310     |
| 00350 | P.0104 | 139     |
| 00351 | P.0105 | 141     |
| 00352 | P.0106 | 148,151 |

REFERENCES TO LOCATION COUNTERS  
LC START NAME            STARTING AND ENDING STATEMENT NUMBERS

|       |        |                     |
|-------|--------|---------------------|
| 00000 |        | 1-1                 |
| 00350 | DATCT, | 4-4,20-26           |
| 00000 | PLGCT, | 282-298             |
| 00000 | PRGCT, | 2-2,113-281,299-300 |
| 00236 | SFLCT, | 3-3,27-93,301-311   |
| 00350 | STRCT, | 5-19,94-112         |

NO MESSAGES FOR ABOVE ASSEMBLY

PHASE ANGLE CALCULATIONS, ED M

IBLDR -- JOB PHANGL

## M E M O R Y M A P

SYSTEM, INCLUDING IOCS

00000 THRU 12273

FILE BLOCK ORIGIN

12302

NUMBER OF FILES - 1

1. S.FBOU

12302

OBJECT PROGRAM

12325 THRU 16620

|     |               |   |       |
|-----|---------------|---|-------|
| 1.  | DECK @PHANGLE | * | 12325 |
| 2.  | SUBR @OUSYFB@ |   | 00000 |
| 3.  | SUBR @POSTX @ |   | 12740 |
| 4.  | SUBR @CNSTNT@ | * | 13053 |
| 5.  | SUBR @FPR @   |   | 13063 |
| 6.  | SUBR @IOS @   |   | 13064 |
| 7.  | SUBR @RWD @   |   | 13341 |
| 8.  | SUBR @FCV @   |   | 14021 |
| 9.  | SUBR @HCV @   |   | 14113 |
| 10. | SUBR @XCV @   |   | 14216 |
| 11. | SUBR @INTJ @  |   | 14237 |
| 12. | SUBR @FFC @   | * | 14553 |
| 13. | SUBR @FPT @   |   | 15162 |
| 14. | SUBR @XEM @   | * | 15532 |
| 15. | SUBR @XIT @   |   | 15743 |
| 16. | SUBR @XP3 @   |   | 15745 |
| 17. | SUBR @XPN @   |   | 16016 |
| 18. | SUBR @ATN @   |   | 16124 |
| 19. | SUBR @LNG @   |   | 16354 |
| 20. | SUBR @SQR @   |   | 16521 |

\* - INSERTIONS OR DELETIONS MADE IN THIS DECK

INPUT - OUTPUT BUFFERS

77317 THRU 77776

UNUSED CORE

16621 THRU 77313

| <u>NO. REACTORS</u> | <u>CYCLES/MIN.</u> | <u>TIME%MIN.↑</u> | <u>GAIN</u> |
|---------------------|--------------------|-------------------|-------------|
| 1.0000              | 15.0000            | 0.4500            | 0.1465      |
| 1.0000              | 15.0000            | 0.5400            | 0.1225      |
| 1.0000              | 15.0000            | 0.6400            | 0.1036      |
| 1.0000              | 15.0000            | 0.7500            | 0.0885      |
| 1.0000              | 7.5000             | 0.4500            | 0.2841      |
| 1.0000              | 7.5000             | 0.5400            | 0.2397      |
| 1.0000              | 7.5000             | 0.6400            | 0.2040      |
| 1.0000              | 7.5000             | 0.7500            | 0.1750      |
| 1.0000              | 3.7500             | 0.4500            | 0.5098      |
| 1.0000              | 3.7500             | 0.5400            | 0.4428      |
| 1.0000              | 3.7500             | 0.6400            | 0.3846      |
| 1.0000              | 3.7500             | 0.7500            | 0.3350      |
| 1.0000              | 1.8750             | 0.4500            | 0.7643      |
| 1.0000              | 1.8750             | 0.5400            | 0.7027      |
| 1.0000              | 1.8750             | 0.6400            | 0.6402      |
| 1.0000              | 1.8750             | 0.7500            | 0.5795      |
| 1.0000              | 0.9375             | 0.4500            | 0.9214      |
| 1.0000              | 0.9375             | 0.5400            | 0.8922      |
| 1.0000              | 0.9375             | 0.6400            | 0.8575      |
| 1.0000              | 0.9375             | 0.7500            | 0.8180      |
| 1.0000              | 0.4688             | 0.4500            | 0.9785      |
| 1.0000              | 0.4688             | 0.5400            | 0.9694      |
| 1.0000              | 0.4688             | 0.6400            | 0.9578      |
| 1.0000              | 0.4688             | 0.7500            | 0.9434      |
| 1.0000              | 0.2344             | 0.4500            | 0.9945      |
| 1.0000              | 0.2344             | 0.5400            | 0.9921      |
| 1.0000              | 0.2344             | 0.6400            | 0.9889      |
| 1.0000              | 0.2344             | 0.7500            | 0.9849      |
| 1.0000              | 0.1172             | 0.4500            | 0.9986      |
| 1.0000              | 0.1172             | 0.5400            | 0.9980      |
| 1.0000              | 0.1172             | 0.6400            | 0.9972      |
| 1.0000              | 0.1172             | 0.7500            | 0.9962      |
| 1.0000              | 0.0586             | 0.4500            | 0.9997      |
| 1.0000              | 0.0586             | 0.5400            | 0.9995      |
| 1.0000              | 0.0586             | 0.6400            | 0.9993      |
| 1.0000              | 0.0586             | 0.7500            | 0.9990      |



| NO. REACTORS | CYCLES/MIN. | TIME%MIN.C | GAIN   |
|--------------|-------------|------------|--------|
| 2.0000       | 15.0000     | 0.4500     | 0.0807 |
| 2.0000       | 15.0000     | 0.5400     | 0.0575 |
| 2.0000       | 15.0000     | 0.6400     | 0.0416 |
| 2.0000       | 15.0000     | 0.7500     | 0.0306 |
| 2.0000       | 7.5000      | 0.4500     | 0.2599 |
| 2.0000       | 7.5000      | 0.5400     | 0.1961 |
| 2.0000       | 7.5000      | 0.6400     | 0.1479 |
| 2.0000       | 7.5000      | 0.7500     | 0.1122 |
| 2.0000       | 3.7500      | 0.4500     | 0.5841 |
| 2.0000       | 3.7500      | 0.5400     | 0.4938 |
| 2.0000       | 3.7500      | 0.6400     | 0.4098 |
| 2.0000       | 3.7500      | 0.7500     | 0.3358 |
| 2.0000       | 1.8750      | 0.4500     | 0.8489 |
| 2.0000       | 1.8750      | 0.5400     | 0.7960 |
| 2.0000       | 1.8750      | 0.6400     | 0.7353 |
| 2.0000       | 1.8750      | 0.7500     | 0.6692 |
| 2.0000       | 0.9375      | 0.4500     | 0.9574 |
| 2.0000       | 0.9375      | 0.5400     | 0.9398 |
| 2.0000       | 0.9375      | 0.6400     | 0.9174 |
| 2.0000       | 0.9375      | 0.7500     | 0.8900 |
| 2.0000       | 0.4688      | 0.4500     | 0.9890 |
| 2.0000       | 0.4688      | 0.5400     | 0.9842 |
| 2.0000       | 0.4688      | 0.6400     | 0.9780 |
| 2.0000       | 0.4688      | 0.7500     | 0.9700 |
| 2.0000       | 0.2344      | 0.4500     | 0.9972 |
| 2.0000       | 0.2344      | 0.5400     | 0.9960 |
| 2.0000       | 0.2344      | 0.6400     | 0.9944 |
| 2.0000       | 0.2344      | 0.7500     | 0.9923 |
| 2.0000       | 0.1172      | 0.4500     | 0.9993 |
| 2.0000       | 0.1172      | 0.5400     | 0.9990 |
| 2.0000       | 0.1172      | 0.6400     | 0.9986 |
| 2.0000       | 0.1172      | 0.7500     | 0.9981 |
| 2.0000       | 0.0586      | 0.4500     | 0.9998 |
| 2.0000       | 0.0586      | 0.5400     | 0.9997 |
| 2.0000       | 0.0586      | 0.6400     | 0.9996 |
| 2.0000       | 0.0586      | 0.7500     | 0.9995 |

| NO. REACTORS<br>----- | CYCLES/MIN.<br>----- | TIME%MIN.,<br>----- | GAIN<br>----- |
|-----------------------|----------------------|---------------------|---------------|
| 3.0000                | 15.0000              | 0.4500              | 0.0670        |
| 3.0000                | 15.0000              | 0.5400              | 0.0419        |
| 3.0000                | 15.0000              | 0.6400              | 0.0265        |
| 3.0000                | 15.0000              | 0.7500              | 0.0171        |
| 3.0000                | 7.5000               | 0.4500              | 0.2932        |
| 3.0000                | 7.5000               | 0.5400              | 0.2109        |
| 3.0000                | 7.5000               | 0.6400              | 0.1489        |
| 3.0000                | 7.5000               | 0.7500              | 0.1042        |
| 3.0000                | 3.7500               | 0.4500              | 0.6621        |
| 3.0000                | 3.7500               | 0.5400              | 0.5694        |
| 3.0000                | 3.7500               | 0.6400              | 0.4761        |
| 3.0000                | 3.7500               | 0.7500              | 0.3883        |
| 3.0000                | 1.8750               | 0.4500              | 0.8921        |
| 3.0000                | 1.8750               | 0.5400              | 0.8506        |
| 3.0000                | 1.8750               | 0.6400              | 0.8004        |
| 3.0000                | 1.8750               | 0.7500              | 0.7423        |
| 3.0000                | 0.9375               | 0.4500              | 0.9711        |
| 3.0000                | 0.9375               | 0.5400              | 0.9588        |
| 3.0000                | 0.9375               | 0.6400              | 0.9429        |
| 3.0000                | 0.9375               | 0.7500              | 0.9229        |
| 3.0000                | 0.4688               | 0.4500              | 0.9926        |
| 3.0000                | 0.4688               | 0.5400              | 0.9894        |
| 3.0000                | 0.4688               | 0.6400              | 0.9852        |
| 3.0000                | 0.4688               | 0.7500              | 0.9797        |
| 3.0000                | 0.2344               | 0.4500              | 0.9981        |
| 3.0000                | 0.2344               | 0.5400              | 0.9973        |
| 3.0000                | 0.2344               | 0.6400              | 0.9963        |
| 3.0000                | 0.2344               | 0.7500              | 0.9949        |
| 3.0000                | 0.1172               | 0.4500              | 0.9995        |
| 3.0000                | 0.1172               | 0.5400              | 0.9993        |
| 3.0000                | 0.1172               | 0.6400              | 0.9991        |
| 3.0000                | 0.1172               | 0.7500              | 0.9987        |
| 3.0000                | 0.0586               | 0.4500              | 0.9999        |
| 3.0000                | 0.0586               | 0.5400              | 0.9998        |
| 3.0000                | 0.0586               | 0.6400              | 0.9998        |
| 3.0000                | 0.0586               | 0.7500              | 0.9997        |

| NO. REACTORS<br>----- | CYCLES/MIN.<br>----- | TIME*MIN.†<br>----- | GAIN<br>----- |
|-----------------------|----------------------|---------------------|---------------|
| 4.0000                | 15.0000              | 0.4500              | 0.0675        |
| 4.0000                | 15.0000              | 0.5400              | 0.0384        |
| 4.0000                | 15.0000              | 0.6400              | 0.0219        |
| 4.0000                | 15.0000              | 0.7500              | 0.0126        |
| 4.0000                | 7.5000               | 0.4500              | 0.3412        |
| 4.0000                | 7.5000               | 0.5400              | 0.2438        |
| 4.0000                | 7.5000               | 0.6400              | 0.1680        |
| 4.0000                | 7.5000               | 0.7500              | 0.1128        |
| 4.0000                | 3.7500               | 0.4500              | 0.7207        |
| 4.0000                | 3.7500               | 0.5400              | 0.6336        |
| 4.0000                | 3.7500               | 0.6400              | 0.5407        |
| 4.0000                | 3.7500               | 0.7500              | 0.4478        |
| 4.0000                | 1.8750               | 0.4500              | 0.9166        |
| 4.0000                | 1.8750               | 0.5400              | 0.8832        |
| 4.0000                | 1.8750               | 0.6400              | 0.8417        |
| 4.0000                | 1.8750               | 0.7500              | 0.7921        |
| 4.0000                | 0.9375               | 0.4500              | 0.9781        |
| 4.0000                | 0.9375               | 0.5400              | 0.9687        |
| 4.0000                | 0.9375               | 0.6400              | 0.9565        |
| 4.0000                | 0.9375               | 0.7500              | 0.9410        |
| 4.0000                | 0.4688               | 0.4500              | 0.9945        |
| 4.0000                | 0.4688               | 0.5400              | 0.9920        |
| 4.0000                | 0.4688               | 0.6400              | 0.9888        |
| 4.0000                | 0.4688               | 0.7500              | 0.9847        |
| 4.0000                | 0.2344               | 0.4500              | 0.9986        |
| 4.0000                | 0.2344               | 0.5400              | 0.9980        |
| 4.0000                | 0.2344               | 0.6400              | 0.9972        |
| 4.0000                | 0.2344               | 0.7500              | 0.9961        |
| 4.0000                | 0.1172               | 0.4500              | 0.9997        |
| 4.0000                | 0.1172               | 0.5400              | 0.9995        |
| 4.0000                | 0.1172               | 0.6400              | 0.9993        |
| 4.0000                | 0.1172               | 0.7500              | 0.9990        |
| 4.0000                | 0.0586               | 0.4500              | 0.9999        |
| 4.0000                | 0.0586               | 0.5400              | 0.9999        |
| 4.0000                | 0.0586               | 0.6400              | 0.9998        |
| 4.0000                | 0.0586               | 0.7500              | 0.9998        |

| <u>NO. REACTORS</u> | <u>CYCLES/MIN.</u> | <u>TIME%MIN.C</u> | <u>GAIN</u> |
|---------------------|--------------------|-------------------|-------------|
| 5.0000              | 15.0000            | 0.4500            | 0.0747      |
| 5.0000              | 15.0000            | 0.5400            | 0.0400      |
| 5.0000              | 15.0000            | 0.6400            | 0.0210      |
| 5.0000              | 15.0000            | 0.7500            | 0.0111      |
| 5.0000              | 7.5000             | 0.4500            | 0.3912      |
| 5.0000              | 7.5000             | 0.5400            | 0.2833      |
| 5.0000              | 7.5000             | 0.6400            | 0.1954      |
| 5.0000              | 7.5000             | 0.7500            | 0.1294      |
| 5.0000              | 3.7500             | 0.4500            | 0.7636      |
| 5.0000              | 3.7500             | 0.5400            | 0.6841      |
| 5.0000              | 3.7500             | 0.6400            | 0.5955      |
| 5.0000              | 3.7500             | 0.7500            | 0.5030      |
| 5.0000              | 1.8750             | 0.4500            | 0.9322      |
| 5.0000              | 1.8750             | 0.5400            | 0.9044      |
| 5.0000              | 1.8750             | 0.6400            | 0.8694      |
| 5.0000              | 1.8750             | 0.7500            | 0.8267      |
| 5.0000              | 0.9375             | 0.4500            | 0.9824      |
| 5.0000              | 0.9375             | 0.5400            | 0.9748      |
| 5.0000              | 0.9375             | 0.6400            | 0.9649      |
| 5.0000              | 0.9375             | 0.7500            | 0.9522      |
| 5.0000              | 0.4688             | 0.4500            | 0.9956      |
| 5.0000              | 0.4688             | 0.5400            | 0.9936      |
| 5.0000              | 0.4688             | 0.6400            | 0.9911      |
| 5.0000              | 0.4688             | 0.7500            | 0.9877      |
| 5.0000              | 0.2344             | 0.4500            | 0.9989      |
| 5.0000              | 0.2344             | 0.5400            | 0.9984      |
| 5.0000              | 0.2344             | 0.6400            | 0.9978      |
| 5.0000              | 0.2344             | 0.7500            | 0.9969      |
| 5.0000              | 0.1172             | 0.4500            | 0.9997      |
| 5.0000              | 0.1172             | 0.5400            | 0.9996      |
| 5.0000              | 0.1172             | 0.6400            | 0.9994      |
| 5.0000              | 0.1172             | 0.7500            | 0.9992      |
| 5.0000              | 0.0586             | 0.4500            | 0.9999      |
| 5.0000              | 0.0586             | 0.5400            | 0.9999      |
| 5.0000              | 0.0586             | 0.6400            | 0.9999      |
| 5.0000              | 0.0586             | 0.7500            | 0.9998      |

| NO. REACTORS<br>----- | CYCLES/MIN.<br>----- | TIME%MIN. L<br>----- | GAIN<br>----- |
|-----------------------|----------------------|----------------------|---------------|
| 6.0000                | 15.0000              | 0.4500               | 0.0860        |
| 6.0000                | 15.0000              | 0.5400               | 0.0445        |
| 6.0000                | 15.0000              | 0.6400               | 0.0222        |
| 6.0000                | 15.0000              | 0.7500               | 0.0109        |
| 6.0000                | 7.5000               | 0.4500               | 0.4384        |
| 6.0000                | 7.5000               | 0.5400               | 0.3242        |
| 6.0000                | 7.5000               | 0.6400               | 0.2267        |
| 6.0000                | 7.5000               | 0.7500               | 0.1508        |
| 6.0000                | 3.7500               | 0.4500               | 0.7958        |
| 6.0000                | 3.7500               | 0.5400               | 0.7235        |
| 6.0000                | 3.7500               | 0.6400               | 0.6407        |
| 6.0000                | 3.7500               | 0.7500               | 0.5511        |
| 6.0000                | 1.8750               | 0.4500               | 0.9429        |
| 6.0000                | 1.8750               | 0.5400               | 0.9192        |
| 6.0000                | 1.8750               | 0.6400               | 0.8890        |
| 6.0000                | 1.8750               | 0.7500               | 0.8518        |
| 6.0000                | 0.9375               | 0.4500               | 0.9853        |
| 6.0000                | 0.9375               | 0.5400               | 0.9789        |
| 6.0000                | 0.9375               | 0.6400               | 0.9706        |
| 6.0000                | 0.9375               | 0.7500               | 0.9599        |
| 6.0000                | 0.4688               | 0.4500               | 0.9963        |
| 6.0000                | 0.4688               | 0.5400               | 0.9947        |
| 6.0000                | 0.4688               | 0.6400               | 0.9925        |
| 6.0000                | 0.4688               | 0.7500               | 0.9898        |
| 6.0000                | 0.2344               | 0.4500               | 0.9991        |
| 6.0000                | 0.2344               | 0.5400               | 0.9987        |
| 6.0000                | 0.2344               | 0.6400               | 0.9981        |
| 6.0000                | 0.2344               | 0.7500               | 0.9974        |
| 6.0000                | 0.1172               | 0.4500               | 0.9998        |
| 6.0000                | 0.1172               | 0.5400               | 0.9997        |
| 6.0000                | 0.1172               | 0.6400               | 0.9995        |
| 6.0000                | 0.1172               | 0.7500               | 0.9994        |
| 6.0000                | 0.0586               | 0.4500               | 0.9999        |
| 6.0000                | 0.0586               | 0.5400               | 0.9999        |
| 6.0000                | 0.0586               | 0.6400               | 0.9999        |
| 6.0000                | 0.0586               | 0.7500               | 0.9998        |

| NO. REACTORS<br>----- | CYCLES/MIN.<br>----- | TIME%MIN.,<br>----- | GAIN<br>----- |
|-----------------------|----------------------|---------------------|---------------|
| 7.0000                | 15.0000              | 0.4500              | 0.1002        |
| 7.0000                | 15.0000              | 0.5400              | 0.0511        |
| 7.0000                | 15.0000              | 0.6400              | 0.0246        |
| 7.0000                | 15.0000              | 0.7500              | 0.0115        |
| 7.0000                | 7.5000               | 0.4500              | 0.4812        |
| 7.0000                | 7.5000               | 0.5400              | 0.3640        |
| 7.0000                | 7.5000               | 0.6400              | 0.2595        |
| 7.0000                | 7.5000               | 0.7500              | 0.1749        |
| 7.0000                | 3.7500               | 0.4500              | 0.8206        |
| 7.0000                | 3.7500               | 0.5400              | 0.7548        |
| 7.0000                | 3.7500               | 0.6400              | 0.6777        |
| 7.0000                | 3.7500               | 0.7500              | 0.5923        |
| 7.0000                | 1.8750               | 0.4500              | 0.9508        |
| 7.0000                | 1.8750               | 0.5400              | 0.9301        |
| 7.0000                | 1.8750               | 0.6400              | 0.9036        |
| 7.0000                | 1.8750               | 0.7500              | 0.8707        |
| 7.0000                | 0.9375               | 0.4500              | 0.9874        |
| 7.0000                | 0.9375               | 0.5400              | 0.9819        |
| 7.0000                | 0.9375               | 0.6400              | 0.9747        |
| 7.0000                | 0.9375               | 0.7500              | 0.9655        |
| 7.0000                | 0.4688               | 0.4500              | 0.9968        |
| 7.0000                | 0.4688               | 0.5400              | 0.9954        |
| 7.0000                | 0.4688               | 0.6400              | 0.9936        |
| 7.0000                | 0.4688               | 0.7500              | 0.9912        |
| 7.0000                | 0.2344               | 0.4500              | 0.9992        |
| 7.0000                | 0.2344               | 0.5400              | 0.9989        |
| 7.0000                | 0.2344               | 0.6400              | 0.9984        |
| 7.0000                | 0.2344               | 0.7500              | 0.9978        |
| 7.0000                | 0.1172               | 0.4500              | 0.9998        |
| 7.0000                | 0.1172               | 0.5400              | 0.9997        |
| 7.0000                | 0.1172               | 0.6400              | 0.9996        |
| 7.0000                | 0.1172               | 0.7500              | 0.9994        |
| 7.0000                | 0.0586               | 0.4500              | 1.0000        |
| 7.0000                | 0.0586               | 0.5400              | 0.9999        |
| 7.0000                | 0.0586               | 0.6400              | 0.9999        |
| 7.0000                | 0.0586               | 0.7500              | 0.9999        |

| NO. REACTORS<br>----- | CYCLES/MIN.<br>----- | TIME%MIN.C<br>----- | GAIN<br>----- |
|-----------------------|----------------------|---------------------|---------------|
| 8.0000                | 15.0000              | 0.4500              | 0.1164        |
| 8.0000                | 15.0000              | 0.5400              | 0.0595        |
| 8.0000                | 15.0000              | 0.6400              | 0.0282        |
| 8.0000                | 15.0000              | 0.7500              | 0.0127        |
| 8.0000                | 7.5000               | 0.4500              | 0.5193        |
| 8.0000                | 7.5000               | 0.5400              | 0.4015        |
| 8.0000                | 7.5000               | 0.6400              | 0.2923        |
| 8.0000                | 7.5000               | 0.7500              | 0.2005        |
| 8.0000                | 3.7500               | 0.4500              | 0.8402        |
| 8.0000                | 3.7500               | 0.5400              | 0.7800        |
| 8.0000                | 3.7500               | 0.6400              | 0.7084        |
| 8.0000                | 3.7500               | 0.7500              | 0.6274        |
| 8.0000                | 1.8750               | 0.4500              | 0.9567        |
| 8.0000                | 1.8750               | 0.5400              | 0.9384        |
| 8.0000                | 1.8750               | 0.6400              | 0.9148        |
| 8.0000                | 1.8750               | 0.7500              | 0.8854        |
| 8.0000                | 0.9375               | 0.4500              | 0.9890        |
| 8.0000                | 0.9375               | 0.5400              | 0.9841        |
| 8.0000                | 0.9375               | 0.6400              | 0.9778        |
| 8.0000                | 0.9375               | 0.7500              | 0.9697        |
| 8.0000                | 0.4688               | 0.4500              | 0.9972        |
| 8.0000                | 0.4688               | 0.5400              | 0.9960        |
| 8.0000                | 0.4688               | 0.6400              | 0.9944        |
| 8.0000                | 0.4688               | 0.7500              | 0.9923        |
| 8.0000                | 0.2344               | 0.4500              | 0.9993        |
| 8.0000                | 0.2344               | 0.5400              | 0.9990        |
| 8.0000                | 0.2344               | 0.6400              | 0.9986        |
| 8.0000                | 0.2344               | 0.7500              | 0.9981        |
| 8.0000                | 0.1172               | 0.4500              | 0.9998        |
| 8.0000                | 0.1172               | 0.5400              | 0.9997        |
| 8.0000                | 0.1172               | 0.6400              | 0.9996        |
| 8.0000                | 0.1172               | 0.7500              | 0.9995        |
| 8.0000                | 0.0586               | 0.4500              | 1.0000        |
| 8.0000                | 0.0586               | 0.5400              | 0.9999        |
| 8.0000                | 0.0586               | 0.6400              | 0.9999        |
| 8.0000                | 0.0586               | 0.7500              | 0.9999        |

| <u>NO. REACTORS</u> | <u>CYCLES/MIN.</u> | <u>TIME%MIN., t</u> | <u>GAIN</u> |
|---------------------|--------------------|---------------------|-------------|
| 9.0000              | 15.0000            | 0.4500              | 0.1342      |
| 9.0000              | 15.0000            | 0.5400              | 0.0693      |
| 9.0000              | 15.0000            | 0.6400              | 0.0327      |
| 9.0000              | 15.0000            | 0.7500              | 0.0145      |
| 9.0000              | 7.5000             | 0.4500              | 0.5532      |
| 9.0000              | 7.5000             | 0.5400              | 0.4361      |
| 9.0000              | 7.5000             | 0.6400              | 0.3242      |
| 9.0000              | 7.5000             | 0.7500              | 0.2268      |
| 9.0000              | 3.7500             | 0.4500              | 0.8560      |
| 9.0000              | 3.7500             | 0.5400              | 0.8007      |
| 9.0000              | 3.7500             | 0.6400              | 0.7341      |
| 9.0000              | 3.7500             | 0.7500              | 0.6575      |
| 9.0000              | 1.8750             | 0.4500              | 0.9614      |
| 9.0000              | 1.8750             | 0.5400              | 0.9450      |
| 9.0000              | 1.8750             | 0.6400              | 0.9238      |
| 9.0000              | 1.8750             | 0.7500              | 0.8971      |
| 9.0000              | 0.9375             | 0.4500              | 0.9902      |
| 9.0000              | 0.9375             | 0.5400              | 0.9859      |
| 9.0000              | 0.9375             | 0.6400              | 0.9802      |
| 9.0000              | 0.9375             | 0.7500              | 0.9730      |
| 9.0000              | 0.4688             | 0.4500              | 0.9975      |
| 9.0000              | 0.4688             | 0.5400              | 0.9964      |
| 9.0000              | 0.4688             | 0.6400              | 0.9950      |
| 9.0000              | 0.4688             | 0.7500              | 0.9932      |
| 9.0000              | 0.2344             | 0.4500              | 0.9994      |
| 9.0000              | 0.2344             | 0.5400              | 0.9991      |
| 9.0000              | 0.2344             | 0.6400              | 0.9988      |
| 9.0000              | 0.2344             | 0.7500              | 0.9983      |
| 9.0000              | 0.1172             | 0.4500              | 0.9998      |
| 9.0000              | 0.1172             | 0.5400              | 0.9998      |
| 9.0000              | 0.1172             | 0.6400              | 0.9997      |
| 9.0000              | 0.1172             | 0.7500              | 0.9996      |
| 9.0000              | 0.0586             | 0.4500              | 1.0000      |
| 9.0000              | 0.0586             | 0.5400              | 0.9999      |
| 9.0000              | 0.0586             | 0.6400              | 0.9999      |
| 9.0000              | 0.0586             | 0.7500              | 0.9999      |



| <u>NO. REACTORS</u> | <u>CYCLES/MIN.</u> | <u>TIME%MIN. [</u> | <u>GAIN</u> |
|---------------------|--------------------|--------------------|-------------|
| 10.0000             | 15.0000            | 0.4500             | 0.1530      |
| 10.0000             | 15.0000            | 0.5400             | 0.0803      |
| 10.0000             | 15.0000            | 0.6400             | 0.0382      |
| 10.0000             | 15.0000            | 0.7500             | 0.0168      |
| 10.0000             | 7.5000             | 0.4500             | 0.5831      |
| 10.0000             | 7.5000             | 0.5400             | 0.4679      |
| 10.0000             | 7.5000             | 0.6400             | 0.3546      |
| 10.0000             | 7.5000             | 0.7500             | 0.2530      |
| 10.0000             | 3.7500             | 0.4500             | 0.8690      |
| 10.0000             | 3.7500             | 0.5400             | 0.8180      |
| 10.0000             | 3.7500             | 0.6400             | 0.7558      |
| 10.0000             | 3.7500             | 0.7500             | 0.6834      |
| 10.0000             | 1.8750             | 0.4500             | 0.9652      |
| 10.0000             | 1.8750             | 0.5400             | 0.9503      |
| 10.0000             | 1.8750             | 0.6400             | 0.9310      |
| 10.0000             | 1.8750             | 0.7500             | 0.9067      |
| 10.0000             | 0.9375             | 0.4500             | 0.9911      |
| 10.0000             | 0.9375             | 0.5400             | 0.9873      |
| 10.0000             | 0.9375             | 0.6400             | 0.9822      |
| 10.0000             | 0.9375             | 0.7500             | 0.9756      |
| 10.0000             | 0.4688             | 0.4500             | 0.9978      |
| 10.0000             | 0.4688             | 0.5400             | 0.9968      |
| 10.0000             | 0.4688             | 0.6400             | 0.9955      |
| 10.0000             | 0.4688             | 0.7500             | 0.9938      |
| 10.0000             | 0.2344             | 0.4500             | 0.9994      |
| 10.0000             | 0.2344             | 0.5400             | 0.9992      |
| 10.0000             | 0.2344             | 0.6400             | 0.9989      |
| 10.0000             | 0.2344             | 0.7500             | 0.9985      |
| 10.0000             | 0.1172             | 0.4500             | 0.9999      |
| 10.0000             | 0.1172             | 0.5400             | 0.9998      |
| 10.0000             | 0.1172             | 0.6400             | 0.9997      |
| 10.0000             | 0.1172             | 0.7500             | 0.9996      |
| 10.0000             | 0.0586             | 0.4500             | 1.0000      |
| 10.0000             | 0.0586             | 0.5400             | 0.9999      |
| 10.0000             | 0.0586             | 0.6400             | 0.9999      |
| 10.0000             | 0.0586             | 0.7500             | 0.9999      |

PHASE ANGLE CALCULATIONS, ED M

FORTRAN SOURCE LIST

ISN

SOURCE STATEMENT

```
0 $IBFTC DELTA NOLIST,NODECK,REF
1 REAL N,N1,N2,NN
2 DIMENSION N%10[,T0%10[,T1%10[,T2%10[
3 DATA N/2.,2.,3.,3., 6*0./
4 DATA T0/0.45,0.54,0.64,0.75,6*0./
5 DATA T1/0.17,0.18,0.19 ,0.19,6*0./
6 W#7.50
7 DO 30 IN#1,4
10 IT#IN
11 T2%IT[#T0%IT[-T1%IT[
12 PRINT 100
13 PRINT 101,N%IN[,T1%IT[,T2%IT[,T0%IT[,W
14 PRINT 102
15 M#N%IN[*50.
16 N1#0.
17 DO 10 IM#1,M
20 N1#N1&0.02
21 N2#N%IN[-N1
22 G1#%1.0/SQRT%1.0&%W*T1%IT[/N1[[[*N1
23 G2#%1.0/SQRT%1.0&%W*T2%IT[/N2[[[*N2
24 NN#N%IN[
25 G #%1.0/SQRT%1.0&%W*T0%IT[/N%IN[[[*NN
26 DEL#G-G1*G2
27 PRINT 103,N1,N2,G1,G2,G,DEL
30 10 CONTINUE
32 20 CONTINUE
33 30 CONTINUE
35 CALL EXIT
36 100 FORMAT%1H1,8X,1HN,14X,2HT1,13X,2HT2,13X,2HT0,11X,5HOMEGA,/
37 101 FORMAT%5%2X,F13.2[,/[
40 102 FORMAT%/ ,7X,2HN1,13X,2HN2,13X,2HG1,13X,2HG2,13X,1HG,13X,5HDELTA,/
41 103 FORMAT%2%2X,F13.2[,3%F12.3,3X[,E15.8[
42 END
```

PHASE ANGLE CALCULATIONS, ED M  
CROSS-REFERENCE DICTIONARY

IBMAP ASSEMBLY DELTA

## REFERENCES TO DEFINED SYMBOLS

| VALUE          | NAME   | STATEMENT NUMBERS  |
|----------------|--------|--|
| 00231          | 100S   | 174  |
| 00267          | 101S   | 178  |
| 00300          | 102S   | 193  |
| 00341          | 103S   | 277  |
| 00206          | 10S    |  |
| 00212          | 20S    |  |
| 00212          | 30S    |  |
| 00403          | DEL    | 274,288  |
| VIRTUAL EXIT   |        | 306  |
| VIRTUAL FILIO. |        | 175,190,194,290  |
| VIRTUAL FILPR. |        | 173,177,192,276  |
| 00417          | G      | 269,272,286  |
| 00420          | G1     | 233,271,282  |
| 00404          | G2     | 250,270,284  |
| VIRTUAL HNLIO. |        | 181,183,185,187,189,279,281,283,285,287,289                    |
| 00440          | IM     | 204,292,294  |
| 00434          | IN     | 159,163,304  |
| VIRTUAL IOHEC. |        | 131  |
| VIRTUAL IOHEF. |        | 74,83,116,133  |
| VIRTUAL IOHFC. |        | 79,121,126   |
| VIRTUAL IOHHC. |        | 45,50,55,60,65,70,87,92,97,102,107,112                         |
| VIRTUAL IOHIO. |        | 73,82,84,115   |
| VIRTUAL IOHLP. |        | 76,118,125   |
| VIRTUAL IOHRP. |        | 81,123,130   |
| VIRTUAL IOHXC. |        | 48,53,58,63,68,77,85,90,95,100,105,110,119,128                 |
| 00453          | IT     | 164,165  |
| VIRTUAL ,EXP3. |        | 232,249,268  |
| VIRTUAL LITCT. |        | 220,227,237,244,256,263  |
| VIRTUAL LTCR2. |        |  |
| 00370          | M      | 201,205  |
| 00422          | N      | 11,180,195,213,251,254   |
| 00436          | N1     | 202,208,210,211,217,230,278                                    |
| 00421          | N2     | 215,235,247,280  |
| 00437          | NN     | 252,266  |
| VIRTUAL SETFP. |        | 155  |
| VIRTUAL S.JXIT |        | 309  |
| 00365          | SNGCT. | 156,196,209  |
| VIRTUAL SQRT   |        | 222,239,258  |
| VIRTUAL STHIO. |        | 172,176,191,275  |
| 00405          | T0     | 22,169,186,255   |
| 00371          | T1     | 33,168,182,219   |
| 00441          | T2     | 171,184,236  |
| 00435          | W      | 157,188,216,234,253  |
| 00225          | D.0000 | 221,225,226,228,229,231,238,242,243,245,246,248,257,261,262,26 |
| 00013          | S.0043 | 166,218  |
| 00212          | S.0045 | 161,179,212,301  |
| 00007          | S.0046 | 305  |
| 00211          | S.0047 | 206  |
| 00063          | S.0050 | 295  |
| 00362          | P.0051 | 336  |

265,267

PHASE ANGLE CALCULATIONS, ED M  
CROSS-REFERENCE DICTIONARY

IBMAP ASSEMBLY DELTA

|       |        |         |
|-------|--------|---------|
| 00365 | P.0052 | 6       |
| 00362 | P.0053 | 342     |
| 00362 | P.0054 | 158,203 |
| 00363 | P.0055 | 197     |
| 00364 | P.0056 | 303     |

## REFERENCES TO LOCATION COUNTERS

LC START NAME            STARTING AND ENDING STATEMENT NUMBERS

|       |        |                     |
|-------|--------|---------------------|
| 00000 |        | 1-1                 |
| 00362 | DATCT. | 4-4,10-43           |
| 00000 | PLGCT. | 313-330             |
| 00000 | PRGCT. | 2-2,154-312,331-332 |
| 00231 | SFLCT. | 3-3,44-133,333-343  |
| 00362 | STRCT. | 5-9,134-153         |

NO MESSAGES FOR ABOVE ASSEMBLY

PHASE ANGLE CALCULATIONS. ED M

IBLDR -- JOB DELTA

## M E M O R Y M A P

SYSTEM, INCLUDING IOCS

00000 THRU 12273

FILE BLOCK ORIGIN

12302

NUMBER OF FILES - 1

1. S.FBOU 12302

OBJECT PROGRAM

12325 THRU 16676

|     |      |         |     |       |
|-----|------|---------|-----|-------|
| 1.  | DECK | @DELTA  | @   | 12325 |
| 2.  | SUBR | @OJSYFB | @   | 00000 |
| 3.  | SUBR | @PSTX   | @   | 13001 |
| 4.  | SUBR | @CNSTNT | @   | 13114 |
| 5.  | SUBR | @FPR    | @   | 13123 |
| 6.  | SUBR | @INS    | @   | 13124 |
| 7.  | SUBR | @RWD    | @   | 13401 |
| 8.  | SUBR | @ECV    | @   | 14061 |
| 9.  | SUBR | @FCV    | @   | 14327 |
| 10. | SUBR | @HCV    | @   | 14421 |
| 11. | SUBR | @XCV    | @   | 14524 |
| 12. | SUBR | @INTJ   | @   | 14545 |
| 13. | SUBR | @FFC    | @ * | 15061 |
| 14. | SUBR | @FPT    | @   | 15470 |
| 15. | SUBR | @XEM    | @ * | 16040 |
| 16. | SUBR | @XIT    | @   | 16251 |
| 17. | SUBR | @XP3    | @   | 16253 |
| 18. | SUBR | @XP3    | @   | 16324 |
| 19. | SUBR | @LNG    | @   | 16432 |
| 20. | SUBR | @SQR    | @   | 16577 |

\* - INSERTIONS OR DELETIONS MADE IN THIS DECK

INPUT - OUTPUT BUFFERS

77317 THRU 77776

UNUSED CORE

16677 THRU 77313

TABLE 6

COMPUTER DATA FOR DETERMINATION OF  $N_2$   
 (NUMBER OF PERFECT MIXERS IN FLUIDIZED SECTION)

3.75 INCH COLUMN  
 $N=2$

| $N_1$ | $N_2$ | $AR_1$ | $AR_2$ | AR   | Delta<br>( $AR-AR_1 \cdot AR_2$ ) |
|-------|-------|--------|--------|------|-----------------------------------|
| .2    | 1.8   | .819   | .499   | .372 | .0362                             |
| .4    | 1.6   | .751   | .511   | .372 | .0119                             |
| .6    | 1.4   | .710   | .527   | .372 | .0020                             |
| .8    | 1.2   | .683   | .545   | .372 | .0001                             |
| 1.0   | 1.0   | .663   | .568   | .372 | .0044                             |
| 1.2   | 0.8   | .648   | .597   | .372 | .0148                             |
| 1.4   | 0.6   | .636   | .637   | .372 | .0326                             |
| 1.6   | 0.4   | .626   | .693   | .372 | .0616                             |
| 1.8   | 0.2   | .618   | .783   | .372 | .1116                             |

TABLE 7  
 COMPUTER DATA FOR DETERMINATION OF  $N_2$   
 (NUMBER OF PERFECT MIXERS IN FLUIDIZED SECTION)

5.75 INCH COLUMN  
 $N=2$

| $N_1$ | $N_2$ | $AR_1$ | $AR_2$ | $AR$ | Delta<br>( $AR-AR_1 \cdot AR_2$ ) |
|-------|-------|--------|--------|------|-----------------------------------|
| 0.2   | 1.8   | .815   | .438   | .331 | .0266                             |
| 0.4   | 1.6   | .744   | .453   | .331 | .0069                             |
| 0.6   | 1.4   | .702   | .471   | .331 | .0003                             |
| 0.8   | 1.2   | .673   | .493   | .331 | .0014                             |
| 1.0   | 1.0   | .652   | .520   | .331 | .0085                             |
| 1.2   | 0.8   | .636   | .554   | .331 | .0219                             |
| 1.4   | 0.6   | .623   | .600   | .331 | .0432                             |
| 1.6   | 0.4   | .613   | .664   | .331 | .0764                             |
| 1.8   | 0.2   | .604   | .765   | .331 | .1319                             |

TABLE 8

COMPUTER DATA FOR DETERMINATION OF  $N_2$   
 (NUMBER OF PERFECT MIXERS IN FLUIDIZED SECTION)

7.75 INCH COLUMN  
 $N=3$

| $N_1$ | $N_2$ | $AR_1$ | $AR_2$ | AR   | Delta<br>( $AR-AR_1 \cdot AR_2$ ) |
|-------|-------|--------|--------|------|-----------------------------------|
| 0.3   | 2.7   | .769   | .335   | .239 | .0188                             |
| 0.6   | 2.4   | .694   | .349   | .239 | .0035                             |
| 0.9   | 2.1   | .652   | .366   | .239 | .000003                           |
| 1.2   | 1.8   | .625   | .387   | .239 | .0031                             |
| 1.5   | 1.5   | .606   | .413   | .239 | .0118                             |
| 1.8   | 1.2   | .592   | .448   | .239 | .0265                             |
| 2.1   | 0.9   | .581   | .496   | .239 | .0494                             |
| 2.4   | 0.6   | .572   | .567   | .239 | .0856                             |
| 2.7   | 0.3   | .564   | .687   | .239 | .1489                             |



TABLE 9

COMPUTER DATA FOR DETERMINATION OF  $N_2$   
 (NUMBER OF PERFECT MIXERS IN FLUIDIZED SECTION)

9.75 INCH COLUMN  
 $N=3$

| $N_1$ | $N_2$ | $AR_1$ | $AR_2$ | AR   | Delta<br>( $AR-AR_1 \cdot AR_2$ ) |
|-------|-------|--------|--------|------|-----------------------------------|
| 0.3   | 2.7   | .769   | .282   | .205 | .0116                             |
| 0.6   | 2.4   | .694   | .297   | .205 | .0010                             |
| 0.9   | 2.1   | .652   | .316   | .205 | .0007                             |
| 1.2   | 1.8   | .625   | .338   | .205 | .0064                             |
| 1.5   | 1.5   | .606   | .367   | .205 | .0175                             |
| 1.8   | 1.2   | .592   | .406   | .205 | .0348                             |
| 2.1   | 0.9   | .581   | .458   | .205 | .0608                             |
| 2.4   | 0.6   | .572   | .536   | .205 | .1011                             |
| 2.7   | 0.3   | .564   | .666   | .205 | .1707                             |