

## **Copyright Warning & Restrictions**

The copyright law of the United States (Title 17, United States Code) governs the making of photocopies or other reproductions of copyrighted material.

Under certain conditions specified in the law, libraries and archives are authorized to furnish a photocopy or other reproduction. One of these specified conditions is that the photocopy or reproduction is not to be “used for any purpose other than private study, scholarship, or research.” If a user makes a request for, or later uses, a photocopy or reproduction for purposes in excess of “fair use” that user may be liable for copyright infringement,

This institution reserves the right to refuse to accept a copying order if, in its judgment, fulfillment of the order would involve violation of copyright law.

**Please Note: The author retains the copyright while the New Jersey Institute of Technology reserves the right to distribute this thesis or dissertation**

Printing note: If you do not wish to print this page, then select “Pages from: first page # to: last page #” on the print dialog screen

The Van Houten library has removed some of the personal information and all signatures from the approval page and biographical sketches of theses and dissertations in order to protect the identity of NJIT graduates and faculty.

71-908

ZALEWSKI, William Charles, 1942-  
A STUDY OF THE DYNAMICS OF GAS ADSORPTION  
IN AN AIR FLUIDIZED BED.

Newark College of Engineering, D.Eng.Sc., 1970  
Engineering, chemical

University Microfilms, A XEROX Company, Ann Arbor, Michigan

PLEASE NOTE:

Some pages have indistinct  
print. Filmed as received.

UNIVERSITY MICROFILMS.

A STUDY OF THE DYNAMICS OF GAS ADSORPTION  
IN AN AIR FLUIDIZED BED  
BY  
WILLIAM CHARLES ZALEWSKI

A DISSERTATION  
PRESENTED IN PARTIAL FULFILLMENT OF  
THE REQUIREMENTS FOR THE DEGREE  
OF  
*ENGINEERING*  
DOCTOR OF SCIENCE IN CHEMICAL ENGINEERING  
AT  
NEWARK COLLEGE OF ENGINEERING

This dissertation is to be used only with due regard to the rights of the author. Bibliographical references may be noted, but passages must not be copied without permission of the College and without credit being given in subsequent written or published work.

Newark, New Jersey

1970

APPROVAL OF DISSERTATION  
A STUDY OF THE DYNAMICS OF GAS ADSORPTION  
IN AN AIR FLUIDIZED BED  
BY  
WILLIAM CHARLES ZALEWSKI  
FOR  
DEPARTMENT OF CHEMICAL ENGINEERING  
NEWARK COLLEGE OF ENGINEERING

BY  
FACULTY COMMITTEE

APPROVED: \_\_\_\_\_ CHAIRMAN

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

NEWARK, NEW JERSEY

JUNE, 1970

## ABSTRACT

The dynamics of gas adsorption was studied in an air fluidized bed containing activated alumina particles. The adsorption studies made with a fixed bed and in the transition region between minimum fluidization velocity and 2.0 times minimum fluidization velocity, compliment work done at higher velocities. With adsorption, particle motion controlled the overall dynamics of the fluidized bed. A different approach in applying the two phase fluidization model was necessary to satisfactorily describe unsteady state adsorption in fluidized beds. Experimental and theoretical results were compared in frequency response plots to obtain a rigorous comparison. Good agreement was obtained for flow rates at 1.1, 1.28 and 1.65 times minimum fluidization velocity. Fluidization was found to be incomplete at the lower flow rates.

An adsorbable and non-adsorbable tracer were used in the study, "Freon-12" and helium respectively. The packed bed region was studied to obtain the kinetics of adsorption with "Freon-12". The results using helium tracer were found to be inconclusive in the fluidized bed region. The combination of the mixing model with bypassing, and the adsorption kinetics in a unique fashion, provided theoretical curves consistent with experimental results.

## PREFACE

Much progress has recently been made in studying fluidized bed processes. It appears that it will be only a matter of time when design of fluidized bed reactors can be made more accurate. There is still much work to be done so design with slightly complicated reactions, such as heterogeneous catalytic reactions, can be undertaken with a fair degree of accuracy. In this work, a mathematical model was developed which can describe the contacting of gaseous reactant with solid catalyst in the unsteady state.

It is the scope of this dissertation to describe the mathematical model which was applied successfully to predict unsteady-state behavior of gas fluidized beds when adsorption is occurring. It is not yet possible to be all inclusive and state that the procedures proposed will be feasible in all cases, since only a narrow region was studied. However, the results indicate that the same model can be applied at higher fluidization velocities.



### ACKNOWLEDGMENTS

The writer is grateful to be the recipient of a National Defense Education Act Title IV Fellowship at Newark College of Engineering. Without this support this dissertation would have been extremely difficult to prepare.

The aid given by his advisor, Dr. Deran Hanesian, is deeply appreciated. His guidance and aid made the experimental work and preparation of this paper an enjoyable experience.

The writer wishes to thank the entire Department of Chemical Engineering in addition to his Faculty Committee who freely provided their advice and encouragement during the experimental phase of this study.

Not to be forgotten are his wife, Terry, who provided moral support during those years of graduate study and Mary Coleman who did an excellent job of typing and editing.

## TABLE OF CONTENTS

	Page
PREFACE.....	iv
ACKNOWLEDGMENTS.....	v
LIST OF FIGURES.....	viii
LIST OF TABLES.....	ix
 Chapter	
I INTRODUCTION.....	1
II BACKGROUND.....	3
III THEORY.....	9
IV EXPERIMENTAL APPARATUS.....	38
V EXPERIMENTAL PROCEDURE.....	49
VI EXPERIMENTAL RESULTS.....	53
VII DISCUSSION OF EXPERIMENTAL RESULTS.....	69
VIII CONCLUSIONS.....	79
IX RECOMMENDATIONS.....	81
REFERENCES.....	84
NOMENCLATURE.....	87
APPENDIX I - ROTAMETER CALIBRATION CURVES.....	92
APPENDIX II - MATHEMATICAL DEVELOPMENT.....	96
Two Region Model.....	97
Adsorption Equations.....	105
Plug Flow Model with Adsorption.....	108

	Page
APPENDIX III - COMPUTER PROGRAMS.....	110
DPLS - Double Precision Fourier Generator.....	111
NLIN1 - Nonlinear Regression.....	122
MOD - Two Region Model.....	150
APPENDIX IV - CALCULATIONS.....	155
Calculated Phase Angle Shift.....	156
APPENDIX V - COMPUTED DATA.....	157
NLIN1 - Plug Flow Results.....	158
DPLS - Experimental Transfer Functions.....	173
MOD - Theoretical Transfer Functions.....	309
APPENDIX VI - RAW DATA.....	312
VITA.....	350

## LIST OF FIGURES

Figure	Page
1. PULSES	19
2. APPARATUS SCHEMATIC	39
3. DISTRIBUTOR DETAILS	40
4. CALMING SECTION DETAILS	41
5. FLOW DIAGRAM OF SAMPLING CIRCUIT	43
6. POWER SUPPLY AND BRIDGE CIRCUIT	45
7. CONDUCTIVITY CELL CALIBRATION	48
8. PRESSURE DROP VS FLOW RATE	50
9. INPUT AND OUTPUT HISTORY HELIUM TRACER - PACKED BED	54
10. INPUT AND OUTPUT HISTORY "FREON-12" TRACER - PACKED BED	55
11. INPUT AND OUTPUT HISTORY HELIUM TRACER - FLUIDIZED BED	56
12. INPUT AND OUTPUT HISTORY "FREON-12" TRACER - FLUIDIZED BED	57
13. BODE PLOT - $U = 0.1175$ FT./SEC.	59
14. BODE PLOT - $U = 0.219$ FT./SEC.	60
15. BODE PLOT - $U = 0.264$ FT./SEC.	61
16. BODE PLOT - $U = 0.309$ FT./SEC.	62
17. BODE PLOT - $U = 0.399$ FT./SEC.	63
18. MAIN AIR FLOW CALIBRATION	93
19. REFERENCE AND SAMPLE FLOW CALIBRATION	94
20. BLEED FLOW CALIBRATION	95

LIST OF TABLES

Table		Page
I	MODEL EQUATIONS	32
II	MODEL PARAMETERS	73
III	CALCULATED PHASE ANGLE SHIFTS	156
IV - XXXVII	DPLS COMPUTER RESULTS	173-308
XXXVIII	MEASURED TOTAL LAG TIMES	313

## I. INTRODUCTION

Realizing the growing use of fluidized bed processes in industry, many investigations of the behavior of fluidized beds have been made. Much of the earlier work involved finding ways to predict steady-state conversions in fluidized bed reactors. These studies utilized mixing models, backmix studies, and residence time distributions. The kinetics studies were primarily first order or pseudo-first order irreversible reactions.

The trend in the past has been toward the study, in a well fluidized state, to find the residence time distribution of the gas in the bed. Using the distribution or a suitable model, first order irreversible kinetics was introduced to predict steady-state conversions for the reactor. This approach has been questioned when heterogeneous reactions occur since particle behavior was not studied in relation to gas behavior. Still, steady-state behavior was the primary goal of previous investigations.

It was the purpose of this study to find a suitable model which will take into account the contacting of gas and solid and predict the unsteady-state response. This was done by finding the experimental transfer

function of the fluidized bed by pulse testing techniques. Mathematical models were hypothesized and their transfer functions were compared with experimental results. When the model exhibited the proper behavior, its parameters were adjusted to match experimental results. These parameters, in turn, were studied to develop reasonable correlations which could be used to predict behavior at other conditions.

The system studied used Alcoa F-1 activated alumina particles fluidized with air. Tracers used for pulse testing were helium and "Freon-12". Flow rates used were .49, .91, 1.1, 1.28, and 1.65 times minimum fluidization velocity. Reactor diameter was six inches and aspect (length/diameter) ratio of the bed was 1.2.

## II. BACKGROUND

Early investigations of fluidized beds started with attempts to define the gas flow behavior. Gilliland and Mason<sup>6</sup>, using helium tracer in an air fluidized bed of glass particles, found that the gas mixing can be described as a combination of complete mixing and gas bypassing. Their experiments also demonstrated that the gas concentration can be different in the bubbles and in the dense regions. The results of back-mixing studies showed that tracer gas could be detected upstream from the point where it was injected. Thus, any model proposed would have to take this reversal of flow into account.

Since there are two types of fluidized beds, particulate and aggregate, which have easily recognizable and different flow patterns, there would have to be two types of classifications of models which would have to be used. With particulate fluidization, each individual particle is independently supported by the fluidizing medium. Some gas-solid systems exhibit particulate fluidization but this behavior is more common with liquid-solid systems. The simple dispersion or the tanks-in-series models have been used to describe flow behavior in these systems.<sup>10</sup>



With aggregate fluidized beds the simple models have not given good results.<sup>2</sup> Two region models have been used with varying degrees of success. These types of models presuppose that flow through a fluidized bed occurs two ways, one through the region created by the bubbles and the other region where the bulk of the particles is present. There is also some degree of interchange between these two regions caused by movement of the gas and by movement of the particles carrying adsorbed and occluded gas. The interchange coefficient has been shown to be higher using conversion data than by using residence time distributions. This tends to indicate that interchange is affected by adsorption on the particles.

Naor and Shinnar,<sup>18</sup> by using a method based on the use of intensity functions, were able to demonstrate that fluidized beds can be represented by a system possessing two parallel pathways with strongly differing residence times. Hence, a two region model seems to be a good choice for aggregate fluidized beds.

Solution of the general equations of the two region model involves the assumption of type of flow in each region. Idealized flows are used to simplify the expression so solutions can be attempted.

The more complicated a flow model, the larger the number of parameters that must be evaluated. The two region model has been studied with varying degrees of complexity and most of these studies are summarized by Levenspiel<sup>10</sup> and Kato and Wen.<sup>8</sup>

Mathematical models which are closely connected to bubble dynamics have been proposed by Orcutt et al.,<sup>19</sup> Davidson and Harrison,<sup>4</sup> Rowe,<sup>22</sup> Murray,<sup>17</sup> Kunii and Levenspiel,<sup>9</sup> and Kato and Wen.<sup>8</sup> These models, however, were derived for the steady state.

Barnstone and Harriot<sup>1</sup> have taken the models of Orcutt, Davidson, and Pigford<sup>19</sup> and extended them to include the unsteady-state response. The models were tested using frequency response techniques with helium tracer. They were able to distinguish between different flow patterns and evaluate the parameters of the models without too much difficulty.

Work with fluidized beds has also been done to predict conversions for chemical reactions in a fluidized bed. The investigators in this area selected a flow model and introduced the kinetics of the reaction they were studying. This usually was a first order or pseudo-first order irreversible reaction. For these studies, operation was at steady state in all cases.

Studies of fluidized beds with reaction have been made by Massimilla and Johnstone,<sup>13</sup> May,<sup>15</sup> Mathis and Watson,<sup>14</sup> and Orcutt et al.<sup>19</sup>

Echigoya et al.<sup>5</sup> have questioned the use of residence time distributions or models which describe the residence time distribution to predict the conversion for heterogeneous reactions in fluidized beds. It has been suggested that a contact time distribution would be more appropriate since the reactants must contact the solid in order to react. They conducted experiments with adsorbable and non-adsorbable gases and found that the contact time distribution was indeed different from the residence time distribution and that the mean contact time was shorter than the mean residence time. Their predicted conversions using the experimentally derived contact time distribution showed excellent agreement with experimental conversions.

Yoshida and Kunii<sup>23</sup> used adsorbable and non-adsorbable gases and, using Kunii and Levenspiel's model,<sup>9</sup> were able to predict, reasonably well, the gas residence time distribution when either type of gas was used. Miyauchi et al.<sup>16</sup> used adsorbable and non-adsorbable gases in a gas fluidized bed to develop a good correlation for dispersion coefficients.

From the study of the work of previous investigators, a fluidized bed model can be hypothesized which can explain the behavior of fluidized beds in unsteady-state operation. This model would have the following characteristics:

1. The model would be composed of two regions, a bubble region and an emulsion region. These regions would have either strongly differing residence times or different flow patterns. The concentrations of a gaseous tracer could be different in the two regions.
2. The bubble region would be described by a flow model which would take into account the mixing of the gas in the bubble with the volume surrounding it, called the bubble cloud.
3. There would be an interchange of material between the bubble cloud and the emulsion region. This would occur because of the concentration difference between the two regions and by movement of the fluidized particles between the two regions. The particles would have occluded material or material adsorbed on the surface.

4. Depending on bubble size and height of bed, a certain amount of gaseous material would bypass the bed.
5. At low fluidization velocities, certain portions of the emulsion phase would become dead space.

### III. THEORY

The physical system studied was a six-inch diameter fluidized bed. The concentration changes of a tracer in the gas flowing through the bed and the type of mixing taking place were investigated. If the functional relationship between varying input and output concentrations of the gaseous solution flowing through the bed can be found, the dynamic properties may be determined. This relationship is commonly called the transfer function of the system.<sup>3</sup> A simplified discussion follows describing the method of using pulses to derive the frequency response characteristics of a system.

It will be assumed that the system studied is one whose behavior can be described by linear differential equations with constant coefficients. If the system is one whose behavior can be expressed by an  $n^{\text{th}}$  order linear differential equation, it can be expressed mathematically as

$$\sum_{k=0}^n a_k \frac{d^k}{dt^k} [y(t)] = x(t) \quad (1)$$

where

$a_k$  - a constant

$y(t)$  - output variable as a function of time

$\frac{d^k}{dt^k}$  -  $k^{\text{th}}$  derivative of the output variable as a function of time

$x(t)$  - input variable as a function of time

If the input variable is a constant, then steady-state conditions would exist. The derivatives would equal zero and a steady-state value of output would be attained.

Thus:

$$y(t)_{s.s.} = \frac{1}{a_0} X_{s.s.} = \text{a constant} \quad (2)$$

When the input variable is a function of time, that is,  $x = x(t)$ , then

$$\sum_{k=0}^n a_k \frac{d^k}{dt^k} [y(t)] = x(t) \quad (3)$$

Applying the Laplace transform with respect to time and assuming initially that the first  $n-1$  derivatives of the variable  $y(t)$  are equal to zero, the above equation becomes:

$$\left( \sum_{k=0}^n a_k s^k \right) Y(s) = X(s) \quad (4)$$

where

$$Y(s) = \int_0^{\infty} e^{-st} y(t) dt$$

$$X(s) = \int_0^{\infty} e^{-st} x(t) dt$$

The ratio of the output function to the input function is called the transfer function which is defined as:

$$\frac{Y(s)}{X(s)} = \frac{\int_0^{\infty} e^{-st} y(t) dt}{\int_0^{\infty} e^{-st} x(t) dt} = T.F. \quad (5)$$

If  $x(t)$  and  $y(t)$  are piecewise continuous functions which depict bounded variations of process variables which return to their initial values after a finite length of time and remain there, then these functions may be called pulses. The integrals can have different upper limits but still will exist.

$$T.F. = \frac{\int_0^{T_y} e^{-st} y(t) dt}{\int_0^{T_x} e^{-st} x(t) dt} \quad (6)$$



where

$T_y$  - duration time of the output pulse

$T_x$  - duration time of the input pulse

By replacing  $s$  by  $i\omega$ , where  $i$  is  $\sqrt{-1}$ , the steady state response of the system to a sinusoidally varying input of frequency  $\omega$  can be found. The transfer function becomes

$$T.F.(i\omega) = \frac{\int_0^{T_y} e^{-i\omega t} y(t) dt}{\int_0^{T_x} e^{-i\omega t} x(t) dt} \quad (7)$$

Applying Euler's relationship

$$e^{-i\omega t} = \cos \omega t - i \sin \omega t \quad (8)$$

The transfer function in the frequency domain becomes

$$T.F.(i\omega) = \frac{\int_0^{T_y} y(t) \cos \omega t dt - i \int_0^{T_y} y(t) \sin \omega t dt}{\int_0^{T_x} x(t) \cos \omega t dt - i \int_0^{T_x} x(t) \sin \omega t dt} \quad (9)$$

One of the methods described by Clements and Schnelle<sup>3</sup> has been widely used to obtain system transfer functions from pulse testing data. The TAFT method, as it is sometimes called, evaluates the transfer function by evaluating the integral above numerically using a quadrature formula. Hays et al.<sup>7</sup> have presented a method which is more efficient and more flexible. It involves evaluating the equations describing the pulse and performing the integration analytically.

Assume the pulse,  $f(t)$ , can be represented by a function made up of a series of polynomial segments. Ordinary discontinuities are allowed in the function and its derivatives at the union of the segments. The equation of this function can be represented using a series of the form

$$f(t) = \sum_{j=1}^n u(t-T_j) \left[ A_j + B_j(t-T_j) + \frac{C_j(t-T_j)^2}{2!} + \frac{D_j(t-T_j)^3}{3!} + \dots \right] \quad (10)$$

The notation  $u(t-T_j)$  represents the unit step function.  $A_j$  is the change in the value of the function at the boundary between the interval  $T_{j-1}$  and  $T_j$ ,  $B_j$  is the

change of the value of the first derivative,  $C_j$  is the change of the value of the second derivative, etc.

The Laplace transform with respect to time of the above equation is

$$F(s) = \sum_{j=1}^n \left[ \frac{A_j}{s} + \frac{B_j}{s^2} + \frac{C_j}{s^3} + \frac{D_j}{s^4} + \dots \right] e^{-T_j s} \quad (11)$$

If the function  $f(t)$  is Fourier transformable,  $i\omega$  can be substituted for  $s$  to give the Fourier transform

$$F(i\omega) = \sum_{j=1}^n \left[ \frac{A_j}{i\omega} + \frac{B_j}{-\omega^2} + \frac{C_j}{(i\omega)^3} + \frac{D_j}{\omega^4} + \dots \right] e^{-i\omega T_j} \quad (12)$$

Applying Euler's relationship

$$e^{-i\omega t} = \cos \omega t - i \sin \omega t \quad (13)$$

$F(i\omega)$  can be written in terms of its real and imaginary parts

$$\begin{aligned}
 R(\omega) = & \sum_{j=1}^n \left[ -\frac{A_j}{\omega} + \frac{C_j}{\omega^3} - \dots \right] \sin \omega T_j \\
 & + \left[ -\frac{B_j}{\omega^2} + \frac{D_j}{\omega^4} - \dots \right] \cos \omega T_j
 \end{aligned} \tag{14}$$

$$\begin{aligned}
 I(\omega) = & \sum_{j=1}^n \left[ -\frac{A_j}{\omega} + \frac{C_j}{\omega^3} - \dots \right] \cos \omega T_j \\
 & - \left[ -\frac{B_j}{\omega^2} + \frac{D_j}{\omega^4} - \dots \right] \sin \omega T_j
 \end{aligned} \tag{15}$$

where

$$F(i\omega) = R(\omega) + i I(\omega) \tag{16}$$

The above technique was used to evaluate the Fourier transform of the input and outlet pulses. A computer program, DPLS, was written which would evaluate the data using step, straight and parabolic segments to describe the pulse. The use of straight line segments was found to be best suited for the type of pulses used in the experiments.

The computer program was tested by using functions where the frequency response characteristics were known. It was found that the step approximation to the curves gave results which were similar to those given by the TAFT method. The use of straight line segments produced

the closest fit in approximating the shape of the curves. Approximating the shape of the curve with parabolic segments gave results similar to those using straight line segments at low frequencies. At high frequencies the results became erratic. It was determined that the use of the second derivatives, which were necessary with parabolic segments, were causing the erratic results.

The transfer function is a complex number which can be represented vectorially in the complex plane by a magnitude and an angle measured with respect to the positive real axis for any value of  $w$ . It is convenient to display the transfer function on logarithmic coordinates, two graphs being required. One is a graph of the logarithm of the magnitude of the transfer function versus the logarithm of frequency. The other is a graph of the angle or phase versus the logarithm of frequency. The combination of the two graphs is called the Bode diagram of the transfer function.

The Bode diagram drawn from the results of pulse testing is exactly similar to one drawn from the results of direct frequency response measurements. By introducing a sinusoidally varying input to the system, the system being linear, a sinusoidally varying output of

the same frequency as the input will be present when transient conditions have vanished. The ratio of the amplitude of the output wave to the input is the magnitude ratio, which is equivalent to the magnitude ratio of the transfer function at the same frequency given by pulse testing. The magnitude ratio is also called the amplitude ratio. The phase difference between the input and output waves by direct testing is equivalent to the angle given by pulse testing. This angle is commonly called the phase angle.

The magnitude ratio and phase angle derived from pulse testing are

$$M.R. = \sqrt{[R(\omega)]^2 + [I(\omega)]^2} \quad (17)$$

$$\phi = \text{phase angle} = \tan^{-1} \frac{I(\omega)}{R(\omega)} \quad (18)$$

To determine the transfer function from experimental data, the one sided Fourier integrals must be evaluated. The function  $x(t)$  describes the pulse put into the fluidized

bed. Since this study utilized concentration changes, the pulse was a deviation from the initial concentration of tracer (namely zero concentration) in the inlet air to the bed. When the pulse was introduced, there was a delay before the concentration change was detected at the top of the bed. The delay was caused by the lag in the outlet sampling device and the time it took the tracer to travel through the bed. The delay from the sampling device was subtracted from the total delay time giving the delay time caused by the bed.

The delay time in the bed is part of the transfer function of the bed. However, in the analysis of the experimental pulses, it may be treated separately. If the input variable is  $x(t)$ , then the output can be expressed as  $y(t) = z(t - L)$  where  $L$  is the delay time. See Figure No. 1.  $t' = 0$  would express the origin moved  $L$  time units to the right of  $t = 0$ .

The delay time delays the function in time without otherwise altering it. Using the Laplace transform

$$Y(s) = \int_0^{\infty} z(t-L) e^{-st} dt \quad (19)$$





FIGURE 1 PULSES



where

$$Z(t') = 0 \text{ for } t' < 0$$

Changing the variable under the integral sign by replacing  $(t - L)$  by  $t'$ :

$$Y(s) = \int_0^{\infty} Z(t') e^{-s(t'+L)} dt' \quad (20)$$

where  $t$  and  $t'$  are values of time measured from different origins  $L$  time units apart on the abscissa.

Since  $L$  is constant

$$Y(s) = e^{-Ls} \int_0^{\infty} e^{-st'} Z(t') dt' \quad (21)$$

By the definition of the Laplace transform

$$Y(s) = e^{-Ls} Z(s) \quad (22)$$

Since the transfer function is expressed as

$$T.F. = \frac{Y(s)}{X(s)} \quad (23)$$

delay time can be treated separately and

$$T.F. = e^{-Ls} \frac{Z(s)}{X(s)} = G_d \frac{Z(s)}{X(s)} \quad (24)$$

Treating the dead time element  $G_d$  separately  $s$  is replaced by  $iw$

$$G_d = e^{-i\omega L} \quad (25)$$

Applying Euler's relation, the magnitude ratio of the dead time element is

$$M.R. = \sqrt{\cos^2 \omega L + \sin^2 \omega L} = 1 \quad (26)$$

The phase angle contribution of the dead time element is

$$\phi = \tan^{-1} \left[ \frac{-\sin wL}{\cos wL} \right] = -wL \quad (27)$$

Since the magnitude ratio is one, dead time has no effect on the magnitude ratio of the measured transfer function. It has the characteristic of a pure phase shift.

After the pulse is introduced into the fluidized bed, the delay will occur and then the output concentration will deviate from initial conditions to return after a finite length of time. This deviation is the output pulse and is defined as  $z(t)$ . To obtain the transfer function of the system, the integrals in (9) must be evaluated from the experimental data; that is, the input and output histories of concentration must be observed.

Based on the previous discussion of the dead time element ending with equations (26) and (27), the altitudes of the input and output pulses were read using different time origins. The values for  $t = 0$  (input pulse origin) and  $t' = 0$  (output pulse origin) were chosen at the points where the measured altitude deviated from the base line. The dead time was then treated separately by measuring  $L$  which was defined by


$$L = \left[ \frac{\text{time origin for output pulse}}{t' = 0} \right] - \left[ \frac{\text{time origin for input pulse}}{t = 0} \right] \quad (28)$$

The computer program, DPLS, calculated the values of the frequency response curves without the dead time correction and with the dead time correction. In the event that the measured dead times had to be adjusted, the corrections in the phase angle could be made without the use of the computer.

The fit of the transfer function in the frequency domain would be preferred to the fit of responses in the time domain because the effect of the phase angle is taken into account. To evaluate the parameters in a distributed parameter system, the method of moments is normally used.<sup>7</sup> This method has two important disadvantages. First, numerical errors associated with the computation of moment can be large since they weigh heavily the tail portion of the experimental time curve. The measured curves are least accurate in the tail portion. Second, the applicability of a theoretical model cannot be determined using the method of moments. The effect of each parameter in the theoretical model is more easily determined in the frequency domain than in the time domain.

For complicated models the predicted response  $y_p(t)$  may be very difficult to find if a fit in the time domain were attempted. A numerical technique is necessary to obtain  $y_p(t)$  from the frequency domain and introduces error.

The mixing model used is the two phase mixing model with bypassing. It was formulated using a staging procedure to predict operation of fluidized beds with high aspect ratios.



The model is composed of three regions, an idealized plug flow region, an ideal completely mixed region, and a bypass region. The model is a modification of a model described by Barnstone and Harriot.<sup>1</sup>

Before formulating the mathematics, it is necessary to provide the background which has gone into developing this model. Davidson and Harrison<sup>4</sup> have determined theoretically and experimentally that there exists a volume outside the rising bubble which is affected by the bubble which has been defined as a cloud. Within the bubble and cloud, the gas circulates in a circular pattern. The volume of the cloud with relation to bubble size is dependent on bubble diameter and minimum fluidization velocity. This cloud and a portion of the bubble volume will be considered the lean phase. The remainder of the bed where solids are present will be the dense phase.

The following conditions have been noted in fluidized beds:

1. At minimum fluidizing conditions, the solids are relatively quiescent. The only noticeable mixing occurs around the vicinity of the rising bubbles. Around minimum fluidizing conditions, a portion of the bubble and all of the cloud volume would be considered completely mixed. Gas bypassing the bed will be through the remaining portion of the bubble volume. The dense phase will be considered to be operating in a plug flow condition.
2. At higher gas velocities, the rising bubbles cause the observed mixing and flow of solids. At these flows there is much more mixing occurring. This mixing should be apparent by an increase in the fraction of bed completely mixed, with a corresponding decrease in plug flow volume. If reaction or adsorption is taking place, the contacting efficiency of the plug flow region will also decrease due to particle motion in this region.

The dense phase will always be considered operating at minimum fluidization conditions, i.e. superficial gas velocity through the dense phase and porosity will be at  $u_{mf}$  and  $\epsilon_{mf}$  respectively.

The following quantities are also defined:

$$\delta_l = \frac{\text{volume of solids in lean phase}}{\text{volume of lean phase}} \quad (29)$$

$$\delta_d = \frac{\text{volume of solids in dense phase}}{\text{volume of dense phase}} \quad (30)$$

A theoretical correlation exists from Davidson and Harrison's work<sup>4</sup> for  $\delta_l$  but this is for a single bubble. Experimental evidence indicates that the volume fraction of solids calculated for single bubbles is less than that for beds with coalescence of bubbles taking place. Hence, the theoretical volume fraction would give a lower limit for volume fractions of solids in the lean phase.

In developing the model, a material balance is necessary for gas flow through the various phases.

$$V_p u_p + V_b u_b + V_{by} u_{by} = u \quad (31)$$

where

$V_p$  - volume fraction of bed in plug flow

$u_p$  - superficial velocity through the plug flow region, ft/sec.

- $u$  - overall superficial velocity into the bed,  
 ft/sec.  
 $V_b$  - volume fraction of bed in backmix flow  
 $u_b$  - superficial velocity through the backmix  
 flow region, ft/sec.  
 $v_{by}$  - volume fraction of bed bypassed  
 $u_{by}$  - velocity through bypass region, ft./sec.

The material balance per unit volume of bed per stage

Plug Flow Phase -  $n^{\text{th}}$  Stage

$$\begin{aligned}
 \left[ \text{Accumulation of material} \right] &= \left[ \text{Material transferred from backmix phase} \right] + \left[ \text{Input of material} \right] \\
 &- \left[ \text{Output of material} \right] - \left[ \text{Material adsorbed on catalyst} \right] \quad (32)
 \end{aligned}$$

Backmix Phase -  $n^{\text{th}}$  Stage

$$\begin{aligned}
 \left[ \text{Accumulation of material} \right] &= \left[ \text{Input of material} \right] - \left[ \text{Output of material} \right] \\
 &+ \left[ \text{Material transferred from plug flow phase} \right] - \left[ \text{Material adsorbed on catalyst} \right] \quad (33)
 \end{aligned}$$

Plug Flow Phase -  $n^{\text{th}}$  Stage

$$(1 - \delta_p) V_p \frac{\partial C_{pn}(t, z)}{\partial z} = k [C_{bn}(t) - C_{pn}(t, z)] - v_p u_p \frac{\partial C_{pn}(t, z)}{\partial z} - \delta_p V_p E_p \frac{\partial Q_p}{\partial t} \quad (34)$$



Backmix Phase - n<sup>th</sup> Stage.

$$(1-\gamma_b)V_b \frac{dC_{bn}(t)}{dt} = \frac{V_b u_b}{Z} [C_{fb}(t) - C_{bn}(t)] + \frac{1}{Z} \int_0^Z k [C_{pn}(t, z) - C_{bn}(t)] dz - E_b \gamma_b V_b \frac{\partial Q_b(t)}{\partial t} \quad (35)$$

where

- $C_{bn}(t)$  - concentration of tracer in backmix phase in the n<sup>th</sup> stage
- $\gamma_p$  - volume fraction solids in plug flow phase
- $C_{pn}(t, z)$  - concentration of tracer in plug flow phase in n<sup>th</sup> stage
- $k$  - interchange coefficient to account for tracer interchange between phases
- $z$  - height in the stage
- $Q_p$  - weight of tracer adsorbed per unit volume of catalyst in plug flow phase
- $\gamma_b$  - volume fraction solids in backmix phase
- $Z$  - total height of stage
- $C_{fb}$  - concentration of tracer entering backmix region from previous stage

$Q_b$  - weight of tracer adsorbed per unit volume  
of catalyst in backmix phase

$E_p$  - catalyst contact efficiency in plug flow  
phase

$E_b$  - catalyst contact efficiency in backmix  
phase

The exit concentration of the bed will be given by

$$\begin{aligned}
 \left[ \text{Overall response} \right] &= \left[ \begin{array}{c} \text{Fraction of total} \\ \text{flow in} \\ \text{backmix flow} \end{array} \right] \times \left[ \begin{array}{c} \text{Backmix phase} \\ \text{response} \end{array} \right] \\
 &+ \left[ \begin{array}{c} \text{Fraction of total} \\ \text{flow in} \\ \text{plug flow} \end{array} \right] \times \left[ \begin{array}{c} \text{Plug flow} \\ \text{response} \end{array} \right] \\
 &+ \left[ \begin{array}{c} \text{Fraction of total} \\ \text{flow in} \\ \text{bypass} \end{array} \right] \times \left[ \begin{array}{c} \text{Bypass} \\ \text{response} \end{array} \right]
 \end{aligned} \quad (36)$$

$$C(s) = \frac{V_b u_b}{u} C_{bm}(s) + \frac{V_p u_p}{u} C_{pm}(s, z_m) + \frac{V_{by} u_{by}}{u} C_{by}(s) \quad (37)$$

where  $s$  is the Laplace transform operator and bypass response is the pure dead time element.

The following are defined:

- $B_p$  - fraction of total flow in plug flow phase  
 $B_y$  - fraction of total flow in the bypass region  
 $V_{by}$  - volume fraction of bed in bypass region  
 $u_{by}$  - velocity in bypass region  
 $Z_m$  - height of the last stage

Therefore from (37)

$$C(s) = (1 - B_p - B_y) C_{bm}(s) + B_p C_{pm}(s, Z_m) + B_y C_{by}(s) \quad (38)$$

Taking the Laplace transform of (33) where

$$C_{pn}(0, z) = C_{bn}(0) = Q_p(0) = 0 \quad (39)$$

and

$$Q_p(s) = Y_p(s) C_{pn}(s, z) \quad (40)$$

and solving (37) with the boundary conditions:

$$\begin{aligned}
 @ z=0 \quad C_{pn}(t, 0) &= C_{fp}(t) \\
 C_{pn}(s, 0) &= C_{fp}(s)
 \end{aligned}$$

the following equation is obtained:

$$\text{where } \alpha = \frac{(1-\delta_p)s}{u_p} + \frac{E_p \delta_p Y_p(s)}{u_p} + \frac{k}{v_p u_p}$$

$$C_{pn}(s, z) = C_{fp}(s) \exp(-\alpha z) + \frac{k}{v_p u_p \alpha} C_{bn}(s) [1 - \exp(-\alpha z)] \quad (41)$$

Substituting this result into (35) for the backmix phase after the Laplace transform has been found and solving, the result is shown in Table I, where

- $C_{fp}$  - concentration of tracer entering plug flow phase from previous stage
- $A$  -  $(1-\delta_p)s + \delta_p Y_p(s) E_p$
- $T_p$  -  $v_p / k$
- $H(s)$  -  $\exp - (L_p A + N)$
- $T_{vb}$  -  $v_b Z / u$
- $T_{vp}$  -  $v_p Z / u$
- $L_p$  -  $Z / u_p$
- $N$  -  $k Z / v_p u_p$
- $Y_b$  - complex adsorption admittance for backmix region
- $Y_p$  - complex adsorption admittance for plug flow region

TABLE I  
MODEL EQUATIONS

Laplace Transform of the Response of the Backmix Phase

$$C_{bn}(s) = \frac{(1 - \beta_p - \beta_\gamma) C_{fb}(s) + \frac{\beta_p C_{fp}(s)}{T_p a + 1} [1 - H(s)]}{(1 - \delta_b) T_{vb} s + 1 - \beta_\gamma + \frac{T_{vp} a}{T_p a + 1} - \frac{\beta_p (T_p a + 2) T_p a}{(T_p a + 1)^2} - \frac{\beta_p H(s)}{(T_p a + 1)^2} + E_b T_{vb} \delta_b Y_b(s)} \quad (42)$$

Laplace Transform of the Response of the Plug Flow Phase

$$C_{pn}(s, \beta) = C_{fp}(s) H(s) + \frac{1}{T_p a + 1} [1 - H(s)] C_{bn}(s) \quad (43)$$

From (41) the Laplace transform at the plug flow phase is shown in Table I. From (43), (42), and (38), the Laplace transform of the exit concentration of the bed is given by

$$C(s) = (1 - B_p - B_y) C_{bm}(s) + B_p C_{pm}(s, Z_T) + B_y C_{by}(s) \quad (44)$$

The adsorption terms  $Q_p$  and  $Q_b$  will be derived according to the method described by Rosen.<sup>21</sup> Assume adsorption occurs like a first order chemical reaction

$$\frac{\partial Q}{\partial t} = k_1 C - k_2 Q \quad (45)$$

Applying this equation to the theoretical model  $\partial Q / \partial t$  would be independent of its position in the bed. Equilibrium is considered to be unhampered by film coefficients or diffusion. Therefore,

$$\frac{dQ}{dt} = k_1 C - k_2 Q \quad (46)$$

Taking the Laplace transform

$$sQ(s) = k_1 C(s) - k_2 Q(s) \quad (47)$$

Rearranging

$$Q(s)(s+k_2) = k_1 C(s) \quad (48)$$

$$Q(s) = \frac{k_1 C(s)}{s+k_2} \quad (49)$$

Therefore,

$$\mathcal{L}\left[\frac{dQ}{dt}\right] = Q(s)s = \left[\frac{k_1 s}{s+k_2}\right] C(s) \quad (50)$$

The value

$$\frac{k_1 s}{s+k_2} = Y'(s) = \text{admittance caused by adsorption} \quad (51)$$

There were two types of flow patterns studied with the dense phase in plug flow:

1. High flow rates with bypassing gas where

$$\begin{aligned} u_p &= u_{mf} \\ \delta_p &= \delta_{mf} \end{aligned} \quad (52)$$

The bypassing gas is assumed to occur through the bubble so the velocity of bypassing gas is assumed to be at the velocity of the bubble. The volume fraction of the bed as bubbles is given by

$$V_v = \frac{Z_T - Z_{mf}}{Z_T} \quad (53)$$

Making a material balance

$$u_v V_v = u - u_d V_d \quad (54)$$

Since there are two regions assumed in the bed with the dense region at minimum fluidization conditions

$$u_v V_v = u - u_{mf} (1 - V_v) \quad (55)$$

Therefore

$$u_v = \frac{u - u_{mf}}{V_v} + u_{mf} \quad (56)$$



The transport lag of the bypass phase is then

$$L_v = \frac{Z_T}{u_v} \quad (57)$$

Utilizing conservation of the volume of catalyst and making a material balance.

$$S Z_T V_p \delta_p + S Z_T V_b \delta_b = S \delta_{mf} Z_{mf} \quad (58)$$

$$\delta_b = \frac{\delta_{mf}}{V_b} \left[ \frac{Z_{mf}}{Z_T} - V_p \right] \quad (59)$$

2. Low flow rates with bypassing gas and a dead zone in the dense phase.

If  $D_v$  is the dead volume fraction, the material balance for catalyst is

$$S Z_T D_v \delta_v + S Z_T V_p \delta_p + S Z_T V_b \delta_b = \delta_{mf} S Z_{mf} \quad (60)$$

$$\gamma_b = \gamma_{mf} \quad (61)$$

$$\gamma_v = \frac{\gamma_{mf}}{D_v} \left[ \frac{Z_{mf}}{Z_T} - V_p - V_b \right] \quad (62)$$

By proper combination of the above equations for the cases studied, the theoretical transfer function of the fluidized bed can be found. By substituting  $i\omega$  for  $s$  and programming the equations on the computer using complex number routines available in FORTRAN IV, the frequency response characteristics of the models were plotted and compared to the experimental data. The computer program was named MOD.

#### IV. EXPERIMENTAL APPARATUS

Figure 2 is a diagram of the apparatus used for the tests. The reaction chamber was a glass pipe six inches in diameter and three feet high. The top cover was made from one-half inch thick plexiglass. It had a tap for one leg of a water manometer and a slip joint for the outlet sampling tube. Exhaust air passed through a one-inch pipe threaded to the center of the cover and was vented outside the building.

Figures 3 and 4 illustrate the design of the air distributor and calming section. The distributor had nineteen one-eighth inch diameter orifices covered by one-inch diameter disks primarily to prevent the flow of catalyst into the calming section when air flow stopped. Under two caps were the sample inlets, one for the other leg of the manometer and the second for the inlet sample. By placing these sample points under the caps, the concentration measurements and the pressure drops could be made directly across the bed. This avoided the error caused by measuring both the pressure drop and dynamic response over the entire reactor and then correcting for the pressure drop and dynamics of the distributor and calming section.




FIGURE 2 EXPERIMENTAL APPARATUS






FIGURE 3 DISTRIBUTOR DETAILS



SECTION A-A

FIGURE 4 CALMING SECTION DETAILS

Bed packing was Alcoa F-1 activated alumina, 28-35 mesh. Fluidizing gas was air and tracer gas was either helium (non-adsorbing) or "Freon-12" (absorbing).

One-eighth inch outside diameter copper tubing was used for the sample lines. No filters were used on the ends of the tubes because these caused unnecessary sampling lags and mixing in the sampling lines. Catalyst particles were not carried into the sampling lines because the sample flow in the outlet sample line was below settling velocity of the particles. The inlet sample line was shielded by the caps to prevent flow of catalyst into the tubing.

Details of one sampling system are in Figure 5. Gow-Mac Model #10-777 thermal conductivity cells were used to detect the tracer gases, "Freon-12" and helium in the air stream. The detectors are a semi-diffusion type utilizing thermistor detector elements. The semi-diffusion type cell was found to give fast response with a high signal to noise ratio.

Originally, flow-through detectors were used which gave faster response but their high sensitivity to flow fluctuations made them impractical to use. Also with the low sampling rates necessary with this type of cell (10 cc/min.) the time lag of the system and undesirable dynamics made these cells unsuitable.




FIGURE 5  
FLOW DIAGRAM OF SAMPLING  
CIRCUITS



With the use of semi-diffusion type cells, the sampling rate could be considerably higher (100 cc/min.) and the signal was not sensitive to minor flow fluctuations. The response characteristics of both inlet and outlet sampling systems were studied and it was determined that corrections in the dynamics other than lag time would not have to be made to the overall response characteristics of the catalyst bed.

Samples were drawn through the cells using a small sampling pump. The cells were connected to Gow-Mac Model #9999-D power supply units. The power supplies provided the proper balancing and had provision for a recorder hookup. D.C. power was supplied by a 12-volt automobile battery to provide noise-free signals. The internal power supply of the Gow-Mac power supply had too much ripple to be used with the recorder at the high sensitivities used. See Figure 6 for an electrical schematic of the power supply.

The recorder was a two-channel Brush Clevite Model #240 pen recorder. Channel widths were 80 mm with rectilinear motion ink pens. The wide channel provided good resolution for reading the curves.




FIGURE 6 THERMISTOR CELL CIRCUIT

Air was supplied to the test apparatus by a compressor at 45 psig at a maximum flow of 10 SCFM. Pressure was regulated in two stages to 15 psig to minimize pressure fluctuations. A third air regulator was used to supply the reference air to the thermal conductivity cells at a pressure of 0-5 psig.

Six rotameters were used for measuring various gas flows. Four Brooks "Sho-Rate" rotameters (0-150 cc/min.) measured sample and reference flows through the thermal conductivity cells. One measured the main air flow to the bed. The sixth rotameter (0-1500 cc/min.) was used in a calibration piping circuit so calibration curves could be established for the detectors under actual operating conditions. The five smaller rotameters were calibrated using a wet test meter. Equipment was not available to calibrate the large rotameter so the factory calibration curves were used. The factory calibration curves for the other five rotameters were sufficiently accurate to justify confidence in the remaining curve.

The detectors were calibrated at 100 cc/min. sample and reference flows with 7.5 ma. bridge current. Main air flow was set at some convenient value. Helium or

"Freon-12" was then metered into the main air stream. The calibration curves for both detectors was similar and linear. These curves are shown in Figure 7.

Pulse introduction was accomplished using a four-way valve. An air bleed stream normally passed through two ports of the valve. With change of position, the air stream was diverted through a loop previously filled with tracer gas. The tracer was then forced into the main air stream. For different pulse strengths, different lengths of tubing were used in the loop.




FIGURE 7 CELL CALIBRATION CURVES


## V. EXPERIMENTAL PROCEDURE

Minimum fluidization velocity was found by observing bed pressure drop vs air rate. Figure 8 illustrates the results. Bed aspect ratio was 1.2. Tracer tests were performed at five air rates, 0.49, 0.91, 1.1, 1.28 and 1.65 times minimum fluidization velocity.

All tracer tests were duplicated to insure reproducibility in the results. Different pulse strengths were used at each test condition to check for linearity.

Before a series of testing, all flows were set and the sample detection apparatus was allowed to stabilize. When the base lines from the detectors showed no drift, the system was considered ready for testing.

The introduction of tracer was accomplished by first flushing the sample loop with tracer gas and then turning the four-way valve. The inlet and outlet tracer concentrations vs. time were recorded. Changing tracer sample size was just a matter of changing sample loop length. All tests at one flow rate could be performed without disturbing the fluidized bed or any of the control settings.

FIGURE 8  $\Delta P$  VS. AIR RATE

The date, run number, air flow rate, bed height and recorder sensitivity were noted on the recorder chart. Chart speed was 10 mm/sec.

A delay will exist because the tracer must travel through the bed and the sample lines. The delay in the sample lines is known to within a second. Since the chart paper was travelling at a constant speed, all that was needed to measure the lag time in the bed was to use a ruler to measure the distance, convert to time and subtract the sample lag time. This method worked well in the packed bed region.

When the bed was fluidized, the measured lag time in the bed was not accurate since the error of the sample lag time was of the same order of magnitude as the bed lag time. In this case, a lag time was calculated from the bubble velocity and the height of the bed.

In analyzing the pulse itself, it was necessary to obtain the height of the pulse at accurate increments of time. By scribing a clear plastic sheet with parallel lines every 2.5 mm, a template was



made. Since the chart speed was 10 mm./sec., the altitude of the pulse could be read at multiples of 0.25 seconds. By placing the template over the chart paper and reading the pulse height at the intersection of the curve and the scribed lines with a magnifying glass, the altitude could be read to within 0.3 mm. The accuracy of the time measurement was estimated to be within 0.01 seconds.

## VI. EXPERIMENTAL RESULTS

Frequency response tests were first made in the packed bed at two air flow rates. The tests conducted using helium demonstrated that in the region of frequencies studied, the packed bed behaved like a plug flow reactor. The amplitude ratio remained at the value of one, up to the limit of reliability of the pulse testing technique used. This upper limit of reliability depended on the width of the input pulse used. To decrease the width of the pulse, the injection point was placed as close as possible to the calming section. The volume of the calming section was the smallest that could be made and still provide good distribution of flows. In addition, the calming section was divided into six smaller volumes with baffles to eliminate gross circulation patterns which could be present. With these precautions, the input pulse could still be described by a sharp increase in concentration followed by an exponential decay. The decay was always slow enough so the width of the input pulse was reasonably long.

Figures 9, 10, 11 and 12 illustrate the input and response curves for the packed bed and fluidized bed with helium and "Freon-12" as tracer gases. Appendix VI presents the data read from the curves in the form

FIGURE 9  
 SAMPLE PACKED BED HELIUM TRACER CURVE




FIGURE 10 SAMPLE PACKED BED "FREON-12" TRACER CURVE.






FIGURE 11  
SAMPLE FLUIDIZED BED HELIUM TRACER CURVE



Time →  
1/3 actual size

FIGURE 12 SAMPLE FLUIDIZED BED "FREON-12" TRACER CURVE



of the computer input for DPLS. DPLS was the name given to the computer program which converted the input and output histories of the bed into the transfer function of the bed. The actual measured lag time between pulses is tabulated separately (Table XXXVIII) to complete the raw data section. The transfer function is presented in the form of magnitude ratios and phase angle vs. frequency in a Bode plot. These calculated data are presented in Appendix V as computer printouts. The correction for lag time was done by the computer program for the packed bed cases. Calculated dead times were used for the fluidized bed cases. The corrections to the phase angle are shown in Table III in Appendix IV.

The experimental lag times for the fluidized bed were determined to be unreliable so lag times were calculated using theoretical bubble velocities. The final results then became consistent.

The experimental transfer functions are shown in Figures 13, 14, 15, 16 and 17. At the frequencies of interest when adsorption was occurring, the packed bed was operating in a plug flow condition. This was determined from the helium test. The magnitude ratio remained at the value of 1.0 and the phase angle obeyed the equation  $\phi = -wL$ .




FIGURE 13 U=1.175 FT./SEC. 7-1/4 IN. PACKED BED







FIGURE 14  $U=0.219$  FT./SEC. 7-1/4 IN. PACKED BED

FIGURE 15  $U=0.264$  FT./SEC. 7-1/4 IN. FLUIDIZED BED




FIGURE 16  $U=309$  FT./SEC.  $7\text{-}3/8$  IN. FLUIDIZED BED




FIGURE 17  $U=0.399$  FT./SEC. 7-5/8 IN. FLUIDIZED BED

This is exactly the response expected for a plug flow mixing pattern. Looking at the curves, then, the adsorption studies in the packed bed region were in a plug flow region and the plug flow model applies.

After establishing that the packed bed was operating in a plug flow manner for the frequencies studied, the "Freon-12" tracer was introduced to determine the dynamics of adsorption. Adsorption was fairly strong. The packed bed was tested at two different flow rates. The results are presented in two Bode plots in Figures 13 and 14.

The frequency response model of the packed bed using adsorption which was described by a first order reversible reaction was fitted to the data. Agreement was good indicating the above assumption was suitable. The other mechanisms tried were adsorption with pore diffusion, adsorption with a film coefficient, and adsorption with film coefficient and pore diffusion. These models did not give as good an overall fit as the simple adsorption model. This does not mean that these models are not applicable but just that for the conditions used in the experiments, they did not play a dominant role.

The adsorption parameters were determined by using the computer program NLIN1, a nonlinear least squares program modified from NLIN,<sup>12</sup> a previously published program. The results for one case are shown in Appendix V. The program is listed in Appendix III. The values of  $k_1$  and  $k_2$  were found to be 46.5 and 4.25 respectively in consistent units. Similar results were found for the two flow rates used in the packed bed, indicating that there was little or no effect of flow on these parameters. These experimental values were satisfactory to use in the fluidized bed regions. In the plug flow model one necessary parameter needed was the void volume. Published data<sup>20</sup> for the Alcoa F-1 catalyst was used. The external void volume fraction used was 0.468. This value was used because facilities weren't available to measure external void volume. To check this value, however, the sum of the external and internal void volume fractions was determined using water. This experimental total void fraction was found to be 0.693. Since this value compared favorably with the published data (0.73), the external void fraction was deemed to be correct for the alumina used during these experiments.

The experimental results in the fluidized bed were consistent and the response was linear within

the limits of the concentration ranges studied. The test for linearity of the system was done by changing the amount of tracer injected. This did not change the shape or the width of the curves but increased the relative concentration of tracer. As mentioned in the Theory chapter, if this change did not affect the frequency response curves, the system behaved in a linear fashion. This was found to be the case. The frequency response curves with the "Freon-12" tracer occurred at nearly a decade of frequencies lower than the helium tracer curves.

The curves showed the expected "blip" in the magnitude ratios and phase angles which are characteristic of distributed parameter systems. The explanation for this type of response occurs when the flow of gas in the bed is through at least two types of mixing regions. Each region has its characteristic frequency response plot. At the exit of the bed when the flows through these regions combined, there is a counteraction because of the relative phase shift.

Remembering the consistency of frequency response testing via the pulse method and direct sinusoidal forcing, it is easier to picture what occurs with direct sinusoidal forcing. When two curves of the same

frequency are combined that are shifted by  $180^\circ$  or multiples of  $360^\circ$  plus  $180^\circ$ , the curves combine to give a minimum in the magnitude. Conversely, when the curves are shifted by multiples of  $360^\circ$ , reinforcement occurs giving a maximum for the magnitudes.

The limits of reliability of frequency response data have long been established by a previous investigator<sup>3</sup>. The normalized frequency content of the input pulse was used for a reliability criterion. Clements and Schnelle<sup>3</sup> reported the maximum frequency to which reliable frequency response data can be obtained. This is when the normalized frequency content of the input pulse falls below 0.2. With the helium tracer tests, this critical frequency was between 1.0 and 2.0 radians per second. With the "Freon-12" tracer, this critical frequency was around 0.5 radians per second.

With this criterion, the range and the upper limit of reliable data was determined by both the shape and the width of the input pulse. If a normalized frequency distribution curve is plotted with normalized frequency content as ordinate, and normalized frequency (frequency x pulse width) as abscissa, the shape of the curve depends



on the shape of the pulse: The shape of the curve determines the normalized frequency where the normalized frequency content is 0.2.

Since the shape of the curve could not be changed easily with the apparatus used, the maximum frequency for reliability was obtained by minimizing the pulse width.

## VII. DISCUSSION OF EXPERIMENTAL RESULTS

The comparisons of experimental and theoretical curves when adsorption occurs in the fluidized bed, are in Figures 15, 16 and 17 for the three flow rates studied. The parameters for the proposed model were determined for the cases where adsorption occurred. With helium for the tracer gas, the same model was applied. These results, however, were inconclusive because there was not enough data before the critical frequency for reliability of the curves. However, some general statements could be made for the helium tracer results. Applying a general empirical transfer function composed of a first-order response and a distance-velocity time delay, the frequency response curve for the magnitude ratio could be described by a first-order response and the phase angle curve by a steadily decreasing curve as frequency increased.

With this in mind, the following generalizations could be drawn from the helium tracer results:

1. As flow rate increased, the residence time of the bed decreased.
2. As flow rate increased, the dead time decreased.

The following generalizations could be drawn from the "Freon-12" tracer results:

1. As flow rate increased, the minimum of the node occurred at higher frequencies.
2. For all flow rates, the magnitude ratio curves were essentially the same shape except for location of the nodes.

Comparing the results with the helium and "Freon-12" tracers, the frequency response curves with the "Freon-12" tracers were located over a decade of frequencies lower than the response curves using helium tracer.

Each adjustable model parameter appeared to affect a distinct portion of the frequency response curves. This relationship proved helpful in determining the model parameters, although some interaction did exist.

The plug flow volume fraction,  $V_p$ , affected the shape of the curve by controlling the major shape of the curve. At high values of  $V_p$  the response was similar to the plug flow reactor, that is, there was a sharp decrease in magnitude ratio and phase angle as the frequency increased. At low values, the response was

similar to a completely mixed reactor since decreases in  $V_p$  caused a corresponding increase in the completely mixed volume fraction,  $V_b$ . The value of  $V_p$  also affected, within limits, the value of the minimum of the node in the magnitude ratio.

The volume of bed in bypass flow,  $V_{by}$ , affected the overall values of the magnitude ratio and phase angle. As  $V_{by}$  increased, the values of the magnitude ratio increased, especially the values around the node. As  $V_{by}$  increased, the overall values of the phase lag decreased. This was understandable since the velocity of the bypassing gas was high in relation to the velocities in the other flow regions.

The value of the interchange coefficient,  $k$ , affected the difference in height between the minimum and maximum of the node. As  $k$  increased, the difference decreased. In the limit as  $k$  increased, the overall response would take on the character of the region which had the highest volumetric flow rate.

The value of the efficiency of the plug flow region,  $E_p$ , determined the frequency where the minimum of the node was located. As  $E_p$  decreased, the minimum would be shifted to the higher frequencies.

The model with adsorption did fit the experimental results well to the limit of reliability of the data. The parameters of the model with adsorption are tabulated in Table II. The parameters  $V_b$ ,  $V_p$ ,  $V_{by}$ ,  $V_d$ ,  $k$ ,  $E_p$  and  $E_b$  were determined by trial and error. The use of the computer program NLINL using the fluidized bed model was tried unsuccessfully in an effort to obtain the values of the parameters. The program had a tendency to minimize the least squares of the deviation using unrealistic values of the parameters. The locations of the minima and maxima were felt to be more important than the closeness of fit in the determination of the applicability of the model.

The use of the model with one stage was adequate to describe the response of the fluidized bed. Since the bed was short, this result was not unreasonable.

The theoretical values of the transfer functions are shown in Appendix V. The theoretical model could only be used to evaluate the parameters for the fluidized bed with adsorption. The limit of reliability of the data for the fluidized bed without adsorption did not allow enough of the frequency response curve to be fitted with the model to any reasonable degree of accuracy. Further discussion will be concerned with the use of the model with adsorption.

TABLE II

## ONE STAGE MODEL PARAMETERS

Flow Rate SCFM	u ft./sec.	Height ft.	Lag Time sec.	V <sub>b</sub>	V <sub>p</sub>	V <sub>d</sub>	V <sub>by</sub>	k
1.36	0.1175	0.599	26.1	---	1.0	---	---	---
2.54	0.219	0.599	12.2	---	1.0	---	---	---
3.06	0.264	0.604	0.5	.348	0.319	0.281	0.052	0.22
3.58	0.309	0.620	0.275	.448	0.349	0.151	0.052	0.22
4.62	0.399	0.646	0.286	.580	0.37	0.	0.05	0.22

Flow Rate SCFM	δ <sub>b</sub>	φ <sub>p</sub>	E <sub>p</sub>	E <sub>b</sub>	k <sub>1</sub>	k <sub>2</sub>	u <sub>b</sub>
1.36	---	0.542	1.0	---	46.8	4.25	---
2.54	---	0.542	1.0	---	46.9	4.24	---
3.06	0.542	0.542	1.0	1.0	46.8	4.25	0.241
3.58	0.542	0.542	0.8	1.0	46.8	4.25	0.241
4.62	0.521	0.542	0.5	1.0	46.8	4.25	0.326

$$u_{mf} = 0.241 \text{ ft./sec.}$$

$$z_{mf} = 0.599 \text{ ft.}$$

$$\text{Cross Sectional Area} = 0.193 \text{ ft.}^2$$

Referring again to Table II, it was noted that as flow rate increased, the fraction of the bed in backmix flow increased. At low flow rates, the rapid mixing occurs around the vicinity of the bubble, but as the flow rate increases, the mixing of the particles increases. It should be noted that with adsorptive gases in the system, the motion of the particles carrying adsorbed gas determines to a large degree what is happening in the fluidized bed.

At the two lower flow rates, an additional region was necessary to bring the theoretical response in line with the experimental results, a dead region.

The dead region was defined as the volume within the bed where little or no gas flow was present. This could be explained by an uneven flow of gases through the distributor at low flow rates. Instead of flowing through the bed in a uniform fashion, a portion of the bed would be inactive, in effect, creating a smaller fluidized bed within the confines of the total catalyst volume. This region of relative inactivity was noted during the experiments. The bubbles were observed near the center of the bed at low air flow rates. At the highest flow rate studied, the entire bed was active.

The dead volume fraction,  $V_d$ , and the plug flow volume fraction,  $V_p$  are physically in the same volume of the fluidized bed and should be studied together. As flow rate increased, the sum of the dead volume fraction and the plug flow volume fraction decreased. The dead volume fraction decreased and finally disappeared at the highest flow rate. As flow rate increases, the fluidized bed becomes more active. It is expected that as flow rate further increases, the plug flow volume fraction will almost disappear because of the growing volume fraction of the completely mixed region. Inefficiencies in contacting will primarily be through bypassing gas via the bubbles. Thus, as flow rate continues to increase, the fluidized bed response would be similar to a completely mixed system with bypassing.

The dead volume,  $V_d$ , was introduced so the bypass volume could be increased at lower flow rates and maintain the proper material balance. At the low velocities, it was evident that a considerable amount of bypassing was occurring. Based on the usual equations for bubble volume in fluidized beds and with bypassing occurring through the bubble, the introduction of dead volume allowed the increase of theoretical bubble volume fraction.



Since the bed was short, bypassing of gas would occur. This bypassing of gas was assumed to occur in the bubble phase since the bubble velocities were higher than in the remainder of the bed. Also the void within the bubble would be the logical place for gas bypassing without contact with the alumina particles. The introduction of bypassing in the model gave results which were good at the highest flow rate studied.

The bypass volume remained essentially constant as flow rates increased. The bubbles formed with the orifice type distributor were expected to be large. This type of distributor was chosen because it was of the type used industrially. By redesigning the distributor to produce smaller bubbles, it is expected that the volume of the bed in which bypassing gas is flowing should decrease. At higher aspect ratios, less gas should also bypass the bed.

It was found that the interchange coefficient,  $k$ , remained constant as flow rate increased. Again particle motion with adsorption determines to a large degree the value of this parameter.

Studying the interchange expression in equation (34), describing interchange between the plug flow and backmix

region, can demonstrate this. In the expression

$$k [C_{bn}(t) - C_{pn}(t, z)] \quad (63)$$

$k$  can be factored as follows:

$$k = k' + KM \quad (64)$$

where  $k'$  is the mass transfer coefficient,  $K$  is an adsorption coefficient and  $M$  can describe the volume of particles moving between the plug flow and backmix regions. If the adsorption coefficient is high, then the interchange of material between the two regions is controlled by particle movement. It is conceivable that in the narrow range of flow rates used the particle motion between the plug flow and backmix regions would remain constant.

As flow rate increased, the efficiency of adsorption decreased in the plug flow region. The particle movement was determined to be a cause of this. The gas flowing through the plug flow region may be flowing in a plug flow fashion but the particles which adsorb the gas are

in motion. This motion is not intense, but it does decrease the efficiency of adsorption. In a packed bed, the gas desorbed from a particle travels and is adsorbed by the particle above. This occurs for the length of the packed bed. When the particles are moving, this adsorption to the particle above the desorbing particle may not occur because previously adsorbed material may already be on the particle. This phenomena must necessarily decrease the efficiency of adsorption in the plug flow region.

Because of particle interaction, it is doubted that the model proposed can be used by omitting the adsorptive terms to describe the response of a fluidized bed where no adsorption is taking place.

### VIII. CONCLUSIONS

The following conclusions can be drawn from this study:

1. The dynamics of adsorption in a fluidized bed can be described well using a unique approach to the use of a two-region model with bypassing. The completely mixed region describes the flow of gases and adsorbed gases around the vicinity of the bubble. The plug flow region describes the flow of gases and adsorbed gases through the remainder of the bed where particles are present. Bypassing occurs because of poor mixing in the bubble void volume.
2. The study in the transition region between packed beds and completely fluidized beds has shown that there is a logical transition in mixing patterns between these extremes. The adsorption dynamics can now be adequately described by a mathematical model. The parameters of the model also exhibit the proper behavior as flow rate increases.
3. This model, if necessary, can easily be adapted to more complicated situations where film coefficients and pore diffusion are dominant in the mechanism of adsorption.

4. The results demonstrate that there are three distinct flow patterns which exist in the partially fluidized bed. Also, at flow rates near minimum fluidization velocity, gas flow can create dead regions where there is no flow of gas or mixing of solids.
5. Adsorption data can be determined in the packed bed region and can be applied in the fluidized bed.
6. Particle movement was found to control the dynamics of adsorption in a fluidized bed.

### IX. RECOMMENDATIONS

This study has shown that a mathematical model can be used to describe the dynamics of adsorption in fluidized beds at low fluidization velocities. It was felt in reading of the results of other researchers that since the packed bed was described using a plug flow model and the completely fluidized bed using a backmix model, there must be a reasonable transition from one model to another.

This study has shown this to be so. However, more work has to be done in this area of fluidized beds:

1. Beds with higher aspect ratios should be studied to determine if a staged model adequately represents the dynamics of tall beds.
2. There appears to be a correlation between the parameters of the model and bubble size and velocity. Bubble size studies should be done in conjunction with dynamic studies. There are no data at present to perform any correlation. Studies have been made correlating bubble properties and the parameters of fluidized bed models but these models should be tested in the unsteady state if they are to be rigorously tested.

3. Studies should be made with gases and materials which give different adsorption rates to determine if particle motion controls the interchange of gases between the two major flow regions.
4. Different distributor designs should be used to vary the bubble size and flow distribution.
5. Efforts should also be made to decrease the width of the input pulses so reliable data at high frequencies can be found.
6. Tests with non-adsorbable tracer gases should be continued to get a better understanding of gas mixing patterns in fluidized beds. The flow model would probably be predominately plug flow through the dense phase with bypassing occurring through the bubble phase. In determining the overall response of the bed, the effect of the portion of the bed operation at minimum fluidization conditions should always be accounted for, no matter how small the flow may be. These regions always affect the dynamics of the bed and mathematical simplification should not be made until it is shown that the region of low flow does not contribute to the overall dynamics of

the bed. The frequency response of fluidized bed models would not necessarily show the presence of the nodes unless all flow regions are taken into account.

7. Additional equipment should be considered to ease the tedious reading of values from the input and output histories. The use of two analog to digital converters which record the concentration histories, should provide a tailor-made computer input for analysis. The use of a data smoothing routine would be necessary, but the amount of time saved could be used for a more complete analysis with a larger number of experiments.



REFERENCES

1. Barnstone, L. and P. Harriot, "Frequency Response of Gas Mixing in a Fluidized Bed Reactor", Systems and Process Control, C.E.P. Technical Manual prepared by the A.I.Ch.E., p. 17, 1967.
2. Bischoff, K. B., "Mixing and Contacting in Chemical Reactors", Industrial Engineering Chemistry, Vol. 58, No. 11, Nov. 1966, p. 18.
3. Clements, W. Jr., and K. Schnelle, "Pulse Testing for Dynamic Analysis", I. and E.C., Process Design and Development, Vol. 2, No. 2, p. 94, April, 1963.
4. Davidson, J. F. and D. Harrison, Fluidised Particles, Cambridge University Press, London, 1963.
5. Echigoya, E., M. Iwasaki, I. Furuoya, H. Sueyoshi, and T. Shirasaki, "Method of Estimating Chemical Reaction Conversion Rate in Fluidized Beds", Kagaku Kagaku, Vol. 29, p. 892, 1965.
6. Gilliland, E. R. and E. A. Mason, "Gas Mixing in Beds of Fluidized Solids", Industrial and Engineering Chemistry, Engineering and Process Development, Vol. 44, No. 1, p. 218, 1952.
7. Hays, J., W. Clements Jr., and T. Harris, "The Frequency Domain Evaluation of Mathematical Models for Dynamic Systems", A.I.Ch.E. Journal, Vol. 13, No. 2, p. 374, March, 1967.
8. Kato, K. and C. Wen, "Bubbling Assemblage Model for Fluidized Bed Catalytic Reactors", Paper presented at 64th National Meeting of A.I.Ch.E., 1969.
9. Kunii, D. and O. Levenspiel, "Bubbling Bed Model for Kinetic Processes in Fluidized Beds", I. and E. C., Process, Design and Development, Vol. 7, No. 4, p. 481, Oct., 1968.
10. Levenspiel, P., Chemical Reaction Engineering, Wiley and Sons Inc., New York, 1962.

11. Marquardt, D. W., "An Algorithm for Least Squares Estimation of Nonlinear Parameters", Journal of Society of Industrial and Applied Mathematics, Vol. 11, No. 2, June, 1963, p. 431.
12. Marquardt, D. W., "Least Squares Estimation of Nonlinear Parameters", Share Program Library S.D.A. 3094-01.
13. Massimilla, L. and H. Johnstone, "Reaction Kinetics in Fluidized Beds", Chem. Eng. Sci., Vol. 16, Nos. 1 and 2, p. 105, December, 1961.
14. Mathis, J., and C. Watson, "Effect of Fluidization on Catalytic Cumene Dealkylation", A.I.Ch.E. Journal, Vol. 2, No. 4, p. 518, Dec., 1956.
15. May, W., "Fluidized Bed Reactor Studies", Chem. Eng. Prog., Vol. 55, No. 12, p. 49, Dec., 1959.
16. Miyauchi, T., H. Kaji and K. Saito, "Fluid and Particle Dispersion in Fluid Bed Reactors", Journal of Chemical Engineering of Japan, Vol. 1, No. 1, p. 72, 1968.
17. Murray, J. D., "Mathematical Aspects of Bubble Motion in Fluidized Beds", Chem. Eng. Prog. Symp. Ser., No. 62, Vol. 62, p. 71.
18. Naor, P. and R. Shinnar, "Representation and Evaluation of Residence Time Distributions", I. and E. C., Fundamentals, Vol. 2, No. 4, Nov., 1963, p. 278.
19. Orcutt, J. C., J. F. Davidson and R. J. Pigford, Chem. Eng. Prog. Symp. Ser. No. 38, Vol. 58, p. 1, 1962.
20. Rimpel, A. E. Jr., D. T. Camp, J. A. KostECKI and L. A. Canjar, "Kinetics of Physical Adsorption of Propane from Helium on Fixed Beds of Activated Alumina", Chemical Engineering Progress Symposium Series, Vol. 3, No. 74, p. 53, 1967.

21. Rosen, J. B. and W. E. Winsche, "The Admittance Concept in the Kinetics of Chromatography, Journal of Chemical Physics, Vol. 18, No. 12, p. 1587, December, 1950.
22. Rowe, P. N., Chem. Eng. Prog , Vol. 60, No. 3, p. 75, 1964.
23. Yoshida, K. and D. Kunii, "Stimulus and Response of Gas Concentration in Bubbling Fluidized Beds", Journal of Chemical Engineering of Japan, Vol. 1. No. 1, p. 11, 1968.

NOMENCLATURE

$A_j$	*Change in $f(t)$ at the boundary between interval $T_{j-1}$ and $T_j$
$a_k$	* $k^{\text{th}}$ constant
$B_j$	*Change in $d f(t)/dt$ at the boundary between interval $T_{j-1}$ and $T_j$
$B_p$	*Fraction of total flow in the plug flow region
$B_y$	*Fraction of total flow in the bypass region
$c$	*Concentration of adsorbable gas
$C_{bn}$	*Concentration of tracer in the plug flow region in the $n^{\text{th}}$ stage
$C_{fb}$	*Concentration of tracer entering backmix region
$C_{fp}$	*Concentration of tracer entering the plug flow region from the previous stage
$C_j$	*Change in $d^2 f(t)/dt^2$ at the boundary between interval $T_{j-1}$ and $T_j$
$C_{pn}$	*Concentration of tracer in the plug flow region in the $n^{\text{th}}$ stage
$C(s)$	*Laplace transform of the exit concentration
$D_j$	*Change in $d^3 f(t)/dt^3$ at the boundary between interval $T_{j-1}$ and $T_j$
$D_v$	*Volume fraction of bed as dead volume
$\frac{d^k}{dt^k}$	* $k^{\text{th}}$ derivative with respect to time
$e$	*Base of the natural logarithm
$E_b$	*Catalyst efficiency in the backmix region

$E_{mf}$	*Porosity at minimum fluidization velocity
$E_p$	*Catalyst efficiency in the plug flow region
$F(i\omega)$	*Fourier transform of $f(t)$
$F(s)$	*Laplace transform of $f(t)$
$f(t)$	*A function of time expressed as a deviation from an initial condition
$G_d$	*Dead time element
$H(s)$	* $\exp -(L_p s + N)$
$i$	* $\sqrt{-1}$
$I(\omega)$	*Imaginary part of $F(i\omega)$
$j$	*Index
$k$	*Interphase transfer coefficient
$k'$	*Mass transfer coefficient
$k_1$	*Adsorption rate constant
$k_2$	*Desorption rate constant
$L$	*Delay time, dead time, seconds
$L_p$	* $Z/u_p$
$L_v$	*Bypass time, seconds
$m$	*Total number of stages
$M$	*Volume of particles interchanging per unit time
$M.R.$	*Magnitude ratio
$N$	* $kZ/V_p u_p$
$n$	*Last value of index $j$
$Q$	*Moles tracer adsorbed per volume of catalyst
$Q_b$	*Moles tracer adsorbed per volume of catalyst

	in the backmix region
$Q_p$	*Moles tracer adsorbed per volume of catalyst in the plug flow region
$R(w)$	*Real part of $F(iw)$
$s$	*Laplace operator
$\lambda$	* $(1-\gamma_p)s + E_p\gamma_p Y_p(s)$
$S$	*Cross sectional area
$t$	*Time, seconds
$t'$	*Time, seconds
T.F.	*Transfer function
$T_j$	*Time at the $j^{\text{th}}$ interval
$T_p$	* $V_p/k$
$T_{vb}$	* $V_b Z/u$
$T_{vp}$	* $V_p Z/u$
$T_x$	*Duration time of input pulse, seconds
$T_y$	*Duration time of output pulse, seconds
$u$	*Overall superficial velocity into the bed
$u_b$	*Superficial velocity through the backmix region
$u_{by}$	*Velocity through the bypass region
$u_d$	*Superficial velocity through the dense phase
$u_{mf}$	*Superficial gas velocity at minimum fluidization
$u_p$	*Superficial gas velocity through the plug flow region
$u_v$	*Velocity of the void volume as bubbles
$u(t-T_j)$	*Unit step function occurring at $t=T_j$

$V_b$	*Volume fraction of bed in backmix flow
$V_{by}$	*Volume fraction of bed bypassed
$V_d$	*Volume fraction of bed as dense phase
$V_p$	*Volume fraction of bed in plug flow
$V_v$	*Void volume fraction in the bed as bubbles
$w$	*Frequency, radians/second
$X(s)$	*Laplace transform of $x(t)$
$x(t)$	*Input variable as a function of time expressed as a deviation from an initial value
$Y_b$	*Complex adsorption admittance for the backmix region
$Y_p$	*Complex adsorption admittance for the plug flow region
$Y'(s)$	*Complex adsorption admittance
$y_p(t)$	* $y(t)$ predicted
$y(t)$	*Output variable as a function of time expressed as a deviation from an initial value
$Y(s)$	*Laplace transform of $y(t)$
$z$	*Height in the stage
$Z_m$	*Height of the last stage
$Z_{mf}$	*Height of the bed at minimum fluidization velocity
$Z_t$	*Total height of the bed
$z(t)$	*Output variable as a function of time expressed as a deviation from an initial value

$\delta_b$	*Volume fraction solids in the backmix region
$\delta_d$	*Volume fraction solids in the dense phase
$\delta_l$	*Volume fraction solids in the lean phase
$\delta_{mf}$	*Volume fraction solids at $u_{mf}$
$\delta_p$	*Volume fraction solids in the plug flow region
$\delta_v$	*Volume fraction solids in the dead zone
$\epsilon$	*Porosity
$\epsilon_{mf}$	*Porosity at $u_{mf}$
$\phi$	*Phase Angle



APPENDIX I  
ROTAMETER CALIBRATION CURVES




FIGURE 18 MAIN AIR FLOW CALIBRATION




FIGURE 19  
REFERENCE AND SAMPLE FLOWS




FIGURE 20 BLEED FLOW CALIBRATION

APPENDIX II  
MATHEMATICAL DEVELOPMENT

MATHEMATICAL DEVELOPMENT OF MODELn<sup>th</sup> StagePlug Flow Phase Material Balance

$$(1-\alpha_p) V_p \frac{\partial c_{pn}(t, z)}{\partial t} = k [c_{bn}(t) - c_{pn}(t, z)] - v_p \mu_p \frac{\partial c_{pn}(t, z)}{\partial z} - E_p \alpha_p V_p \frac{dq_p(t)}{dt} \quad (1)$$

Backmix Phase

$$(1-\alpha_b) V_b \frac{d c_{bn}(t)}{dt} = \frac{v_b \mu_b}{Z} [c_{fb}(t) - c_{bn}(t)] + \frac{1}{Z} \int_0^Z k [c_{pn}(t, z) - c_{bn}(t)] dz - E_b \alpha_b V_b \frac{dq_b(t)}{dt} \quad (2)$$

The exit concentration of the bed is given by

$$C(s) = \frac{v_b \mu_b}{\mu} C_{bm}(s) + \frac{v_p \mu_p}{\mu} C_{pm}(s, Z_m) + \frac{v_{by} \mu_{by}}{\mu} C_{by}(s) \quad (3)$$

where  $s$  is the Laplace transform variable and  $Z_m$  is the height of the last stage.

Define  $B_p$  as the fraction of total flow in the plug flow phase and  $B_y$  as the fraction of total flow bypassing the stage

$$\therefore C(s) = (1 - B_p - B_y) C_{bn}(s) + B_p C_{pm}(s, z_m) + B_y C_{by}(s) \quad (4)$$

Taking the Laplace transform of (1) where

$$C_{pn}(0, z) = C_{bn}(0) = q_p(0) = 0 \quad (5)$$

and

$$s q_p(s) = Y_p(s) C_{pn}(s, z) \quad (6)$$

where (6) will be derived later

$$(1 - \delta_p) V_p s C_{pn}(s, z) = k [C_{bn}(s) - C_{pn}(s, z)] - V_p \mu_p \frac{d C_{pn}(s, z)}{d z} - E_p \delta_p V_p Y_p(s) C_{pn}(s, z) \quad (7)$$

Rearranging (7)

$$\frac{d C_{pn}(s, z)}{d z} + \alpha C_{pn}(s, z) = \frac{k}{V_p \mu_p} C_{bn}(s) \quad (8)$$

where

$$\alpha = \frac{(1-\gamma_p) s}{u_p} + \frac{E_p \gamma_p Y_p(s)}{u_p} + \frac{k}{v_p \mu_p} \quad (9)$$

Solving using operator notation for (8)

$$(D + \alpha) C_{pn}(s, z) = \frac{k}{v_p \mu_p} C_{bn}(s) \quad (10)$$

$$C_{pn}(s, z) = C_1 \exp(-\alpha z) + \frac{k}{v_p \mu_p \alpha} C_{bn}(s) \quad (11)$$

Boundary Conditions

$$\begin{aligned} @ z=0 \quad C_{pn}(t, 0) &= C_{fp}(t) \\ C_{pn}(s, 0) &= C_{fp}(s) \end{aligned}$$

$$\therefore C_1 = C_{fp}(s) - \frac{k}{v_p \mu_p \alpha} C_{bn}(s) \quad (12)$$

$$\therefore C_{pn}(s, z) = \left[ C_{fp}(s) - \frac{k}{v_p \mu_p \alpha} C_{bn}(s) \right] \exp(-\alpha z) + \frac{k}{v_p \mu_p \alpha} C_{bn}(s) \quad (13)$$



Rearranging (13)

$$C_{pn}(s, z) = C_{fp}(s) \exp(-\alpha z) + \frac{k}{v_p \mu_p \alpha} C_{bn}(s) [1 - \exp(-\alpha z)] \quad (14)$$

Now evaluate

$$\int_0^Z k [C_p(s, z) - C_b(s)] dz \quad \text{from (2) using (14)}$$

$$k \int_0^Z \left\{ C_{fp}(s) \exp(-\alpha z) + \frac{k}{v_p \mu_p \alpha} C_{bn}(s) [1 - \exp(-\alpha z)] - C_{bn}(s) \right\} dz \quad (15)$$

$$= k C_{fp}(s) \int_0^Z \exp(-\alpha z) dz + \frac{k^2}{v_p \mu_p \alpha} C_{bn}(s) \int_0^Z dz - \frac{k^2}{v_p \mu_p \alpha} C_{bn}(s) \int_0^Z \exp(-\alpha z) dz - k C_{bn}(s) \int_0^Z dz \quad (16)$$

$$= k C_{fp}(s) \frac{\exp(-\alpha z)}{-\alpha} \Big|_0^Z + \frac{k^2}{v_p \mu_p \alpha} C_{bn}(s) z \Big|_0^Z + \frac{k^2 C_{bn}(s)}{v_p \mu_p \alpha} \frac{\exp(-\alpha z)}{\alpha} \Big|_0^Z - k C_{bn}(s) z \Big|_0^Z \quad (17)$$

$$= k C_{fp}(s) \frac{\exp(-\alpha z)}{-\alpha} + \frac{k C_{fp}(s)}{\alpha} + \frac{k^2 C_{bn}(s)}{v_p \mu_p \alpha} z + \frac{k^2 C_{bn}(s)}{v_p \mu_p \alpha^2} \exp(-\alpha z) - \frac{k^2 C_{bn}(s)}{v_p \mu_p \alpha^2} - k C_{bn}(s) z \quad (18)$$

Rearranging (18)

$$k \int_0^Z [C_{pn}(s, \beta) - C_{bn}(s)] d\beta = \frac{k C_{fp}(s)}{\alpha} [1 - \exp(-\alpha Z)] + \frac{k^2 C_{bn}(s)}{v_p \mu_p \alpha} \left[ Z - \frac{1}{\alpha} (1 - \exp(-\alpha Z)) \right] - k C_{bn}(s) Z \quad (19)$$

Taking the Laplace transform of (2) and applying conditions

$$C_{bn}(0) = q_b(0) = 0 \quad ; \quad s q_b(s) = Y_b(s) C_{bn}(s) \quad (20)$$

$$V_b (1 - \delta_b) s C_{bn}(s) = \frac{V_b \mu_b}{Z} [C_{fb}(s) - C_{bn}(s)] + \frac{1}{Z} \int_0^Z k [C_{pn}(s, \beta) - C_{bn}(s)] d\beta - \delta_b V_b E_b Y_b(s) C_{bn}(s) \quad (21)$$

Substituting (19) into (21)

$$V_b (1 - \delta_b) s C_{bn}(s) = \frac{V_b \mu_b}{Z} C_{fb}(s) - \frac{V_b \mu_b}{Z} C_{bn}(s) + \frac{k C_{fp}(s)}{Z \alpha} [1 - \exp(-\alpha Z)] + \frac{k^2 C_{bn}(s)}{v_p \mu_p \alpha Z} \left[ Z - \frac{1}{\alpha} (1 - \exp(-\alpha Z)) \right] - \frac{k C_{bn}(s) Z}{Z} - \delta_b V_b E_b Y_b(s) C_{bn}(s) \quad (22)$$

Rearranging (22)

$$\left\{ (1-\delta_b) V_b s + \frac{V_b \mu_b}{Z} - \frac{k^2}{v_p \mu_p \alpha} \left[ 1 - \frac{1}{2\alpha} (1 - \exp(-\alpha Z)) \right] + k + \delta_b V_b E_b Y_b(s) \right\} C_{bn}(s) \\ = \frac{V_b \mu_b}{Z} C_{fb}(s) + \frac{k C_{fp}(s)}{Z \alpha} \left[ 1 - \exp(-\alpha Z) \right] \quad (23)$$

Solving (23) for  $C_{bn}(s)$

$$C_{bn}(s) = \frac{\frac{V_b \mu_b}{Z} C_{fb}(s) + \frac{k C_{fp}(s)}{Z \alpha} \left[ 1 - \exp(-\alpha Z) \right]}{V_b (1-\delta_b) s + \frac{V_b \mu_b}{Z} - \frac{k^2}{v_p \mu_p \alpha} \left[ 1 - \frac{1}{2\alpha} (1 - \exp(-\alpha Z)) \right] + k + \delta_b E_b V_b Y_b(s)} \quad (24)$$

Rearranging the expression for  $\alpha$  from (9)

$$\alpha = \frac{(1-\delta_p) s}{\mu_p} + \frac{\delta_p E_p Y_p(s)}{\mu_p} + \frac{k}{v_p \mu_p} = \frac{1}{\mu_p} \left[ (1-\delta_p) s + \delta_p E_p Y_p(s) + \frac{k}{v_p} \right] \quad (25)$$

Define  $T_p = v_p/k$  and rearranging (25)

$$\alpha = \frac{1}{\mu_p T_p} \left[ T_p (1-\delta_p) s + T_p E_p \delta_p Y_p(s) + 1 \right] = \frac{1}{\mu_p T_p} (T_p \mathcal{A} + 1) \quad (26)$$

where

$$\mathcal{A} = (1-\delta_p) s + E_p \delta_p Y_p(s) \quad (27)$$

Substituting (26) into (24) and rearranging

$$C_{bn}(s) = \frac{\frac{v_b \mu_b}{Z} c_{fb}(s) + \frac{\mu_p v_p}{Z(T_p \alpha + 1)} \left[ 1 - \exp\left(-Z \frac{T_p \alpha + 1}{\mu_p T_p}\right) \right]}{v_b(1-\delta_b)s + \frac{v_b \mu_b}{Z} \frac{k}{(T_p \alpha + 1)} \left[ 1 - \frac{\mu_p v_p}{kZ(T_p \alpha + 1)} \left( 1 - \exp\left(-Z \frac{T_p \alpha + 1}{\mu_p T_p}\right) \right) \right] + k + \delta_b v_b E_b Y_b(s)} \quad (28)$$

Define:

$$(1 - \beta_p - \beta_y) = \frac{v_b \mu_b}{\mu}, \quad \beta_p = \frac{v_p \mu_p}{\mu}, \quad T_p = \frac{v_p}{k} = \frac{L_p}{N},$$

$$T_{vp} = \frac{v_p^2}{\mu}, \quad T_{vb} = \frac{v_b Z}{\mu}, \quad L_p = \frac{Z}{\mu_p}, \quad N = \frac{kZ}{v_p \mu_p}$$

Multiply (28) by  $\frac{Z/\mu}{Z/\mu}$  and rearrange

$$C_{bn}(s) = \frac{(1 - \beta_p - \beta_y) c_{fb}(s) + \frac{\beta_p c_{fp}(s)}{(T_p \alpha + 1)} \left[ 1 - \exp\left(\frac{T_p \alpha + 1}{\mu_p T_p} Z\right) \right]}{\frac{v_b Z}{\mu} \left[ (1 - \delta_b)s + (1 - \beta_p - \beta_y) - \left(\frac{v_p \mu_p}{\mu}\right) \left(\frac{kZ}{v_p \mu_p}\right) \frac{1}{T_p \alpha + 1} \left[ 1 - \frac{1}{N(T_p \alpha + 1)} \left( 1 - \exp\left(\frac{T_p \alpha + 1}{\mu_p T_p} Z\right) \right) \right] \right]} + \left(\frac{v_p \mu_p}{\mu}\right) \left(\frac{kZ}{v_p \mu_p}\right) + T_{vb} E_b \delta_b Y_b(s) \quad (29)$$

Taking the following expression from (29)

$$\begin{aligned} \exp\left(-\frac{T_p \alpha + 1}{\mu_p T_p} Z\right) &= \exp\left(-\frac{T_p \alpha Z}{\mu_p T_p} - \frac{Z}{\mu_p T_p}\right) = \exp\left(-L_p \alpha - \frac{kZ}{\mu_p v_p}\right) \\ &= \exp\left(-L_p \alpha + N\right) = H(s) \end{aligned} \quad (30)$$

After substitution of (30) into (29) and further rearranging of (29)

$$C_{bn}(s) = \frac{(1 - B_p - B_y) C_{fb}(s) + \frac{B_p C_{fp}(s)}{T_p \alpha + 1} [1 - H(s)]}{(1 - \delta_b) T_{vb} s + 1 - B_y + \frac{T_{vp} \alpha}{T_p \alpha + 1} - \frac{B_p (T_p \alpha + 2) T_p \alpha}{(T_p \alpha + 1)^2} - \frac{B_p H(s)}{(T_p \alpha + 1)^2} + T_{vb} E_b \delta_b Y_b(s)} \quad (31)$$

From (14)

$$C_{pn}(s, Z) = C_{fp}(s) \exp(-\alpha Z) + \frac{k}{v_p \mu_p \alpha} [1 - \exp(-\alpha Z)] C_{bn}(s) \quad (32)$$

$$C_{pn}(s, Z) = C_{fp}(s) H(s) + \frac{1}{T_p \alpha + 1} [1 - H(s)] C_{bn}(s) \quad (33)$$

ADSORPTION EQUATIONS

The rate of adsorption of material is given by

$$\frac{\partial q}{\partial t} = G(c, q) \quad (34)$$

The relation  $G(c, q) = 0$  defines a unique equilibrium value  $q_e(c)$ , of  $q$  for all values of  $c$  in some given range. The adsorption process is defined as reversible and after sufficient time, the relationship  $G(c, q) = 0$  is always satisfied regardless of the initial condition of the adsorbent.

A linear adsorption is assumed. That is,  $G(c, q)$  is linear in  $c$  and  $q$ . If the adsorption isotherm is nonlinear, the disturbance will be adjusted so a linear approximation can be used to describe the isotherm.

Adsorption is assumed to proceed similar to the response of opposing first order reactions

$$G(c, q) = k_1 c - k_2 q \quad (35)$$

When used in the model previously described, (34) holds independently of  $g$ , the height in the column. Hence (34) can be written as an ordinary differential equation. Combining (34) and (35)

$$\frac{dq}{dt} = k_1 c - k_2 q \quad (36)$$

Taking the Laplace transform of (36) with  $q(0) = 0$

$$s q(s) = k_1 c(s) - k_2 q(s) \quad (37)$$

Rearranging (37)

$$q(s) = \frac{k_1 c(s)}{k_2 + s} \quad (38)$$

Since the Laplace transform of  $\frac{dq}{dt} = s q(s)$ , (38) becomes

$$s q(s) = \left( \frac{k_1 s}{k_2 + s} \right) c(s) \quad (39)$$

The quantity in parentheses is defined as the admittance

$$Y'(s) = \frac{k_1 s}{k_2 + s} = \frac{k_1}{1 + (k_2/s)} \quad (40)$$

and

$$s q(s) = Y'(s) C(s) \quad (41)$$

Taking equation (40) and letting  $s = iw$ , the admittance in the frequency domain is given by

$$Y'(iw) = \frac{k_1}{1 - i(k_2/w)} \quad (42)$$

Separating into real and imaginary parts

$$Y'(iw) = Y_1(w) + iY_2(w) = \frac{k_1}{1 + (k_2/w)^2} + i \frac{k_1(k_2/w)}{1 + (k_2/w)^2} \quad (43)$$

where  $Y_1(w)$  and  $Y_2(w)$  are known, the values of  $k_1$  and  $k_2$  can be found by

$$k_2 = (Y_2(w)/Y_1(w)) w, \quad k_1 = [1 + (Y_2(w)/Y_1(w))^2] Y_1(w) \quad (44)$$

If equation (35) is the correct mechanism,  $k_2$  and  $k_1$  should be independent of  $w$ . Solving equations (44) should yield the same values for  $k_1$  and  $k_2$  for all frequencies



PLUG FLOW MODEL

Equation (33) can be applied to a plug flow reactor by taking the limiting case where  $k = 0$  and the reactor is described by a single stage.

$$C_p(s, \beta) = C_{fp}(s) H(s) = C_{fp}(s) \exp(-L_p \Delta) \quad (45)$$

Thus the transfer function of a plug flow reactor with adsorption is given by

$$\frac{C_p(s, \beta)}{C_{fp}(s)} = \exp(-L_p \Delta) = \exp\left\{-L_p[(1-\delta_p)s + \epsilon_p \delta_p Y_p(s)]\right\} \quad (46)$$

Converting to the frequency domain by letting  $s = iw$

$$\frac{C_p(w, \beta)}{C_{fp}(w)} = \exp\left\{-L_p \epsilon_p \delta_p Y_1(w) - i L_p [(1-\delta_p)w + \delta_p \epsilon_p Y_2(w)]\right\} \quad (47)$$

where

$$Y_p(w) = Y_1(w) + i Y_2(w) \quad (48)$$

The resulting vector can be described by a magnitude and an angle defined previously as the amplitude ratio and the phase angle  $\phi$ .

$$M.R. = A.R. = \exp - [L_p \cdot E_p \delta_p Y_1(\omega)] \quad (49)$$

$$\phi = -L_p [(1-\delta_p) \omega + \delta_p E_p Y_2(\omega)] \quad (50)$$

By determining the transfer function experimentally, the values  $Y_1(\omega)$  and  $Y_2(\omega)$  can be found for each  $\omega$ .

Therefore

$$Y_1(\omega) = \frac{-\ln A.R.}{L_p \delta_p E_p} \quad (51)$$

$$Y_2(\omega) = \frac{\phi + L_p (1-\delta_p) \omega}{-L_p \delta_p E_p} \quad (52)$$

The values of the rate constants for adsorption can then be found using equation (44).

APPENDIX III  
COMPUTER PROGRAMS

```

1      PROGRAM DPLS
2      PROGRAM PULSE. ARRAY DESCRIPTION.F-TIME DEPENDENT VARIABLE,F(1)
3      ARE BASE LINES.CA,CB,CC --- A,B,C DESCRIBED IN AICHE J VOL 13 ND 2DPLS
4      P 374. SA,SB,SC --- COEFFICIENTS OF GENERAL EQUATION F(T)= SA*T**2DPLS
5      +SB*T+SC IN THE INTERVAL. T -- TIME. NC ---ND OF CARDS IN A SINGLEDPLS
6      PULSE DATA SET. NF -- NO OF FIELDS USED ON LAST CARD OF DATA SET. DPLS
7      DT--- INCREMENTS OF TIME. NT1 --- NO OF TIME INTERVALS FOR DPLS
8      FIRST DELTA T INCREMENTS. RD -- AREA UNDER CURVE. IF INDEX=1 STEP-DPLS
9      WISE APPROXIMATIONS ARE USED INDEX=2 STRAIGHT INDEX=3 PARA- DPLS
10     BDLIC DPLS
11     IF L=1 INPUT PULSE L=2 OUTPUT PULSE. DPLS
12
13     DIMENSION F(101,2),CA(100,2),CB(100,2),CC(100,2),SA(101,2),SB(101,2),
14     SC(101,2),T(101,2),NF(2),NF(2),DT(2,2),NT1(2),RD(2),INDEX(2),
15     2N(2),K(2),FIM(2),COMM(20),MTIM(2),JTIM(2),CAL(2)
16     DOUBLE PRECISION AR,CA,CR,CC,F,FIM,DM,DMF,DMS,PHI,R,RD,SA,SB,SC,
17     ISW,SWN,T,TEM,TFM1,TEM2,TFI,TFR,TIM,TRUN,Z,CAL,DT,DTIM
18     DATA IVER/'QUIT'/,IDIR/'1'/,MTIM(2)/'1'/,MTIM(1)/'1'/,NMLC/'1'/,
19     1LFC/'1'/,IZER/'0'/
20     READ 81,INDEX(1),NC(1),NF(1),DT(1,1),NT1(1),DT(2,1),JTIM(1),IDEL, DPLS
21     1INDEX(2),NC(2),NF(2),DT(1,2),NT1(2),DT(2,2),JTIM(2),NML,LTIM,DTIM, DPLS
22     1DMS,DMF,CAL(1),CAL(2),ID DPLS
23     81     FORMAT(2(I1,2I2,F4.1,I2,F4.1,2A1),A1,F4.1,4F6.2,13X,A4) DPLS
24     TIM=0. DPLS

```

25 C	CHECK FOR TERMINATION CARD	DPLS	25
26	IF(IVER-ID)55,54,55	DPLS	26
27 55	READ 85,(COMM(I),I=1,20)	DPLS	27
28 85	FORMAT(20A4)	DPLS	28
29 C	IF NO INPUT PULSE DATA, PROGRAM ASSUMES DIRAC DELTA	DPLS	29
30 C	CHECK FOR DIRAC DELTA INPUT	DPLS	30
31	IF(IDIR-IDEL)1,2,1	DPLS	31
32 2	L=2	DPLS	32
33	IKAC=2	DPLS	33
34	RO(1)=1.	DPLS	34
35	GO TO 100	DPLS	35
36 1	L=1	DPLS	36
37	IKAC=1	DPLS	37
38 100	NP=(12*(NC(L)-1))+NF(L)	DPLS	38
39	N(L)=NP	DPLS	39
40	READ 82,(F(I,L),I=1,NP)	DPLS	40
41 82	FORMAT(12F6.1)	DPLS	41
42 C	CALCULATE VALUES FROM CALIBRATING CURVE	DPLS	42
43	DO 336 I=1,NP	DPLS	43
44 336	F(I,L)=F(I,L)*CAL(L)	DPLS	44
45 C	CHECK IF TIMES ARE TO BE READ	DPLS	45
46	IF(MTIM(L)-JTIM(L))102,101,102	DPLS	46
47 C	IF NO DELTA T SPECIFIED PROGRAM READS NEXT DATA SET AS TIMES	DPLS	47
48 101	READ 82,(T(I,L),I=1,NP)	DPLS	48
49	GO TO 103	DPLS	49
50 C	TIME CALCULATED FROM DELTA T VALUES	DPLS	50

```

FORTRAN IV011 SOURCE PROGRAM . DPLS          PROGRAM          01/29/69    PAGE 0002
51 102      T(1,L)=0.                                DPLS          51
52          T(2,L)=0.                                DPLS          52
53          IF(DT(2,L))105,105,106                    DPLS          53
54 C        2 DELTA T SPECIFIED                       DPLS          54
55 106      ITEM=NT1(L)                                DPLS          55
56          DO 104 I=1,ITEM                            DPLS          56
57          Z=I                                         DPLS          57
58 104      T(I+2,L)=Z*DT(1,L)                         DPLS          58
59          IDUM=NP-ITEM-2                             DPLS          59
60          ITEM=ITEM+2                                DPLS          60
61          DO 107 I=1,IDUM                             DPLS          61
62          Z=I                                         DPLS          62
63          IT=ITEM+I                                  DPLS          63
64 107      T(IT,L)=T(ITEM,L)+Z*DT(2,L)                DPLS          64
65          GO TO 103                                  DPLS          65
66 C        ONE DELTA T SPECIFIED                     DPLS          66
67 105      ITEM=NP-2                                  DPLS          67
68          DO 108 I=1,ITEM                            DPLS          68
69          Z=I                                         DPLS          69
70 108      T(I+2,L)=Z*DT(1,L)                         DPLS          70
71 103      NINT=NP-1                                  DPLS          71
72 C        INITIALIZE                                 DPLS          72
73          DO 3 I=1,NP                                 DPLS          73
74          CA(1,L)=0.                                  DPLS          74

```

```

75      CB(I,L)=0.          DPLS 75
76      CC(I,L)=0.          DPLS 76
77      SA(I,L)=0.          DPLS 77
78      SB(I,L)=0.          DPLS 78
79 3    SC(I,L)=0.          DPLS 79
80      SWN=1.              DPLS 80
81 C    CURRENT DATA TO ZERO BASELINE  DPLS 81
82      DO 110 I=2,NP       DPLS 82
83 110  F(I,L)=F(I,L)-F(1,L) DPLS 83
84      F(1,L)=0.          DPLS 84
85      IND=INDEX(L)       DPLS 85
86 C    GU TO SPECIFIED APPROXIMATION  DPLS 86
87      GU TO (21,22,23),IND DPLS 87
88 C    STEPWISE APPROXIMATION          DPLS 88
89 21  IF(L-2)211,25,25    DPLS 89
90 211 IF(F(3,L)-F(1,L))25,26,25        DPLS 90
91 26  F(2,L)=2.*F(2,L)    DPLS 91
92 25  DO 28 I=2,NINT      DPLS 92
93 28  SC(I,L)=(F(I,L)+F(I+1,L))/2.      DPLS 93
94      DO 136 I=2,NP      DPLS 94
95 136  CA(I,L)=SC(I,L)-SC(I-1,L)        DPLS 95
96      GU TO 24           DPLS 96
97 C    STRAIGHT LINE APPROXIMATION     DPLS 97
98 22  DO 31 I=2,NINT      DPLS 98
99      SB(I,L)=(F(I,L)-F(I+1,L))/(T(I,L)-T(I+1,L))
100 31  SC(I,L)=(F(I,L)+F(I+1,L)-SB(I,L)*(T(I,L)+T(I+1,L)))/2. DPLS 100

```

```

FORTRAN IV011 SOURCE PROGRAM DPLS PROGRAM 01/29/69 PAGE 0003
101 CA(2,L)=F(2,L)-F(1,L) DPLS 101
102 CA(NP,L)=F(NP,L)-F(1,L) DPLS 102
103 DO 236 I=2,NP DPLS 103
104 236 CB(I,L)=SB(I,L)-SB(I-1,L) DPLS 104
105 GO TO 24 DPLS 105
106 C PARABOLIC APPROXIMATION DPLS 106
107 23 IDUM=NINT-1 DPLS 107
108 DO 34 I=2,IDUM DPLS 108
109 TEM=T(I,L)*(T(I+2,L)**2 -T(I+1,L)**2 )+T(I+1,L)*(T(I,L)**2 -T(I+2,L)**2 ) DPLS 109
110 1L)**2 )+T(I+2,L)*(T(I+1,L)**2 -T(I,L)**2 ) DPLS 110
111 SA(I,L)=((T(I+1,L)-T(I+2,L))*(F(I,L)-F(I+1,L))-T(I,L)-T(I+1,L))* DPLS 111
112 1(F(I+1,L)-F(I+2,L))/TEM DPLS 112
113 SB(1,L)=((F(I,L)-F(I+1,L))*(T(I+1,L)**2-T(I+2,L)**2)-(F(I+1,L) DPLS 113
114 1-F(I+2,L))*(T(I,L)**2-T(I+1,L)**2))/(-TEM) DPLS 114
115 34 SC(1,L)=(F(1,L)+F(I+1,L)+F(I+2,L))-SA(I,L)*(T(I,L)**2 +T(I+1,L)**2 DPLS 115
116 1+T(I+2,L)**2 )-SB(I,L)*(T(I,L)+T(I+1,L)+T(I+2,L))/3. DPLS 116
117 C LAST TWO INTERVALS, USE SAME APPROXIMATING CURVE DPLS 117
118 SA(NINT,L)=SA(IDUM,L) DPLS 118
119 SB(NINT,L)=SB(IDUM,L) DPLS 119
120 SC(NINT,L)=SC(IDUM,L) DPLS 120
121 CA(2,L)=F(2,L)-F(1,L) DPLS 121
122 CA(NP,L)=F(NP,L)-F(1,L) DPLS 122
123 DO 36 I=2,NP DPLS 123
124 CB(I,L)=(2.*SA(I,L)*T(I,L)+SB(I,L))-(2.*SA(I-1,L)*T(I,L)+SB(I-1,L)) DPLS 124

```



```

125      1)
126 36      CC(I,L)=2.*(SA(I,L)-SA(I-1,L))
127 C      CALCULATE AREAS UNDER CURVES USING SPECIFIED APPROXIMATION
128 24      RU(L)=0.
129      DU 35 I=2,NINT
130 35      RU(L)=RU(L)+(SA(I,L)*(T(I+1,L)**3 -T(I,L)**3 )/3.)+(SB(I,L)*(T(I+1,L)
131      L,L)**2 -T(I,L)**2 )/2.)+(SC(I,L)*(T(I+1,L)-T(I,L)))
132 C      SAVE VALUE IF CURVE IS TRUNCATED BY THE PROGRAM
133      TRUN=F(NP,L)
134      F(NP,L)=F(1,L)
135 C      IF INPUT PULSE CALCULATIONS DONE DO OUTPUT PULSE
136      IF(2-L)38,38,39
137 39      L=2
138      GO TO 100
139 C      INITIALIZE
140 38      DM=0.
141      PHI=0.
142      FIM(1)=0.
143      FIM(2)=0.
144      R(1)=1.
145      ILN=7
146      -AR=KD(2)/RD(1)
147      PRINT 83, ID
148 83      FORMAT(1H1//50X,'RUN ID ',A4/)
149      PRINT 87,(COMM(I),I=1,20)
150 87      FORMAT(11X,'COMMENTS ',20A4/)
DPLS 125
DPLS 126
DPLS 127
DPLS 128
DPLS 129
DPLS 130
DPLS 131
DPLS 132
DPLS 133
DPLS 134
DPLS 135
DPLS 136
DPLS 137
DPLS 138
DPLS 139
DPLS 140
DPLS 141
DPLS 142
DPLS 143
DPLS 144
DPLS 145
DPLS 146
DPLS 147
DPLS 148
DPLS 149
DPLS 150

```

```

151 IF(NMLC-NML)68,67,68 DPLS 151
152 PRINT 89,TIM DPLS 152
153 89 FORMAT(20X,'DEAD TIME= ',G10.3,2X,'PULSES NORMALIZED'//) DPLS 153
154 GO TO 69 DPLS 154
155 68 PRINT 90,TIM DPLS 155
156 90 FORMAT(20X,'DEAD TIME= ',G10.3,2X,'PULSES NOT NORMALIZED'//) DPLS 156
157 69 PRINT 86 DPLS 157
158 86 FORMAT(10X,'OMEGA',4X,'AMPLITUDE',2X,'PHASE ANGLE',4X,'OUTPUT PULSDPLS 158
159 1E',11X,'INPUT PULSE',6X,'INPUT FREQ CONTENT',9X,'RAD/SEC',5X,'RATIO DPLS 159
160 20',6X,'DEGREES',5X,'REAL',4X,'IMAGINARY',5X,'REAL',4X,'IMAGINARY' DPLS 160
161 3,2X,'NORMALIZED',3X,'ACTUAL'//) DPLS 161
162 PRINT 84,OM,AR,PHI,RO(2),FIM(2),RO(1),FIM(1),SWN,RO(1) DPLS 162
163 OM=UMS DPLS 163
164 44 DO 40 L=IRAC,2 DPLS 164
165 FIM(L)=0. DPLS 165
166 R(L)=0. DPLS 166
167 NP=N(L) DPLS 167
168 DO 40 I=2,NP DPLS 168
169 TEM=OM*T(I,L) DPLS 169
170 ITER=(OM*T(I,L))/(2.*3.14159) DPLS 170
171 TEM1=ITEM DPLS 171
172 TEM=TEM-(TEM1*2.*3.14159) DPLS 172
173 TEM1=(-CA(I,L)/OM)+(CC(I,L)/(OM**3)) DPLS 173
174 TEM2=-CB(I,L)/(OM*OM) DPLS 174

```

```

175      R(L)=R(L)+TEM1*DSIN(TEM)+TEM2*DCOS(TEM)          DPLS 175
176 40    FIM(L)=FIM(L)+TEM1*DCOS(TEM)-TEM2*DSIN(TEM)      DPLS 176
177      TEM=R(1)*R(1)+FIM(1)*FIM(1)                      DPLS 177
178      TFR=(R(2)*R(1)+FIM(2)*FIM(1))/TEM                DPLS 178
179      TFI=(R(1)*FIM(2)-R(2)*FIM(1))/TEM                DPLS 179
180      AR=DSQRT(TFR*TFR+TFI*TFI)                         DPLS 180
181      TEM=TFI/TFR                                        DPLS 181
182      CALL DVCHK(J)                                     DPLS 182
183      IF(J-2)51,50,50                                    DPLS 183
184 51    PHI=DATAN2(TFR,TFI)*(180./3.14159)+90.           DPLS 184
185      GO TO 52                                           DPLS 185
186 50    PHI=DATAN2(TFI,TFR)*180./3.14159                DPLS 186
187 52    SW=DSQRT(R(1)*R(1)+FIM(1)*FIM(1))                DPLS 187
188      SWN=SW/RD(1)                                       DPLS 188
189      IF(NMLC-NML)64,63,64                               DPLS 189
190 C     NORMALIZE BUTH PULSES                            DPLS 190
191 63    AR=AR*(RD(1)/RD(2))                              DPLS 191
192      DU 62 NORM=1,2                                     DPLS 192
193      R(NORM)=R(NORM)/RO(NORM)                          DPLS 193
194 62    FIM(NORM)=FIM(NORM)/RO(NORM)                    DPLS 194
195 64    PRINT 84,DM,AR,PHI,R(2),FIM(2),R(1),FIM(1),SWN,SW DPLS 195
196 84    FORMAT(8X,9(G10.3,1X ))                         DPLS 196
197      ILN=ILN+1                                          DPLS 197
198      IF(ILN-34)60,60,61                               DPLS 198
199 61    ILN=7                                             DPLS 199
200      PRINT 83,ID                                       DPLS 200

```

FORTRAN	IV011	SOURCE	PROGRAM	DPLS	PROGRAM	01/29/69	PAGE	0005
201		PRINT 88						DPLS 201
202	88	FURMAT(54X,'CONTD.')						DPLS 202
203		IF(NMLC-NML)71,70,71						DPLS 203
204	70	PRINT 89,TIM						DPLS 204
205		GO TO 72						DPLS 205
206	71	PRINT 90,TIM						DPLS 206
207	72	PRINT 86						DPLS 207
208	60	ITEM=DLBG10(OM)-0.99						DPLS 208
209		IF(OM-10.)300,300,301						DPLS 209
210	301	ITEM=ITEM+1						DPLS 210
211	300	OM=OM+10.**ITEM						DPLS 211
212		IF(OMF-OM)43,44,44						DPLS 212
213	C	IF DEAD TIME DO CALCS W/O DEAD TIME, THEN WITH DEAD TIME						DPLS 213
214	43	IF(LTIC-LTIM)53,65,53						DPLS 214
215	65	L=2						DPLS 215
216		NP=N(L)						DPLS 216
217		F(NP,L)=TRUN						DPLS 217
218		DO 66 I=2,NP						DPLS 218
219	66	T(I,L)=T(I,L)+DTIM						DPLS 219
220		LTIM=1ZER						DPLS 220
221		TIM=DTIM						DPLS 221
222		GO TO 103						DPLS 222
223	54	CUNTINUE						DPLS 223
224		STOP						DPLS 224
225		END						DPLS 225

INPUT FORMAT FOR DPLSCONTROL CARD

- | <u>COL.</u> | <u>INPUT PULSE</u>   |
|-------------|--|
| 1           | (1) Type of approximation to be used.<br>1-step, 2-straight line segments, 3-parabolic   |
| 2-3         | (2) No. of cards for input pulse, $f(t)$ .   |
| 4-5         | (3) No. of data points on last card.   |
| 6-9         | (4) $\Delta t_1$ increments for first part of pulse, if applicable.  |
| 10-11       | (5) No. of $\Delta t_1$ increments. If no $\Delta t_2$ increments, leave blank, program will compute <sup>2</sup> proper number of increments. |
| 12-15       | (6) $\Delta t_2$ increments for second part of pulse, if applicable. If not, leave blank.  |
| 16          | (7) Read individual times instead of using $\Delta t$ increments. 0 for no, 1 for yes.   |
| 17          | (8) Is dirac delta used for input? 0 for no, 1 for yes. If yes, entries 4-6 inclusive can be left blank.                                       |

OUTPUT PULSE

- |       |   |
|-------|---|
| 18    | (9) Same as (1).                                      |
| 19-20 | (10) No. of cards for output pulse.                   |
| 21-22 | (11) No. of data points on last card.                 |
| 23-26 | (12) Same as (4).                                     |
| 27-28 | (13) Same as (5).                                     |
| 29-32 | (14) Same as (6).                                     |
| 33    | (15) Same as (7).                                     |
| 34    | (16) Normalize pulses? 0 if no, 1 if yes.             |
| 35    | (17) Is dead time used separately for pulse? 0 if no, |

COL.      OUTPUT PULSE

1 if yes. If yes, results are calculated with dead time and w/o dead time.

- 36-39 (18) Dead time, if applicable.
- 40-45 (19) Initial value of frequency for analysis must not be 0.
- 46-51 (20) Value of frequency at finish of job must not be 0.
- 52-57 (21) Slope of input calibration curve.
- 58-63 (22) Slope of output calibration curve.
- 77-80 (23) Run ID. - printed on output sheets.

COMMENT CARD

For descriptive comments on output sheet. A card must be included. Only one is to be used.

INPUT PULSE  $f(t)$ 

First entry is baseline. 2nd entry is  $f(t)$  @  $t = 0$ . If dirac input pulse is used, omit card. Twelve (12) entries per card. Six column fields.

INPUT PULSE ( $t$ )

If applicable, entries are in one-to-one correspondence with pulse cards. If not applicable, omit cards. Twelve (12) entries per card. Six column fields.

OUTPUT PULSE  $f(t)$ 

Same as for input pulse.

OUTPUT PULSE ( $t$ )

Same as for input pulse.

Succeeding data sets use same format as above. They are placed one after another.

TERMINATION CARD

Last card in the last data set causes normal exit of program. "QUIT" punched in columns 77-80.

GT  
R  
F  
C  
O  
M  
M  
GT  
R  
F  
C  
O  
M

```

NLIN1      12:57      04/16/70

100C PROGRAM NLIN1--NONLINEAR LEAST SQUARES
110C BY D. W. MARQUARDT
120C REPROGRAMMED IN FORTRAN IV FOR GE MARK II TIME-SHARING
130C MAX NO OF PARAMETERS IS K.      MAX NO OF IND. VARS. IS M
140C MAX NO OF OBSERVATIONS IS N
150C DIMENSION PRNT(5),CONS(5),IWS(6)
160C DIMENSION X(N,M),B(K),Y(N),A(2K,K),P(K)
170C DIMENSION BS(K),DB(K),BA(K),G(K),IB(K-1),SA(K)
180C CALL SUBZ
190C      CODING FOR CASE INITIALIZING
200C CALL FCODE
210C      F IS Y HAT(I)
220C      NPRNT IS THE NO OF OTHER WORDS TO BE PRINTED
230C      THE WORDS TO BE PRINTED ARE IN PRNT(1).....PRNT(5)
240C CALL PCODE
250C      CODING TO MAKE DF/DB GOES HERE
260C      MAKE K OF THEM. CALL THEM P(J),J=1,K
270C      THEY ARE MADE FROM X(I,L) AND B(J)
280      DIMENSION PRNT(5),CONS(5),IWS(6)
290      DIMENSION X(25,1),B(12),Y(25),A(24,12),P(12)
300      DIMENSION BS(12),DB(12),BA(12),G(12),IB(11),SA(12)
310 COMMON X,B,PRNT,A,P
320 COMMON Y
330 COMMON Y
340      DATA IBCH/" ",I0CH/"0"/,IPCH/"P"/,IYCH/"Y"/,IXCH/"X"/,NPRNT/0
350C READ FIRST CARD OF NEXT CASE

```

```

360 10 ITCT=0
370 IBOUT=0
380 PRINT 900
390 INPUT,N,K,IP,M,IFP,NCONS
400 NTILDA=N+NCONS
410 XNT=NTILDA
420C END OF LAST PROBLEM
430 IF(N.LE.0) GO TO 660
440 PRINT 901
450 INPUT,(IWS(I),I=1,6)
460 IF (IFP.LE.0)GO TO 22
470 PRINT 929
480 INPUT,YMN,SPRD
490 22 IF(IP.LE.0) GOTO 30
500 PRINT 930,IP
510 INPUT,(IB(I),I=1,IP)
520 DO 26 I=1,IP
530 IF (IB(I).GT.0)GO TO 26
540 PRINT 926
550 IBOUT=1
560 26 CONTINUE
570 30 PRINT 931
580 INPUT,FF,T,E,TAU,XL,GAMCR,DEL,ZETA
590C DUB IN INPUT CONSTANTS IF NOT SUPPLIED
600C (XL IS CHECKED IN FIRST ITERATION)
610 IF(FF.GT.0.) GOTO 34
620 FF=4.
630 34 IF(E.GT.0.) GOTO 37
640 E=.00005
650 37 IF(TAU.GT.0.) GOTO 39

```

G  
 P  
 R  
 I  
 T  
 C  
 O  
 M  
 M  
 G  
 P  
 R  
 I  
 T  
 C  
 O  
 M  
 M  
 G  
 P  
 R  
 I  
 T  
 C  
 O  
 M  
 M



```

660 TAU=.001
670 39 IF(T.GT.0.) GO TO 50
680 T=2.
690 50 IF(GAMCR.GT. 0.) GO TO 52
700 GAMCR = 45.
710 52 IF (DEL.GT. 0.) GO TO 55
720 DEL=.00001
730 55 IF (ZETA.GT. 0.) GO TO 53
740 ZETA=.1E-30
750 53 XKDB = 1.
760 PRINT 932,K
770C READ IN INITIAL B GUESSES
780 INPUT,(B(I),I=1,K)
790 PRINT 942,M
800 DO 56 I=1,N
810 56 INPUT,Y(I),(X(I,L),L=1,M)
820 CALL SUBZ(NPRINT,N)
830 IF(IBOUT.NE.0) GO TO 10
840 IBKA=1
850C START THE CALCULATION OF THE PTP MATRIX
860 PRINT 907,N,K,IP,M,IFP,GAMCR,DEL,FF,T,E,TAU,XL,ZETA
870 GO TO 61
880 60 IWS(3)=IWS(3)-1
890 IF(IWS(3).GT.0) GO TO 61
900 IWS(3)=0
910 61 DO 62 I=1,K
920 G(I) =0.
930 DO 62 J=1,K
940 62 A(I,J)=0.
950 PRINT 908,ITCT,(B(J),J=1,K)

```

**G** **PT** **COMM**  
**G** **PT** **COMM**  
**G** **PT** **COMM**

```

960 IF(IWS(3).EQ.0) GO TO 73
970 IF (IFP.LE.0)GO TO 68
980 WS = YMN+SPRD
990 PRINT 906,YMN,WS
1000 GO TO 73
1010 68 PRINT 910
1020 73 I=1
1030 PHI=0.
1040 PHIN=0.
1050 ICONS=1
1060C GET P S AND F
1070 72 IF(IWS(2).EQ.1) GO TO 602
1080C THIS IS THE ANALYTICAL P S ROUTINE
1090 CALL FCODE(F,I,RES)
1100 CALL PCODE(F,I)
1110 IF (IP.LE.0)GO TO 80
1120 DO 77 I=1,IP
1130 KWS=IB(I)
1140 77 P(KWS)=0.
1150 GO TO 80
1160C END OF ANALYTICAL P S ROUTINE
1170C THIS IS THE ESTIMATED P S ROUTINE
1180 602 CALL FCODE(F,I,RES)
1190 RWS=RES
1200 FSAVE=F
1210 J=1
1220 608 IF (IP.LE.0)GO TO 618
1230 DO 612 I=1,IP
1240 IF ((J-IB(I)).EQ.0)GO TO 621
1250 612 CONTINUE

```

**GET**   **RT**   **COMM**  
**GET**   **RT**   **COMM**  
**GET**   **RT**   **COMM**

```

1260 618 DBW=B(J)*DEL
1270 TWS=B(J)
1280 B(J)=B(J)+DBW
1290 CALL FCODE(F,I,RES)
1300 B(J)=TWS
1310 P(J)=- (RES-RWS)/DBW
1320 GO TO 622
1330 P(J)=0.
1340 J=J+1
1350 IF ((J-K).LE.0)GO TO 608
1360 RES=RWS
1370 F=FSAVE
1380C END OF ESTIMATED P S ROUTINE
1390C NOW, USE THE P S TO MAKE PARTIALS MATRIX
1400 80 D0 82 JJ=1,K
1410 G(JJ)=G(JJ)+RES*P(JJ)
1420 D0 82 II=JJ,K
1430 A(II,JJ)=A(II,JJ)+P(II)*P(JJ)
1440 82 A(JJ,II)=A(II,JJ)
1450C PLOTTING ROUTINE
1460 IF (IFP.LE.0)GO TO 318.
1470 IF(IWS(3).EQ.0.0R.1.GT.N) GO TO 314
1480C PLOTTING Y(I),F
1490 YI=CABS(Y(I))
1500 YI=ALOG(YI)/2.303
1510 FI=ALOG(F)/2.303
1520 IO=(YI-YMN)*50./SPRD
1530 IPP=(FI-YMN)*50./SPRD
1540 IF (IO.EQ.IPP)GO TO 808
1550 IF (IO.GT. IPP)GO TO 812

```

**G** **R** **F** **C** **O** **M** **M**  
**G** **R** **F** **C** **O** **M** **M**  
**G** **R** **F** **C** **O** **M** **M**

1560C Y(I) OUT FIRST  
 1570 IP1=I0CH  
 1580 IP2=IPCH  
 1590 I1=I0  
 1600 I2=IPP  
 1610 GO TO 816  
 1620C ONLY ONE CHARACTER  
 1630 808 IP1=IYCH  
 1640 IP2=IBCH  
 1650 I1=I0  
 1660 I2=IPP  
 1670 GO TO 816  
 1680C F OUT FIRST  
 1690 812 IP1=IPCH  
 1700 IP2=I0CH  
 1710 I1=IPP  
 1720 I2=I0  
 1730C ZERO PLOTS IN THE LEFT HAND COLUMN, S0  
 1740C I1 IS ITS OWN BLANK COUNTER  
 1750C OVERFLOWS PLOT X IN COLUMN 51  
 1760C UNDERFLOWS ALSO PLOT X IN COLUMN ZERO  
 1770 816 IF(I2.LE.51) GO TO 819  
 1780 I2=51  
 1790 IP2=IXCH  
 1800 IF(I1.LT.51) GO TO 819  
 1810 I1=51  
 1820 IP1=IXCH  
 1830 IP2=IBCH  
 1840 GO TO 825  
 1850 819 IF (I1.GE.0)GO TO 825

G M COMM  
 G M COMM  
 G M COMM  
 G M COMM  
 G M COMM

FT RECOMM  
FT RECOMM  
FT RECOMM

```

1860 I1=0
1870 IP1=IXCH
1880 IF (I2.GT.0)G0 T0 825
1890 I2=1
1900 IP2=IBCH
1910 825 I1M1=I1
1920 I1M2=I2-I1-1
1930 IF (I1M1.GT.0)G0 T0 832
1940 IF (I1M2.GT.0)G0 T0 828
1950 PRINT 928,IP1,IP2
1960 G0 T0 314
1970 828 PRINT 928,IP1,(IBCH,I1=1,I1M2),IP2
1980 G0 T0 314
1990 832 IF (I1M2.GT.0)G0 T0 840
2000 PRINT 928,(IBCH,I1=1,I1M1),IP1,IP2
2010 G0 T0 314
2020 840 PRINT 928,(IBCH,I1=1,I1M1),IP1,(IBCH,I1=1,I1M2),IP2
2030 G0 T0 314
2040C END OF PLOTTING ROUTINE
2050 318 WS=RES
2060 IF(IWS(3).EQ.0.OR.I.GT.N) G0 T0 314
2070 IF (NPRNT.GT.0)G0 T0 312
2080 YI=CABS(Y(I))
2090 PRINT 925,YI,F,WS
2100 G0 T0 314
2110 312 YI=CABS(Y(I))
2120 PRINT 925,YI,F,WS,(PRNT(JJ),JJ=1,NPRNT)
2130 314 WS=RES
2140 PHI=PHI+WS*WS
2150 IF (I.GT.N) G0 T0 313

```

```

2160 PHIN=PHIN+WS*WS
2170 GO TO 315
2180 CONS(ICONS)=RES
2190 ICONS=ICONS+1
2200 I=I+1
2210 IF (I.LE.NTILDA) GO TO 72
2220 IF (IP.LE.0)GO TO 88
2230 DO 87 JJ=1,IP
2240 KWS=IB(JJ)
2250 DO 86 II=1,K
2260 A(KWS,II)=0.
2270 86 A(II,KWS)=0.
2280 87 A(KWS,KWS)=1.
2290 88 GO TO (90,704,703),IBKA
2300C SAVE SQUARE ROOTS OF DIAGONAL ELEMENTS
2310 90 DO 92 I=1,K
2320 92 SA(I)=SQRT (A(I,I))
2330 DO 106 I=1,K
2340 DO 100 J=1,K
2350 WS = SA(I)*SA(J)
2360 IF(WS.GT.0.) GOTO 98
2370 A(I,J) =0.
2380 GO TO 100
2390 98 A(I,J)=A(I,J)/WS
2400 100 CONTINUE
2410 IF(SA(I).GT.0.) GOTO 104
2420 G(I)=0.
2430 GO TO 106
2440 104 G(I)=G(I)/SA(I)
2450 106 CONTINUE

```

**GET R F C O M M**  
**GET R F C O M M**  
**GET R F C O M M**

```

2460      D0 110 I=1,K
2470      110 A(I,I)=1.
2480      PHIZ=PHI
2490C WE NOW HAVE PHI ZERO
2500      D0 1133 II=1,K
2510      III=II+K
2520      D0 1133 JJ=1,K
2530      1133 A(III,JJ)=A(II,JJ)
2540      IF (ITCT.NE.0) G0 T0 163
2550C FIRST ITERATION
2560      IF(XL.GT.0.) G0T0 154
2570      XL=0.01
2580      154 D0 161 J=1,K
2590      161 BS(J)=B(J)
2600C BS(J) CORRESPONDS TO PHIZ
2610      163 IBK1=1
2620      WS=N-K+IP
2630      ITCT=ITCT+1
2640      SE=SQRT(PHIN/WS)
2650      IF(IWS(3).GT.0) G0 T0 165
2660      IF(IWS(2).EQ.0) G0 T0 168
2670      PRINT 911,PHIZ,SE,XLL,GAMMA,XL
2680      G0 T0 200
2690      168 PRINT 912,PHIZ,SE,XLL,GAMMA,XL
2700      G0 T0 200
2710      165 IF (NCONS.EQ.0) G0 T0 166
2720      PRINT 938,(JJ,CONS(JJ),JJ=1,NCONS)
2730      166 PRINT 939
2740      D0 114 I=1,K
2750      PRINT 937,I,(A(I,J),J=1,K)

```

**END**  
**END**  
**END**  
**END**  
**END**  
**END**

```

2760 114 CONTINUE
2770 IF(IWS(2).EQ.0) GO TO 1661
2780 PRINT 903,PHIZ,SE,XL
2790 GO TO 200
2800 1661 PRINT 909,PHIZ,SE,XL
2810 GO TO 200
2820 164 PHIL=PHI
2830C WE NOW HAVE PHI LAMBDA
2840 D0 170 J=1,K
2850 IF (ABS(DB(J)/(ABS(B(J)) + TAU)).GE.E) GOTO 172
2860 170 CONTINUE
2870 PRINT 923
2880 GO TO 700
2890 172 IF(IWS(4).EQ.0) GO TO 173
2900 IF(IWS(4).EQ.1) GO TO 171
2910 IWS(4)=IWS(4)-1
2920 GO TO 173
2930 171 PRINT 924
2940 GO TO 700
2950 173 XKDB = 1.
2960 IF (PHIL.GT.PHIZ)GO TO 190
2970 XLS=XL
2980 D0 176 J=1,K
2990 BA(J)=B(J)
3000 176 B(J)=BS(J)
3010 IF (XL.GT..00000001)GO TO 175
3020 D0 1176 J=1,K
3030 B(J)=BA(J)
3040 1176 BS(J)=B(J)
3050 GO TO 60

```

RTN COMM

RTN COMM

RTN COMM

RTN COMM

RTN



3060 175 XL=XL/10.  
 3070 IBK1=2  
 3080 GO TO 200  
 3090 177 PHL4=PHI  
 3100C WE NOW HAVE PHI(LAMBDA/10)  
 3110 IF(PHL4.GT.PHIZ) GO TO 184  
 3120 DO 183 J=1,K  
 3130 BS(J)=B(J)  
 3140 GO TO 60  
 3150 184 XL=XLS  
 3160 DO 186 J=1,K  
 3170 BS(J)=BA(J)  
 3180 186 B(J)=BA(J)  
 3190 GO TO 60  
 3200 190 IBK1=4  
 3210 XLS=XL  
 3220 XL=XL/10.  
 3230 DO 185 J=1,K  
 3240 BS(J)=BS(J)  
 3250 GO TO 200  
 3260 187 IF (PHI.LE.PHIZ)GO TO 196  
 3270 XL=XLS  
 3280 IBK1=3  
 3290 192 XL=XL\*10.  
 3300 195 DO 193 J=1,K  
 3310 193 B(J)=BS(J)  
 3320 GO TO 200  
 3330 194 PHIT4=PHI  
 3340C WE NOW HAVE PHI(10\*LAMBDA)  
 3350 IF (PHIT4.GT.PHIZ)GO TO 198

```

G
3360 196 D0 197 J=1,K
3370 197 BS(J)=B(J)
3380 GO TO 60
3390 198 IF (GAMMA*GE*GAMCR)GO TO 192
3400 XKDB = XKDB/2.
3410 D0 1199 J=1,K
3420 IF (ABS(DB(J))/(ABS(B(J))+TAU)).GE.E)GO TO 195
3430 1199 CONTINUE
3440 D0 1200 J=1,K
3450 1200 B(J)=BS(J)
3460 PRINT 934
3470 GO TO 700
3480C SET UP FOR MATRIX INVERSION
3490 200 D0 1103 II=1,K
3500 III=II+K
3510 D0 1103 JJ=1,K
3520 1103 A(II,JJ)=A(III,JJ)
3530 D0 202 I=1,K
3540 202 A(I,I)=A(I,I)+XL
3550C GET INVERSE OF A AND SOLVE FOR DB(J) S
3560 IBKM=1
3570C THIS IS THE MATRIX INVERSION ROUTINE
3580C K IS THE SIZE OF THE MATRIX
3590 404 CALL GJR(K,ZETA,MSING)
3600 GO TO (415,10),MSING
3610 415 GO TO (416,710), IBKM
3620C END OF MATRIX INVERSION, SOLVE FOR DB(J)
3630 416 D0 420 I=1,K
3640 DB(I)=0.
3650 D0 421 J=1,K

```

**FT** **COM** **M**  
**FT** **COM** **M**  
**FT** **COM** **M**  
**FT** **COM** **M**

```

G
3660 DB(I)=A(I,J)*G(J)+DB(I)
3670 DB(I)=XKDB*DB(I)
3680 XLL=0.
3690 DTG = 0.
3700 GTG = 0.
3710 DO 250 J=1,K
3720 XLL=XLL+DB(J)*DB(J)
3730 DTG = DTG + DB(J)*G(J)
3740 GTG = GTG + G(J)**2
3750 DB(J)=DB(J)/SA(J)
3760 B(J)=B(J)+DB(J)
3770 KIP=K-IP
3780 IF (KIP.EQ.1) GO TO 1257
3790 CGAM=DTG/SQRT(XLL*GTG)
3800 JGAM = 1
3810 IF(CGAM.GT..0) GO TO 253
3820 CGAM = ABS(CGAM)
3830 JGAM = 2
3840 GAMMA=57.2958*(1.57073+CGAM*(-0.212114+CGAM*(0.074261
3850 &-CGAM*.0187293)))*SQRT(1.-CGAM)
3860 GO TO (257,255), JGAM
3870 GAMMA = 180.-GAMMA
3880 IF (XL.LT.1.0)GO TO 257
3890 PRINT 922,XL,GAMMA
3900 GO TO 700
3910 GAMMA=0.
3920 257 XLL=SQRT(XLL)
3930 IBK2=1
3940 GO TO 300
3950 252 IF(IWS(3).EQ.0) GO TO 256

```

G

RECOMM

G

RECOMM

RECOMM

RECOMM



```

4260 706 WS=N-K+IP
4270 SE=SQRT(PHI/WS)
4280 PHIZ=PHI
4290 IF(IWS(2).EQ.0) GO TO 709
4300 PRINT 903,PHIZ,SE,XL
4310 GO TO 708
4320 709 PRINT 909,PHIZ,SE,XL
4330C NOW WE HAVE MATRIX A
4340 708 DO 1123 II=1,K
4350 III=II+K
4360 DO 1123 JJ=1,K
4370 1123 A(III,JJ)=A(II,JJ)
4380 IBKM=2
4390 GO TO 404
4400C NOW WE HAVE C = A INVERSE
4410 710 DO 711 J=1,K
4420 IF(A(J,J).LT..0) GO TO 713
4430 711 SA(J)=SORT(A(J,J))
4440 GO TO 715
4450 713 IBOUT=1
4460 715 KST=-4
4470 PRINT 916
4480 234 KST=KST+5
4490 KEND=KST+4
4500 IF (KEND.LT.K) GO TO 719
4510 KEND=K
4520 719 DO 712 I=1,K
4530 712 PRINT 918,I,(A(I,J),J=KST,KEND)
4540 IF (KEND.LT.K) GO TO 234
4550 IF (IBOUT.EQ.0) GO TO 717

```

**FTM**  
**FTM**  
**FTM**  
**FTM**  
**FTM**  
**FTM**  
**FTM**

```

4560 PRINT 936
4570 GO TO 10
4580 717 DO 718 I=1,K
4590 DO 718 J=1,K
4600 WS=SA(I)*SA(J)
4610 IF(WS.GT. 0.) GOTO 716
4620 A(I,J)=0.
4630 GO TO 718
4640 716 A(I,J)=A(I,J)/WS
4650 718 CONTINUE
4660 DO 720 J=1,K
4670 720 A(J,J)=1.
4680 PRINT 917
4690 KST=-9
4700 721 KST=KST+10
4710 KEND=KST+9
4720 IF (KEND.LT.K) GO TO 722
4730 KEND=K
4740 722 DO 724 I=1,K
4750 724 PRINT 935,I,(A(I,J),J=KST,KEND)
4760 IF (KEND.LT.K) GO TO 721
4770C GET T*SE*SQRT(C(I,I))
4780 DO 726 J=1,K
4790 726 SA(J)= SE*SA(J)
4800 DO 1113 II=1,K
4810 III=II+K
4820 DO 1113 JJ=1,K
4830 1113 A(II,JJ)=A(III,JJ)
4840 PRINT 919
4850 WS=K-IP

```

END

PROGRAM

END

END

PROGRAM

FM G RFCOMM  
4860 D0 750 J=1,K  
4870 IF (IP.LE.0)G0 T0 743  
4880 D0 742 I=1,IP  
4890 IF (J.EQ.IB(I))G0 T0 746  
4900 742 CONTINUE  
4910 HJTD=SQRT(WS\*FF)\*SA(J)  
4920 STE=SA(J)  
4930 CPL=BS(J)-SA(J)\*T  
4940 CPU=BS(J)+SA(J)\*T  
4950 SPL=BS(J)-HJTD  
4960 SPU=BS(J)+HJTD  
4970 PRINT 927,J,STE,0PL,SPL,0PU,SPU  
4980 G0 T0 750  
4990 746 PRINT 913,J  
5000C NONLINEAR CONFIDENCE LIMIT  
5010 750 IF(IWS(6).EQ.1) G0 T0 10  
5020 WS=K-IP  
5030 WS1=N-K+IP  
5040 PKN=WS/WS1  
5050 PC=PHIZ\*(1.+FF\*PKN)  
5060 PRINT 920,PC  
5070 PRINT 921  
5080 IWS(3)=1  
5090 D0 790 J=1,K  
5100 IBKP=1  
5110 D0 752 JJ=1,K  
5120 752 B(JJ)=BS(JJ)  
5130 IF (IP.LE.0)G0 T0 758  
5140 D0 756 JJ=1,IP  
5150 IF (J.EQ.IB(JJ))G0 T0 787  
RFCOMM  
GFM RFCOMM

5160 756 CONTINUE  
 5170 758 DD=-1.  
 5180 IBKN=1  
 5190 760 D=DD  
 5200 B(J)=BS(J)+D\*SA(J)  
 5210 IBK2=4  
 5220 G0 T0 300  
 5230 PHI1=PHI  
 5240 IF (PHI1.GE.PC)G0 T0 770  
 5250 764 D=D+DD  
 5260 IF (D/DD.GE.5.)G0 T0 788  
 5270 B(J)=BS(J)+D\*SA(J)  
 5280 IBK2=5  
 5290 G0 T0 300  
 5300 766 PHID=PHI  
 5310 IF (PHID.LT.PC)G0 T0 764  
 5320 IF (PHID.GE.PC) G0 T0 778  
 5330 770 D=D/2.  
 5340 IF (D/DD.LE..001)G0 T0 788  
 5350 B(J)=BS(J)+D\*SA(J)  
 5360 IBK2=6  
 5370 G0 T0 300  
 5380 772 PHID=PHI  
 5390 IF (PHID.GT.PC)G0 T0 770  
 5400 778 XK1=PHIZ/D+PHI1/(1.-D)+PHID/(D\*(D-1.))  
 5410 XK2=- (PHIZ\*(1.+D)/D+D/(1.-D)\*PHI1+PHID/(D\*(D-1.)))  
 5420 XK3=PHIZ-PC  
 5430 BC = (SORT(XK2\*XK2-4.\*XK1\*XK3)-XK2)/(2.\*XK1)  
 5440 G0 T0 (779,784),IBKN  
 5450 779 B(J)=BS(J)-SA(J)\*BC

FT  
 G

COMMM  
 R  
 COMMM  
 R

FT  
 G

COMMM  
 FT  
 COMMM



5460	GO TO 781
5470	784 B(J)=BS(J)+SA(J)*BC
5480	781 IBK2=2
5490	GO TO 300
5500	780 GO TO (782,786),IBKN
5510	782 IBKN=2
5520	DD=1.
5530	BL=B(J)
5540	PL=PHI
5550	GO TO 760
5560	786 BU=B(J)
5570	PU=PHI
5580	GO TO (783,795,785,789),IBKP
5590	783 PRINT 940,J,BL,BU,PL,PU
5600	GO TO 790
5610	795 PRINT 915,J,BU,PU
5620	GO TO 790
5630	785 PRINT 941,J,BL,PL
5640	GO TO 790
5650	787 PRINT 913,J
5660	GO TO 790
5670	789 PRINT 914,J
5680	GO TO 790
5690	788 GO TO (791,792),IBKN
5700C	DELETE LOWER PRINT
5710	791 IBKP=2
5720	GO TO 780
5730	792 GO TO (793,794),IBKP
5740C	DELETE UPPER PRINT
5750	793 IBKP=3

**FM** 5760 GO TO 780  
 5770C LOWER IS ALREADY DELETED, SO DELETE BOTH  
**FM** 5780 794 IBKP=4  
**GD** 5790 GO TO 780  
**GD** 5800 790 CONTINUE  
 5810 GO TO 10  
 5820 900 FORMAT(1X,"N,K,IP,M,IFP,NCONS")  
 5830 901 FORMAT(1X,"IWS(I),I=1,6")  
 5840 903 FORMAT(/24H ESTIMATED PARTIALS USED /13X,4H PHI 14X,  
 5850 &4H S E 9X,7H LAMBDA /5X,2E18.8,E13.3)  
 5860 904 FORMAT(/12H INCREMENTS /4(/1X,4E18.8))  
 5870 905 FORMAT (13X,4H PHI 10X,7H LAMBDA 6X,7H GAMMA 6X, 7H LENGTH /  
 5880 & 5X, E18.8, 3E13.3)  
 5890 906 FORMAT(1X,1E9.2,36X,E9.2/1X,1H+ 49X,1H+)  
 5900 907 FORMAT(5H- N= 13,5X,5H K = 13,5X,5H IP= 13,5X,5H M = 13,5X,  
 5910 & 7H IFP = 13/5X,13HGAMMA CRIT = E10.3,5X,6HDEL = E10.3,6H FF =  
 5920 & E10.3/5X,5H T = E10.3,5X,5H E = E10.3,5X,7H TAU = E10.3/5X,6H XL=  
 5930 & E10.3 , 4X, 7HZETA = E10.3 /)  
 5940 908 FORMAT(/2H (13,13H) PARAMETERS 3E18.8,3(/18X,3E18.8))  
 5950 909 FORMAT(/24H ANALYTIC PARTIALS USED /13X,4H PHI 14X,  
 5960 &4H S E 9X,7H LAMBDA /5X,2E18.8,E13.3)  
 5970 910 FORMAT(1H /5X,9X,4H OBS 13X,5H PRED 13X,5H DIFF )  
 5980 911 FORMAT(/24H ESTIMATED PARTIALS USED /9X,4H PHI 12X,4H S E  
 5990 &9X,7H LENGTH 4X,7H GAMMA 4X,7H LAMBDA /1X,2E16.8,3E11.3)  
**FM** 6000 912 FORMAT(/24H ANALYTIC PARTIALS USED /9X,4H PHI 12X,4H S E  
 6010 &9X,7H LENGTH 4X,7H GAMMA 4X,7H LAMBDA/5X,2E16.8,3E11.3)  
 6020 913 FORMAT(2X,13,20H PARAMETER NOT USED )  
 6030 914 FORMAT(2X,13,12H NONE FOUND )  
 6040 915 FORMAT(2X,13,18X,E18.8/23X,E18.8)  
**FM** 6050 916 FORMAT(1H /13H PTP INVERSE )

```

6060 917 FORMAT(1H /30H PARAMETER CORRELATION MATRIX )
6070 918 FORMAT(2X,13,6E12.5/ 2(6X,6E10.5))
6080 919 FORMAT(1H /1H /13X,4H STD,11X,13H ONE-PARAMETER 6X,14H
6090 &SUPPORT PLANE /3X,2H B 7X,6H ERROR 9X,14H LOWER / UPPER
6100 &6X,14H LOWER / UPPER)
6110 920 FORMAT(1H /1H /30H NONLINEAR CONFIDENCE LIMITS / /
6120 & 16H PHI CRITICAL = E15.8)
6130 921 FORMAT(1H /5H PARA 19H LOWER B / LOWER PHI 19H UPPER
6140 &B / UPPER PHI )
6150 922 FORMAT(1H-/20X,17HGAMMA LAMBDA TEST 6X,2E13.3)
6160 923 FORMAT (1H-/60X,12HEPSILON TEST )
6170 924 FORMAT(1H-/60X,10HFORCE OFF )
6180 925 FORMAT(5X,3E18.8/ 2(10X,3E18.8))
6190 926 FORMAT ( 40H BAD DATA, SUBSCRIPTS FOR UNUSED BS = 0 / / / )
6200 927 FORMAT(2X,13,3E18.8/23X,2E18.8)
6210 928 FORMAT(1H 70A1)
6220 929 FORMAT(1X,"YMN,SPRD")
6230 930 FORMAT(1X,"IB(I),I=1,"",13)
6240 931 FORMAT(1X,"FF,T,E,TAU,XL,GAMCR,DEL,ZETA")
6250 932 FORMAT(1X,"B(I),I=1,"",13)
6260 933 FORMAT(5HON = 13,5X,5H K = ,13,5X,5H IP= ,13,5X,5H M = ,13,5X
& /6H FF = ,E10.3,4X,5H T = ,E10.3,
6280 & 4X,5H E = ,E10.3,4X,7H TAU = ,E10.3/)
6290 934 FORMAT(1H-/55X,18HGAMMA EPSILON TEST )
6300 935 FORMAT(3X,15,2X,6F10.4/2(11X,6F10.4))
6310 936 FORMAT (27H0 NEGATIVE DIAGONAL ELEMENT )
6320 937 FORMAT(3X,15,2X,6F10.4/ 2(11X,6F10.4))

```

```

6330 938 FORMAT(1H /25H CONSTRAINT RESIDUALS ... /12(3X,15,33X,E18.8)
6340 939 FORMAT (1H /23H PTP CORRELATION MATRIX )
6350 940 FORMAT(2X,13,2E18.8/5X,2E18.8)
6360 941 FORMAT(2X,13,E18.8/5X,E18.8)
6370 942 FORMAT(1X,"Y(I),(X(I),L=1,"",13,"")"
6380 660 STOP
6390 END
6400 SUBROUTINE GJR(N, EPS, MSING)
6410C GAUSS-JORDAN-RUTISHAUSER MATRIX INVERSION WITH DOUBLE PIVOTING
6420C K, N, M AS DEFINED IN MAIN PROGRAM
6430C DIMENSION PRNT(5), X(N, M), B(K), Y(N), A(2K, K), P(K)
6440C DIMENSION C(K), Q(K), BDUM(K)
6450 DIMENSION PRNT(5)
6460 DIMENSION X(25, 1), B(12), Y(25), A(24, 12), P(12)
6470 DIMENSION C(12), Q(12), BDUM(12)
6480 COMMON X, BDUM, PRNT, A, DUMM(12)
6490 COMMON Y
6500 COMPLEX Y
6510 MSING=1
6520 DO 10 K=1, N
6530C DETERMINATION OF THE PIVOT ELEMENT
6540 PIVOT=0.
6550 DO 20 I=K, N
6560 DO 20 J=K, N
6570 IF((ABS(A(I, J)) - ABS(PIVOT)) .LE. 0.) GO TO 20
6580 PIVOT=A(I, J)
6590 P(K)=I
6600 Q(K)=J
6610 20 CONTINUE
6620 IF((ABS(PIVOT)-EPS) .LE. 0.) GO TO 40

```

END

END

END

END

END

END

END

END

END

END

END

END

END

END

END

END

END

END

END

END

END







```

7540 RETURN
7550 END
7560 SUBROUTINE PCODE(F,I)
7570C CODING FOR PARTIAL OF F WITH RESPECT TO B S
7580C K,N,M AS DEFINED IN MAIN PROGRAM
7590C DIMENSION PRNT(5),X(N,M),B(K),Y(N),A(2K,K),P(K)
7600 DIMENSION PRNT(5)
7610 DIMENSION X(25,1),B(12),Y(25),A(24,12),P(12)
7620 COMMON X,B,PRNT,A,P
7630 COMMON Y
7640 COMPLEX Y
7650 RETURN
7660 END

```

COM  
LJ  
LJ  
LJ



INPUT ITEMS FOR NLIN1

<u>INPUT ITEM NO.</u>	<u>FORTRAN LABEL</u>	<u>COMMENTS</u>
1	N	No. of data points.
	K	Total No. of parameters.
	IP	No. of omitted parameters.
	M	No. of independent variables.
	IFP	IFP = 0 to tabulate $Y_i, Y_i, (Y_i - Y_i), \text{PRNT}(1) \dots \text{PRNT}(5)$ IFP = 1 to plot $Y_i, Y_i$ .
	NCONS	No. of constraints.
2	IWS(1)	Doesn't apply.
	IWS(2)	= 0 Analytical derivatives. = 1 Estimated derivatives.
	IWS(3)	= 0 Abbreviated printout. = # Detail printout for # iterations
	IWS(4)	= 0 No force off. = # Forced branch to confidence region calculation after # iterations.
	IWS(5)	Doesn't apply.
	IWS(6)	= 0 Nonlinear confidence limits desired.
3	YMN	Left side of plot.
	SPRD	Spread of plot.
(Item 3 is required only if IFP = 1.)		
4	IB(1)	Subscripts of omitted B(J)'S.
	IB(IP)	

INPUT ITEMS FOR NLIN1 CONT.

<u>INPUT ITEM NO.</u>	<u>FORTTRAN LABEL</u>	<u>COMMENTS</u>
(Item 4 is required only if IP 0.)		
5	FF	Variance ratio statistic.
	T	Student's T.
	E	Convergence criterion.
	TAV	Convergence criterion.
	XL	Program parameter.
	GAMCR	Critical angle.
	DEL	Used in finite difference derivatives.
	ZETA	Singularity criterion for matrix inversion.
<p>Any or all of the quantities may be left zero. If this is done, the program supplies the following reasonable values for most situations.</p> <p>FF = 4.0, T = 2.0, E = <math>5 \times 10^{-5}</math>, TAV = <math>10^{-3}</math>,            XL = <math>10^{-2}</math>, GAMCR = <math>\pi/4</math>, DEL = <math>10^{-5}</math>, ZETA = <math>10^{-31}</math></p>		
6	B(1) ⋮ B(K)	Initial guess for parameters.
7		This item consists of N sub-items. Each sub-item is the input data for one observation. The sequence of variables in a sub-item must be:  Y(I), X(I,1), X(I,2), ...X(I,M). Each Y(I) begins on a new line.
8		Case data from subroutine SUB Z. In this case, a comment line is required.
9		Sequential cases by repeating items 1 through 8. For normal exit type item 1 with all zeroes.

COM  
M  
G

M0D 12:32 04/07/70

100 COMPLEX CFP,CFB,CYP,CGAMP,CGAMB,CBETA,CTP,S,SS,CTVP,CTVB,  
 110 &CEL,CEN,TEM,CS,HS,NUMB,NUMP,DEN,DEN1,DEN2,CYB,CEPP,CEPB,CE  
 120 &P,CEB,CBY,COPY  
 130 REAL ZERO,OMEGA,ZS,ZT,U,U0,VP,K,GAMP,GAMB,VB,UB,UP,BETA,TP,  
 140 &OM,Z,TVP,TVB,EL,EN,R,XMAG,AMAG,DUM,ANG,K1,K2,Y1,Y2,Z0,  
 150 &EPP,EPB,EP,EB  
 160 DIMENSION OMEGA(100),ZS(18)  
 170 ZERO=0.0  
 180C NO. OF VALUES OF OMEGA  
 190 INPUT,NIT  
 200 INPUT,(OMEGA(I),I=1,NIT)  
 210C NO. OF STAGES. IF ZERO, PROGRAM EXITS  
 220 2 INPUT,NIT  
 230 IF(NIT.LE.0) GO TO 3  
 240C HEIGHT OF STAGES  
 250 INPUT,(ZS(I),I=1,NIT)  
 260 ZT=0.0  
 270 DO 10 I=1,NIT  
 280 10 ZT=ZT+ZS(I)  
 290 95 FORMAT(1H 1X,3(/1X,4G15.3))  
 300C INPUT PARAMETERS

```

R F C O M M
310 INPUT,U,U0,VP,K,GAMB,GAMP,K1,K2,Z0,EP,EB,VB,Y
320 VB=1.0-VP-VBY
330 UP=U0
340 UBY =ZT*(U-UP)/(ZT-Z0)+UP
350 BPT=ZT/UBY
360 UB=(U-VP*UP-VBY*UBY)/VB
370C IF UB.LT.UP DEAD ZONE EXISTS
380 IF(UB.GE.UP)G0 T0 11
390 UB=UP
400 DUM=VP
410 VP=(U-VBY*UBY-VB*UB)/UP
420 DUM=DUM-VP
430 PRINT,VP,DUM
440 GAMB=GAMP
450 G0 T0 12
460 11 GAMB=(GAMP/VB)*(Z0/ZT-VP)
470 12 BETA=VP*UP/U
480 TP=VP/K
490 IF(GAMB.GT.0.) G0 T0 9
500 GAMB=0.
510 9 PRINT 95,(ZS(I),I=1,NIT),ZT
520 PRINT 93,U,U0,VP,K,GAMB,GAMP,K1,K2,Z0,UB,EP,EB,UBY
530 93 F0RMA T(4(/1X,4G15.3))
540 PRINT 91
550 91 F0RMA T(/8X,"FREQUENCY",6X,"MAGNITUDE",8X,"ANGLE")
560 CEP=CMPLX(EP,ZER0)

```

R F C O M M

G F

R F C O M M

R F C O M M

```

570 CEB=CMPLX(EB,ZER0)
580 CGAMB=CMPLX(GAMB,ZER0)
590 CGAMP=CMPLX(GAMP,ZER0)
600 CBETA=CMPLX(BETA,ZER0)
610 CBY=CMPLX((VBY*UBY/U),ZER0)
620 CTP=CMPLX(TP,ZER0)
630 IT=1
640 I OM=OMEGA(IT)
650 IF(OM.LE.0.) GO TO 2
660C CALCULATE ADMITTANCE
670 Y1=(K1/(1.0+(K2/OM)**2))
680 Y2=(K1*(K2/OM))/(1.0+(K2/OM)**2)
690 CYP=CMPLX(Y1,Y2)
700 CYB=CYP
710 CYP=CYP*CEP
720 CYB=CYB*CEB
730 S=CMPLX(ZER0,OM)
740 SS=((1.0,0.0)-CGAMP)*S+CGAMP*CYP
750 CFP=(1.0,0.0)
760 CFB=(1.0,0.0)
770 D0 6 I=1,NIT
780 Z=ZS(I)
790 TVP=VP*Z/U
800 TVB=VB*Z/U

```

FM

G

FM

G

FM

G

FM

G

FM

G

FM

G

```

810 EL=Z/UP
820 EN=EL/TP
830 CTVP=CMPLEX(TVP,ZERØ)
840 CTVB=CMPLEX(TVB,ZERØ)
850 CEL=CMPLEX(EL,ZERØ)
860 CEN=CMPLEX(EN,ZERØ)
870 TEM=-CEN-CEL*SS
880 E=EXP(REAL(TEM))
890 F=CGS(AIMAG(TEM))
900 H=SIN(AIMAG(TEM))
910 F=E*F
920 H=E*H
930 HS=CMPLEX(F,H)
940 NUMB=CFB*((1.0,0.0)-CBETA-CBY)+CFP*CBETA*((1.0,0.0)-HS)
950 &/((CTP*SS+(1.0,0.0))
960 NUMP=((1.0,0.0)-HS)*NUMB/(CTP*SS+(1.0,0.0))
970 DEN=(((1.0,0.0)-CGAMB)*CTVB*S)+CTVP*SS/(CTP*SS+(1.0,0.0))
980 DEN1=CBETA*(CTP*SS+(2.0,0.0))*CTP*SS/((CTP*SS+(1.0,0.0))**2)
990 DEN2=CTVB*CGAMB*CYB-CBETA*HS/((CTP*SS+(1.0,0.0))**2)
1000 DEN=DEN+DEN2-DEN1+(1.0,0.0)-CBY
1010 CFB=NUMB/DEN
1020 6 CFP=NUMP/DEN+CFP*HS
1030 CBPY=CEXP(CMPLEX(ZERØ,(-ØM*BPT)))
1040C PREDICTED TRANSFER FUNCTION
1050 CS=((1.0,0.0)-CBETA-CBY)*CFB+CBETA*CFP+CBY*CBPY

```

**Q** **RF** **COMM** **RF** **COMM** **RF** **COMM** **RF** **COMM**

1060C CONVERT TRANSFER FUNCTION TO MAGNITUDE RATIO & PHASE ANGLE

```

1070 R=REAL(CS)
1080 XMAG=AIMAG(CS)
1090 AMAG=SQRT(R**2+XMAG**2)
1100 DUM=XMAG/R
1110 IF(DUM.LT.1.0E+36) GO TO 4
1120 ANG=ATAN(R/XMAG)*(180./3.14159)
1130 IF(R.LT.0.) ANG=ANG-90.
1140 GO TO 5
1150 4 ANG=ATAN(DUM)*(180./3.14159)
1160 IF(R.LT.0.) ANG=ANG-180.
1170 5 IF(ANG.LE.0.) GO TO 7
1180 ANG=ANG-360.
1190 7 PRINT 92,0M,AMAG,ANG
1200 92 FORMAT(1X,3G15.3)
1210 IT=IT+1
1220 GO TO 1
1230 3 CONTINUE
1240 STOP
1250 END

```

M M G F F C O M M

APPENDIX IV  
CALCULATIONS



TABLE III

## PHASE ANGLE SHIFT FROM CALCULATED LAG TIMES

Flow Rate, ft./sec.	0.264	0.309	0.399
Lag Time, secs.	0.5	0.275	0.286
=====			
Frequency, rad./sec.	-----		
0.1	2.86	1.57	1.64
0.2	5.72	3.14	3.28
0.3	8.58	4.71	4.92
0.4	11.4	6.28	6.56
0.5	14.3	7.85	8.20
0.6	17.2	9.42	9.84
0.7	20.0	11.0	11.5
0.8	22.8	12.6	13.1
0.9	25.7	14.1	14.8
1.0	28.6	15.7	16.4
2.0	57.2	31.4	32.8
3.0	85.8	47.1	49.2
4.0	114.	62.8	65.6
5.0	143.	78.5	82.0
6.0	172.	94.2	98.4
7.0	200.	110.	115.
8.0	228.	126.	131.
9.0	257.	141.	148.
10.	286.	157.	164.

APPENDIX V  
COMPUTED DATA

PT COMM  
PT COMM  
PT COMM  
PT COMM

NLINI 16:45 03/13/70

N,K,IP,M,IFP,NCCNS?17,4,2,1,1,0

IWSC(I),I=1,6?0,1,2,20,0,0

YMN,SPRD?-2.0,2.0

IBC(I),I=1, 2?1,2

FF,T,E,TAU,XL,GAMCR,DEL,ZETA?0,0,0,0,0,0,0,0

B(I),I=1, 4?5.14,0.542,88.5,4.52.35,0.693,120.,4.0

.- IS BAD CHAR IN DATA OR BAD FORMAT.

RETYPE DATA FOR LIST IN LINE 235

?5.14,0.542,88.5,4.5

Y(I),(X(I,L))L=1, 1)?.7746,-.6324,0.02

? .5630,-.8144,0.03

? .2460,-.9486,0.04

GF	?	-.07779,	-.9669,	0.05
GF	?	-.3705,	-.8856,	0.06
GF	?	-.6610,	-.6893,	0.07
GF	?	-.8301,	-.4620,	0.08
GF	?	-.9284,	-.1470,	0.09
GF	?	-.9232,	.1479,	0.1
GF	?	.2327,	.8279,	0.15
GF	?	.7026,	-.2324,	0.2
GF	?	-.4585,	.1994,	0.3
GF	?	.2869,	-.1630,	0.4
GF	?	-.1546,	0.0922,	0.5
GF	?	.0918,	-.0371,	0.60
GF	?	-.0533,	.0173,	0.7
GF	?	.0299,	-.0021,	0.8
GF	?	F-12 PLUG FLOW REACTOR AIR RATE 2.0 CM		







PTP CORRELATION MATRIX			
1	1.0000	0.	0.
2	0.	1.0000	0.
3	0.	0.	1.0000
4	0.	0.	-0.9986

ESTIMATED PARTIALS USED			
	PHI	S E	LAMBDA
	0.46963375E+01	0.55954371E+00	0.100E-01

INCREMENTS			
0.	0.	0.	-0.11606948E+02

INCREMENTS			
0.	0.	0.	-0.23566788E+00

PTP CORRELATION MATRIX			
1	1.0000	0.	0.
2	0.	1.0000	0.
3	0.	0.	1.0000
4	0.	0.	-0.9986

ESTIMATED PARTIALS USED			
	PHI	S E	LAMBDA
	0.50038820E+12	0.100E-02	0.825E+02

INCREMENTS			
0.	0.	0.	-0.39073251E+02

INCREMENTS			
0.	0.	0.	-0.22453842E+01

OMM GF RECOMM GF RECOMM GF



GM	( 2 )	PARAMETERS	0.51400000E+01	0.54200000E+00	0.22534910E+02
FM			0.21916045E+01		
GM		ESTIMATED PARTIALS USED			
GM		PHI	S E	LENGTH	LAMBDA
		0.59232109E+00	0.19871606E+00	0.118E+02	0.825E+02 0.100E-01
GM	( 3 )	PARAMETERS	0.51400000E+01	0.54200000E+00	0.29744771E+02
			0.26921962E+01		
GM		ESTIMATED PARTIALS USED			
GM		PHI	S E	LENGTH	LAMBDA
		0.94736129E-01	0.79471642E-01	0.288E+01	0.796E+02 0.100E-02
GM	( 4 )	PARAMETERS	0.51400000E+01	0.54200000E+00	0.43354798E+02
			0.39347743E+01		
GM		ESTIMATED PARTIALS USED			
GM		PHI	S E	LENGTH	LAMBDA
		0.98543253E-02	0.25631134E-01	0.243E+01	0.480E+02 0.100E-03
GM	( 5 )	PARAMETERS	0.51400000E+01	0.54200000E+00	0.49387179E+02
			0.44855003E+01		
GM		ESTIMATED PARTIALS USED			
GM		PHI	S E	LENGTH	LAMBDA
		0.84017115E-02	0.23666730E-01	0.151E+01	0.522E+02 0.100E-04

COM	6)	PARAMETERS	0.51400000E+01	0.54200000E+00	0.46860297E+02
COM			0.42508466E+01		
COM		ESTIMATED PARTIALS USED			
COM		PHI	S E	LENGTH	LAMBDA
COM		0.7241139E-02	0.21971366E-01	0.543E+00	0.324E+02 0.100E-03
COM	7)	PARAMETERS	0.51400000E+01	0.54200000E+00	0.46620405E+02
COM			0.42335565E+01		
COM		ESTIMATED PARTIALS USED			
COM		PHI	S E	LENGTH	LAMBDA
COM		0.71266487E-02	0.21797016E-01	0.106E+00	0.836E+02 0.100E-03
COM	8)	PARAMETERS	0.51400000E+01	0.54200000E+00	0.46912470E+02
COM			0.42594095E+01		
COM		ESTIMATED PARTIALS USED			
COM		PHI	S E	LENGTH	LAMBDA
COM		0.71184443E-02	0.21784466E-01	0.656E-01	0.791E+02 0.100E-04
COM	9)	PARAMETERS	0.51400000E+01	0.54200000E+00	0.46901383E+02
COM			0.42596260E+01		
COM		ESTIMATED PARTIALS USED			
COM		PHI	S E	LENGTH	LAMBDA
COM		0.71180564E-02	0.21783872E-01	0.182E-02	0.309E+02 0.100E+00

( 10 )	PARAMETERS	0.51400000E+01	0.54200000E+00	0.46871251E+02
		0.42557070E+01		
ESTIMATED PARTIALS USED				
	PHI	S E	LENGTH	LAMBDA
	0.71173885E-02	0.21782850E-01	0.844E-02	0.777E+02 0.100E-01
( 11 )	PARAMETERS	0.51400000E+01	0.54200000E+00	0.46860272E+02
		0.42558232E+01		
ESTIMATED PARTIALS USED				
	PHI	S E	LENGTH	LAMBDA
	0.71171350E-02	0.21782462E-01	0.177E-02	0.361E+02 0.100E+00
( 12 )	PARAMETERS	0.51400000E+01	0.54200000E+00	0.46844237E+02
		0.42532812E+01		
ESTIMATED PARTIALS USED				
	PHI	S E	LENGTH	LAMBDA
	0.71170969E-02	0.21782404E-01	0.518E-02	0.732E+02 0.100E-01
( 13 )	PARAMETERS	0.51400000E+01	0.54200000E+00	0.46834937E+02
		0.42534834E+01		
ESTIMATED PARTIALS USED				
	PHI	S E	LENGTH	LAMBDA
	0.71169672E-02	0.21782206E-01	0.153E-02	0.297E+02 0.100E+00

RF COMM  
RF COMM  
RF COMM  
RF COMM  
RF COMM

Q

RECOMM

RECOMM

( 14) PARAMETERS 0.51400000E+01 0.54200000E+00 0.46839392E+02  
0.42528853E+01

ESTIMATED PARTIALS USED

PHI S E LENGTH GAMMA LAMBDA  
0.71168218E-02 0.21781983E-01 0.249E-02 0.578E+02 0.100E+00

( 15) PARAMETERS 0.51400000E+01 0.54200000E+00 0.46832585E+02  
0.42532173E+01

ESTIMATED PARTIALS USED

PHI S E LENGTH GAMMA LAMBDA  
0.71166647E-02 0.21781743E-01 0.324E-02 0.666E+02 0.100E+00

( 16) PARAMETERS 0.51400000E+01 0.54200000E+00 0.46837322E+02  
0.42527422E+01

ESTIMATED PARTIALS USED

PHI S E LENGTH GAMMA LAMBDA  
0.71165636E-02 0.21781588E-01 0.130E-02 0.246E+02 0.100E+00

( 17) PARAMETERS 0.51400000E+01 0.54200000E+00 0.46830974E+02  
0.42530322E+01

ESTIMATED PARTIALS USED

PHI S E LENGTH GAMMA LAMBDA  
0.71164643E-02 0.21781436E-01 0.322E-02 0.685E+02 0.100E+00

( 18) PARAMETERS 0.51400000E+01 0.54200000E+00 0.46835880E+02  
0.42526407E+01

ESTIMATED PARTIALS USED  
PHI S E LENGTH GAMMA LAMBDA  
0.71164123E-02 0.21781356E-01 0.120E-02 0.247E+02 0.100E+00

( 19) PARAMETERS 0.51400000E+01 0.54200000E+00 0.46831164E+02  
0.42530302E+01

ESTIMATED PARTIALS USED  
PHI S E LENGTH GAMMA LAMBDA  
0.71163556E-02 0.21781270E-01 0.113E-02 0.182E+02 0.100E+00

FORCE OFF

N = 17 K = 4 IP = 2 M = 1  
FF = 0.400E+01 T = 0.200E+01 E = 0.500E-04 TAU = 0.100E-02

GF R F C O M M GF R F C O M M GF R F C O M M

COMM GE RECOMM

( 19) PARAMETERS 0.5140000E+01 0.5420000E+00 0.46831164E+02

-0.20E+01  
+

0.  
+  
Y Y Y Y Y Y Y Y Y Y  
Y  
Y  
Y

- P0

P 0

P 0

P 0

COMM			
GF RECOMM			
GF			
RF			
( 19) PARAMETERS			
GRS	PRED	DIFF	
0.51400000E+01	0.54200000E+00	0.46831164E+02	
0.42530302E+01			
0.99996746E+00	0.99711911E+00	0.24217415E-01	
0.99005876E+00	0.99352987E+00	0.24966590E-01	
0.97997855E+00	0.98852695E+00	0.94281074E-02	
0.97002417E+00	0.98213218E+00	0.12109891E-01	
0.95997792E+00	0.97437337E+00	0.20037580E-01	
0.95501596E+00	0.96528404E+00	0.24974275E-01	
0.95000526E+00	0.95490327E+00	0.89104907E-02	
0.93996572E+00	0.94327533E+00	0.12756214E-01	
0.93497200E+00	0.93044940E+00	0.45950972E-02	
0.85998122E+00	0.85036884E+00	0.33549217E-01	
0.74003819E+00	0.74985673E+00	0.12387649E-01	
0.49998261E+00	0.52417330E+00	0.28243298E-01	
0.32997062E+00	0.31856771E+00	0.13352899E-01	







DPLS EX

TABLE IV

RUN ID H-01

COMMENTS HE TRACER BEH IN AIR RATE 6.3 CM

12/27/68

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FRFQ CONTENT NORMALIZED	ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	1.17	0.0000 00	0.0000 00	0.0000 00	0.0000 00	0.0000 00	1.00	71.8
0.1000-01	1.00	-0.320	0.999	-0.3900-01	0.999	-0.3340-01	1.00	71.8
0.2000-01	1.00	-0.642	0.996	-0.7790-01	0.996	-0.6670-01	0.998	71.7
0.3000-01	1.00	-0.967	0.990	-0.116	0.991	-0.9950-01	0.996	71.5
0.4000-01	1.00	-1.30	0.983	-0.154	0.984	-0.132	0.993	71.3
0.5000-01	1.00	-1.63	0.973	-0.192	0.975	-0.163	0.989	71.0
0.6000-01	1.00	-1.97	0.962	-0.228	0.965	-0.194	0.984	70.7
0.7000-01	1.01	-2.32	0.948	-0.264	0.953	-0.224	0.978	70.3
0.8000-01	1.01	-2.69	0.933	-0.298	0.939	-0.252	0.972	69.8
0.9000-01	1.01	-3.06	0.916	-0.331	0.924	-0.280	0.965	69.3
0.100	1.01	-3.44	0.898	-0.363	0.908	-0.305	0.958	68.8
0.200	1.03	-3.88	0.858	-0.600	0.712	-0.485	0.861	61.9
0.300	1.04	-4.39	0.804	-0.695	0.527	-0.557	0.767	55.1
0.400	1.03	-4.97	0.759	-0.696	0.372	-0.583	0.691	49.6
0.500	1.02	-5.3	0.716	-0.629	0.234	-0.573	0.619	44.5
0.600	0.992	-5.7	0.673	-0.520	0.126	-0.536	0.551	39.6
0.700	0.956	-6.1	0.625	-0.404	0.4640-01	-0.492	0.494	35.5
0.800	0.916	-6.7	0.573	-0.296	-0.1440-01	-0.447	0.447	32.1
0.900	0.875	-7.1	0.520	-0.199	-0.6200-01	-0.401	0.405	29.1
1.00	0.825	-7.8	0.464	-0.117	-0.9830-01	-0.355	0.369	26.5
2.00	0.388	-12.1	0.2940-01	0.4980-01	-0.138	-0.5760-01	0.149	10.7
3.00	0.223	-17.4	0.1700-02	0.1470-01	-0.6440-01	0.1250-01	0.6610-01	4.75
4.00	0.257	-25.2	0.1480-02	0.7370-07	-0.2340-01	0.1720-01	0.2900-01	2.09
5.00	0.267	-31.8	0.1770-02	0.3050-07	-0.1060-01	0.8570-02	0.1360-01	0.979
6.00	0.149	-43.2	0.1270-02	-0.1340-03	-0.4720-02	0.7160-02	0.8580-02	0.616
7.00	0.435	103.	-0.1230-02	-0.1280-07	-0.2240-02	0.3430-02	0.4090-02	0.294
8.00	0.546	12.8	-0.1100-02	0.1080-02	-0.1540-02	0.2370-02	0.2830-02	0.203
9.00	0.401	-34.3	0.2750-03	0.3900-03	-0.1520-02	0.1940-02	0.2460-02	0.177
10.0	0.410	-104.	0.7530-03	-0.4050-04	-0.3440-03	0.1810-02	0.1840-02	0.132

TABLE IV

RUN IC 11-01

CONTD.

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
11.0	0.112	135.	-0.143D-03	-0.529D-04	0.576D-03	0.123D-02	0.136D-02	0.976D-01
21.0	0.262	72.3	0.948D-04	-0.251D-03	-0.802D-03	-0.636D-03	0.102D-02	0.736D-01
31.0	0.141	-152.	0.478D-04	-0.226D-04	-0.192D-03	0.285D-03	0.343D-03	0.247D-01
41.0	0.344	62.4	0.219D-04	-0.309D-04	-0.708D-04	-0.109D-03	0.130D-03	0.931D-02
51.0	0.943	-38.5	-0.543D-04	-0.759D-04	0.499D-05	-0.988D-04	0.989D-04	0.711D-02
61.0	0.209	152.	-0.639D-05	-0.791D-05	0.929D-05	0.478D-04	0.487D-04	0.350D-02
71.0	0.234	64.0	0.113D-04	-0.146D-04	-0.570D-04	-0.545D-04	0.788D-04	0.566D-02
81.0	0.239	-143.	0.131D-04	-0.273D-05	-0.368D-04	0.421D-04	0.559D-04	0.402D-02
91.0	0.321	69.7	0.638D-05	-0.610D-05	-0.109D-04	-0.252D-04	0.275D-04	0.197D-02
101.	1.02	-23.6	0.424D-06	-0.141D-04	0.591D-05	-0.125D-04	0.138D-04	0.994D-03

TABLE IV  
CONT'D.  
RUN ID H-01

12/27/68

COMMENTS HE TRACER BED IN AIR RATE 6.3 CM

DEAD TIME= 0.650 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES		OUTPUT PULSE		INPUT REAL	INPUT IMAGINARY	INPUT FREQ NORMALIZED	CONTENT	
				REAL	IMAGINARY				NORMALIZED	ACTUAL
0.0000-00	1.17	0.0000	00	84.0	0.0000	00	0.0000	00	1.00	71.8
0.1000-01	1.00	-0.693		0.999	-0.4550	-01	-0.3340	-01	1.00	71.8
0.2000-01	1.00	-1.39		0.995	-0.9080	-01	-0.6670	-01	0.998	71.7
0.3000-01	1.00	-2.08		0.988	-0.136		-0.9950	-01	0.996	71.5
0.4000-01	1.00	-2.79		0.978	-0.180		-0.132		0.993	71.3
0.5000-01	1.00	-3.49		0.966	-0.223		-0.163		0.989	71.0
0.6000-01	1.00	-4.21		0.952	-0.265		-0.194		0.984	70.7
0.7000-01	1.01	-4.93		0.935	-0.307		-0.224		0.978	70.3
0.8000-01	1.01	-5.66		0.916	-0.346		-0.252		0.972	69.8
0.9000-01	1.01	-6.41		0.895	-0.384		-0.280		0.965	69.3
0.100	1.01	-7.17		0.872	-0.421		-0.305		0.958	68.8
0.200	1.03	-15.5		0.574	-0.680		-0.485		0.861	61.9
0.300	1.04	-25.0		0.252	-0.759		-0.557		0.767	55.1
0.400	1.03	-34.6		-0.2560	-0.713		-0.583		0.691	49.6
0.500	1.02	-43.9		-0.233	-0.585		-0.573		0.619	44.5
0.600	0.992	-53.5		-0.353	-0.417		-0.536		0.551	39.6
0.700	0.956	-62.7		-0.397	-0.255		-0.447		0.494	35.5
0.800	0.918	-71.7		-0.393	-0.116		-0.447		0.447	32.1
0.900	0.875	-80.6		-0.355	-0.3520	-02	-0.401		0.405	29.1
1.00	0.825	-89.1		-0.294	0.7630	-01	-0.355		0.369	26.5
2.00	0.388	-157.		0.4010	0.4170	-01	-0.5760	-01	0.149	10.7
3.00	0.223	174.		0.1410	-0.4310	-02	0.1250	-01	0.6610	4.75
4.00	0.257	146.		0.2510	-0.7030	-02	0.1720	-01	0.2900	2.09
5.00	0.267	90.0		-0.2780	-0.2820	-02	0.8570	-02	0.1360	0.979
6.00	0.149	4.93		-0.7940	0.1010	-02	0.7160	-02	0.8580	0.616
7.00	0.435	-158.		0.1470	-0.1010	-02	0.2240	-02	0.4090	0.294
8.00	0.546	74.8		-0.1470	-0.4690	-03	0.2370	-02	0.2830	0.203
9.00	0.401	-29.5		-0.1500	0.9780	-03	0.1940	-02	0.2460	0.177
10.0	0.410	-117.		0.7250	-0.2070	-03	0.1810	-02	0.1840	0.132

TABLE IV

RUN ID H-01

CONTD.

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
			OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY				
11.0	0.112	85.7	-0.1330-03	0.7480-04	0.5780-03	0.1230-02	0.1360-02	0.9780-01
21.0	0.262	10.2	-0.1770-03	-0.2010-03	-0.8020-03	-0.6360-03	0.1020-02	0.7360-01
31.0	0.141	134.	-0.1030-04	-0.4730-04	-0.1920-03	0.2850-03	0.3430-03	0.2470-01
41.0	0.344	-24.5	-0.3770-04	-0.2390-04	-0.7080-04	-0.1090-03	0.1300-03	0.9310-02
51.0	0.943	-138.	-0.6600-04	0.6590-04	0.4990-05	-0.9880-04	0.9890-04	0.7110-02
61.0	0.209	40.3	-0.4980-05	0.8670-05	0.9290-05	0.4780-04	0.4870-04	0.3500-02
71.0	0.234	-40.2	-0.1840-04	-0.1130-05	-0.5700-04	-0.5450-04	0.7880-04	0.5660-02
81.0	0.239	80.4	-0.1140-04	-0.7010-05	-0.3680-04	0.4210-04	0.5590-04	0.4020-02
91.0	0.321	-79.4	-0.8610-05	0.1950-05	-0.1090-04	-0.2520-04	0.2750-04	0.1970-02
101.	1.02	175.	-0.4900-05	0.1330-04	0.5910-05	-0.1250-04	0.1380-04	0.9940-03

TABLE V  
RUN ID H-02

COMMENTS HE TRACER BEH HT 7 3/8 IN AIR RATE 6.3 CM LINE APPROX 1/2/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
0.0000 00	1.39	0.0000 00	30.3	0.0000 00	21.7	0.0000 00	1.00	21.7
0.1000-01	1.00	-0.448	0.999	-0.3950-01	0.999	-0.3170-01	1.00	21.7
0.2000-01	1.00	-0.892	0.995	-0.7870-01	0.997	-0.6320-01	0.999	21.7
0.3000-01	0.999	-1.33	0.989	-0.117	0.992	-0.9450-01	0.997	21.7
0.4000-01	0.998	-1.76	0.980	-0.155	0.986	-0.125	0.994	21.6
0.5000-01	0.997	-2.18	0.969	-0.197	0.979	-0.156	0.991	21.5
0.6000-01	0.996	-2.59	0.956	-0.228	0.969	-0.185	0.987	21.4
0.7000-01	0.995	-2.98	0.942	-0.262	0.959	-0.214	0.982	21.3
0.8000-01	0.994	-3.36	0.925	-0.295	0.947	-0.242	0.977	21.2
0.9000-01	0.993	-3.72	0.907	-0.326	0.933	-0.269	0.971	21.1
0.100	0.992	-4.07	0.888	-0.356	0.919	-0.294	0.965	21.0
0.200	0.995	-7.24	0.665	-0.570	0.735	-0.484	0.860	19.1
0.300	1.01	-11.8	0.474	-0.678	0.546	-0.568	0.788	17.1
0.400	1.00	-17.4	0.191	-0.687	0.386	-0.596	0.710	15.4
0.500	0.982	-22.0	0.7780-02	-0.628	0.247	-0.590	0.639	13.9
0.600	0.963	-26.5	-0.124	-0.537	0.133	-0.557	0.572	12.4
0.700	0.940	-31.0	-0.209	-0.436	0.4870-01	-0.512	0.515	11.2
0.800	0.913	-35.6	-0.260	-0.337	-0.1700-01	-0.466	0.467	10.1
0.900	0.883	-40.0	-0.294	-0.244	-0.6860-01	-0.418	0.424	9.21
1.00	0.852	-44.7	-0.297	-0.161	-0.107	-0.371	0.386	8.39
2.00	0.470	-73.2	-0.4160-01	0.6000-01	-0.148	-0.4790-01	0.156	3.38
3.00	0.244	-76.9	0.9510-03	0.1510-01	-0.5930-01	0.1780-01	0.6200-01	1.35
4.00	0.225	-81.6	0.3280-02	0.5610-02	-0.2260-01	0.1810-01	0.2890-01	0.628
5.00	0.149	-171.	0.1380-02	-0.1610-02	-0.7370-02	0.1220-01	0.1420-01	0.310
6.00	0.8510-01	82.9	-0.4900-03	-0.2710-03	-0.3880-02	0.5320-02	0.6580-02	0.143
7.00	0.533	109.	-0.1760-02	-0.1520-02	-0.1630-02	0.4040-02	0.4360-02	0.9470-01
8.00	0.493	46.5	-0.1750-02	0.8410-03	-0.2350-03	0.2730-02	0.2740-02	0.5950-01
9.00	0.932	29.2	-0.5040-03	0.1010-02	0.5610-04	0.1210-02	0.1210-02	0.2630-01
10.0	1.65	-55.9	0.7600-04	0.6150-03	-0.2960-03	0.2320-03	0.3760-03	0.8170-02

TABLE V

R:IN 10 H-02

CONTD.

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
			REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
11.0	1.14	-83.7	0.1050-04	0.4770-03	-0.4140-03	0.5480-04	0.4170-03	0.9070-02
21.0	0.267	82.4	0.1460-03	-0.2300-03	-0.7810-03	-0.6560-03	0.1020-02	0.2220-01
31.0	0.147	104.	-0.2510-04	-0.2680-04	-0.1340-03	0.2120-03	0.2510-03	0.5450-02
41.0	1.68	-39.3	-0.2240-04	-0.6210-04	0.1310-04	-0.3700-04	0.3920-04	0.8530-03
51.0	0.931	-32.6	-0.4770-04	-0.8330-04	0.5030-05	-0.1030-03	0.1030-03	0.2240-02
61.0	0.814	-13.4	-0.1100-04	0.3110-05	-0.1400-04	0.5850-06	0.1400-04	0.3050-03
71.0	0.312	114.	0.2530-04	-0.9760-05	-0.6200-04	-0.6090-04	0.8690-04	0.1890-02
81.0	0.149	141.	-0.9430-06	-0.5990-05	-0.2030-04	0.3530-04	0.4070-04	0.8840-03
91.0	2.48	3.59	0.1360-05	-0.1170-04	0.2510-06	-0.4730-05	0.4730-05	0.1030-03
101.	0.988	-20.6	0.1260-05	-0.1400-04	0.6200-05	-0.1280-04	0.1430-04	0.3100-03

TABLE V CONTD.

RUN ID H-02

COMMENTS HE TRACER BED HT 7 3/8 IN AIR RATE 6.3 CM LINE APPROX

1/2/69

DEAD TIME 0.550 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
			REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
0.000D 00	1.39	0.000D 00	30.3	0.000D 00	21.7	0.000D 00	1.00	21.7
0.100D-01	1.00	-0.763	0.998	-0.450D-01	0.999	-0.317D-01	1.00	21.7
0.200D-01	1.00	-1.52	0.994	-0.897D-01	0.997	-0.632D-01	0.999	21.7
0.300D-01	0.999	-2.28	0.987	-0.134	0.992	-0.945D-01	0.997	21.7
0.400D-01	0.998	-3.02	0.976	-0.177	0.986	-0.125	0.994	21.6
0.500D-01	0.997	-3.76	0.964	-0.219	0.979	-0.156	0.991	21.5
0.600D-01	0.996	-4.48	0.948	-0.259	0.969	-0.185	0.987	21.4
0.700D-01	0.995	-5.19	0.931	-0.298	0.959	-0.214	0.982	21.3
0.800D-01	0.994	-5.88	0.911	-0.335	0.947	-0.242	0.977	21.2
0.900D-01	0.993	-6.56	0.890	-0.371	0.933	-0.269	0.971	21.1
0.100	0.992	-7.22	0.867	-0.404	0.919	-0.294	0.965	21.0
0.200	0.995	-13.5	0.598	-0.640	0.735	-0.484	0.880	19.1
0.300	1.01	-21.3	0.307	-0.738	0.546	-0.568	0.788	17.1
0.400	1.00	-30.0	0.364D-01	-0.712	0.386	-0.596	0.710	15.4
0.500	0.982	-37.7	-0.163	-0.606	0.247	-0.590	0.639	13.9
0.600	0.963	-45.4	-0.291	-0.468	0.133	-0.557	0.572	12.4
0.700	0.940	-53.1	-0.357	-0.326	0.487D-01	-0.512	0.515	11.2
0.800	0.913	-60.8	-0.379	-0.194	-0.170D-01	-0.466	0.467	10.1
0.900	0.883	-68.4	-0.366	-0.799D-01	-0.686D-01	-0.418	0.424	9.21
1.00	0.852	-76.2	-0.329	0.130D-01	-0.107	-0.371	0.386	8.39
2.00	0.470	-136.	0.346D-01	0.643D-01	-0.148	-0.479D-01	0.156	3.38
3.00	0.244	-171.	0.150D-01	-0.214D-02	-0.593D-01	0.178D-01	0.620D-01	1.35
4.00	0.225	152.	0.261D-02	-0.596D-02	-0.226D-01	0.181D-01	0.289D-01	0.628
5.00	0.149	31.8	-0.149D-02	0.965D-03	-0.737D-02	0.122D-01	0.142D-01	0.310
6.00	0.851D-01	-106.	0.526D-03	0.191D-03	-0.388D-02	0.532D-02	0.658D-02	0.143
7.00	0.533	-112.	0.233D-02	0.512D-05	-0.163D-02	0.405D-02	0.436D-02	0.947D-01
8.00	0.493	154.	-0.476D-03	-0.126D-02	-0.235D-03	0.273D-02	0.274D-02	0.595D-01
9.00	0.932	106.	-0.110D-02	-0.252D-03	0.561D-04	0.121D-02	0.121D-02	0.263D-01
10.0	1.65	-14.1	-0.380D-03	0.469D-03	-0.296D-03	0.232D-03	0.376D-03	0.817D-02



TABLE V

RUN ID H-02

CONTD.

DEAD TIME = 0.550 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE PATID	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
			REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
11.0	1.14	-70.3	-0.999D-04	0.466D-03	-0.414D-03	0.548D-04	0.417D-03	0.907D-02
21.0	0.267	141.	0.272D-03	0.321D-05	-0.781D-03	-0.656D-03	0.102D-02	0.222D-01
31.0	0.147	-152.	0.318D-04	-0.184D-04	-0.134D-03	0.212D-03	0.251D-03	0.545D-02
41.0	1.68	109.	0.519D-04	0.408D-04	0.131D-04	-0.370D-04	0.392D-04	0.853D-03
51.0	0.931	160.	0.279D-04	0.918D-04	0.503D-05	-0.103D-03	0.103D-03	0.224D-02
61.0	0.814	-136.	0.850D-05	0.763D-05	-0.140D-04	0.585D-06	0.140D-04	0.305D-03
71.0	0.312	37.0	-0.402D-05	-0.268D-04	-0.620D-04	-0.609D-04	0.869D-04	0.189D-02
81.0	0.149	109.	-0.402D-05	-0.454D-05	-0.203D-04	0.353D-04	0.407D-04	0.884D-03
91.0	2.46	15.9	0.382D-05	-0.111D-04	0.251D-06	-0.473D-05	0.473D-05	0.103D-03
101.	0.988	36.6	0.125D-04	-0.654D-05	0.620D-05	-0.128D-04	0.143D-04	0.310D-03

TABLE VI

RUN ID H-03

COMMENTS HE TRACER BED HT 7 1/4 IN PACKED AIR FLOW 2.0 CM SAMPLE LOOP 1 LINE APP 1/6/69

DEAD TIME= .00000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSES REAL	OUTPUT PULSES IMAGINARY	INPUT PULSES REAL	INPUT PULSES IMAGINARY	INPUT FRFQ NORMALIZED	CONTENT ACTUAL
0.0000-00	0.981	0.0000 00	92.3	0.0000 00	94.1	0.0000 00	1.00	94.1
0.1000-01	1.00	-0.289	0.996	-0.6030-01	0.996	-0.5530-01	0.998	93.9
0.2000-01	0.999	-0.569	0.993	-0.119	0.993	-0.109	0.991	93.3
0.3000-01	0.998	-0.834	0.963	-0.173	0.967	-0.159	0.980	92.3
0.4000-01	0.996	-1.08	0.937	-0.222	0.944	-0.205	0.966	90.9
0.5000-01	0.994	-1.29	0.906	-0.265	0.917	-0.246	0.949	89.3
0.6000-01	0.993	-1.48	0.873	-0.301	0.897	-0.280	0.930	87.5
0.7000-01	0.991	-1.63	0.839	-0.331	0.856	-0.310	0.910	85.6
0.8000-01	0.989	-1.75	0.806	-0.355	0.825	-0.333	0.890	83.7
0.9000-01	0.988	-1.86	0.774	-0.374	0.795	-0.353	0.870	81.8
0.100	0.988	-1.95	0.744	-0.390	0.767	-0.369	0.851	80.1
0.200	0.993	-3.66	0.571	-0.496	0.555	-0.465	0.724	68.2
0.300	0.997	-5.61	0.345	-0.526	0.396	-0.493	0.633	59.5
0.400	0.984	-7.70	0.193	-0.526	0.266	-0.503	0.569	53.6
0.500	0.989	-9.53	0.7110-01	-0.501	0.155	-0.487	0.511	48.1
0.600	0.975	-11.6	-0.2650-01	-0.452	0.6620-01	-0.459	0.464	43.7
0.700	0.970	-13.1	-0.101	-0.395	-0.8700-02	-0.420	0.420	39.5
0.800	0.968	-14.9	-0.155	-0.329	-0.6760-01	-0.370	0.376	35.4
0.900	0.960	-17.0	-0.187	-0.263	-0.106	-0.319	0.336	31.7
1.000	0.947	-19.0	-0.201	-0.204	-0.130	-0.273	0.303	28.5
2.000	0.852	-33.3	-0.8690-01	0.4550-01	-0.115	-0.1140-01	0.115	10.8
3.000	0.791	-48.3	-0.4880-02	0.3670-01	-0.3830-01	0.2590-01	0.4620-01	4.35
4.000	0.737	-61.3	0.9260-02	0.1270-01	-0.9080-02	0.1930-01	0.2130-01	2.01
5.000	0.661	-97.2	0.5610-02	-0.6270-05	-0.1050-02	0.8420-02	0.8490-02	0.799
6.000	0.525	-97.5	0.2400-02	-0.7600-03	0.8350-03	0.4730-02	0.4800-02	0.452
7.000	1.89	160.	-0.4820-03	-0.1840-02	-0.1010-03	0.1000-02	0.1010-02	0.9470-01
8.000	0.444	61.5	-0.6730-03	0.2310-03	-0.2650-03	0.1580-02	0.1600-02	0.151
9.000	0.664	33.9	-0.5710-03	0.5610-03	-0.2430-03	0.1180-02	0.1200-02	0.113
10.0	0.629	-29.1	0.5070-03	0.6430-03	0.2070-03	0.1290-02	0.1300-02	0.123

TABLE VI

RUN ID H-03

CONTD.

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FRQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
11.0	0.257	-2.79	0.2560-03	0.1670-03	0.9630-03	0.6950-03	0.1190-02	0.112
21.0	0.761	63.6	0.3750-03	-0.4010-03	-0.2530-03	-0.6760-03	0.7220-03	0.6790-01
31.0	0.472	-93.7	0.8900-04	-0.1440-04	0.1830-04	0.1900-03	0.1910-03	0.1800-01
41.0	0.705	-2.84	-0.1200-04	-0.4310-04	-0.1400-04	-0.6190-04	0.6350-04	0.5970-02
51.0	0.968	-13.7	-0.2550-04	-0.7740-04	-0.6610-05	-0.8390-04	0.8410-04	0.7970-02
61.0	0.242	-31.5	0.8750-05	0.3340-05	0.2360-04	0.3060-04	0.3860-04	0.3630-02
71.0	0.795	74.4	0.3750-04	-0.2230-04	-0.1440-04	-0.5300-04	0.5490-04	0.5170-02
81.0	0.402	-99.8	0.1180-04	-0.1190-05	-0.2100-05	0.2950-04	0.2950-04	0.2780-02
91.0	0.562	1.89	-0.1220-06	-0.8260-05	-0.7000-06	-0.1470-04	0.1470-04	0.1380-02
101.	0.988	-8.73	0.2330-05	-0.1100-04	0.4030-05	-0.1070-04	0.1140-04	0.1070-02

TABLE VI CONTD.

RUN ID H-03

COMMENTS HE TRACER BED HT 7 1/4 IN PACKED AIR FLJW 2.0 CM SAMPLE LOOP 1 LINE APP 1/6/69

DEAD TIME= 2.06 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FRFQ CONTENT NORMALIZED	CONTENT ACTUAL
0.0000-00	0.981	0.0000 00	92.3	0.0000 00	94.1	0.0000 00	1.00	94.1
0.1000-01	1.00	-1.47	0.994	-0.8090-01	0.996	-0.5530-01	0.998	93.9
0.2000-01	0.999	-2.93	0.977	-0.159	0.985	-0.109	0.991	93.3
0.3000-01	0.998	-4.38	0.950	-0.232	0.967	-0.159	0.980	92.3
0.4000-01	0.996	-5.80	0.915	-0.298	0.944	-0.205	0.966	90.9
0.5000-01	0.994	-7.19	0.874	-0.357	0.917	-0.246	0.949	89.3
0.6000-01	0.993	-8.56	0.829	-0.406	0.887	-0.280	0.930	87.5
0.7000-01	0.991	-9.89	0.783	-0.448	0.856	-0.310	0.910	85.6
0.8000-01	0.989	-11.2	0.736	-0.487	0.825	-0.333	0.890	83.7
0.9000-01	0.988	-12.5	0.692	-0.510	0.795	-0.353	0.870	81.8
0.100	0.988	-13.8	0.649	-0.534	0.767	-0.369	0.851	80.1
0.200	0.993	-17.3	0.279	-0.663	0.555	-0.465	0.724	68.2
0.300	0.997	-41.0	-0.2500-01	-0.630	0.396	-0.493	0.633	59.5
0.400	0.984	-54.9	-0.255	-0.499	0.266	-0.503	0.569	53.6
0.500	0.989	-68.5	-0.392	-0.319	0.155	-0.487	0.511	48.1
0.600	0.975	-82.4	-0.435	-0.123	0.6620-01	-0.459	0.464	43.7
0.700	0.970	-95.8	-0.404	0.4930-01	-0.8700-02	-0.420	0.420	39.5
0.800	0.968	-109.	-0.316	0.180	-0.6760-01	-0.370	0.376	35.4
0.900	0.960	-123.	-0.200	0.253	-0.106	-0.319	0.336	31.7
1.00	0.947	-137.	-0.8000-01	0.273	-0.130	-0.273	0.303	28.5
2.00	0.852	90.6	0.1080-01	-0.9750-01	-0.115	-0.1140-01	0.115	10.8
3.00	0.791	-42.4	-0.8590-02	0.3550-01	-0.3830-01	0.7590-01	0.4620-01	4.35
4.00	0.737	-173.	0.8770-02	-0.1340-01	-0.9080-02	0.1930-01	0.2130-01	2.01
5.00	0.661	32.7	-0.3590-02	0.4310-02	-0.1050-02	0.8420-02	0.8490-02	0.799
6.00	0.525	-85.7	0.2510-02	-0.2520-03	0.8350-03	0.4730-02	0.4800-02	0.452
7.00	1.89	53.3	-0.1630-02	0.9750-03	-0.1010-03	0.1000-02	0.1010-02	0.9470-01
8.00	0.444	-163.	0.3210-03	-0.6350-03	-0.2650-03	0.1580-02	0.1600-02	0.151
9.00	0.664	51.6	-0.7150-03	0.3600-03	-0.2430-03	0.1180-02	0.1200-02	0.113
10.0	0.629	-129.	0.5420-03	-0.6140-03	0.2070-03	0.1290-02	0.1300-02	0.123

TABLE VI

RUN ID H-03

CONTD.

DEAD TIME= 2.06 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
11.0	0.257	139.	-0.3040-03	0.2830-04	0.9630-03	0.6950-03	0.1190-02	0.112
21.0	0.761	105.	0.5460-03	-0.5340-04	-0.2530-03	-0.6760-03	0.7220-03	0.6790-01
31.0	0.472	-153.	0.3370-04	-0.8370-04	0.1830-04	0.1900-03	0.1910-03	0.1800-01
41.0	0.705	-162.	-0.4020-05	0.4450-04	-0.1400-04	-0.6190-04	0.6350-04	0.5970-02
51.0	0.968	86.8	0.8070-04	-0.1090-04	-0.6610-05	-0.8390-04	0.8410-04	0.7920-02
61.0	0.242	-31.2	0.8730-05	0.3370-05	0.2360-04	0.3060-04	0.3860-04	0.3630-02
71.0	0.795	-25.7	-0.2860-04	-0.3300-04	-0.1440-04	-0.5300-04	0.5490-04	0.5170-02
81.0	0.402	59.8	-0.1070-04	0.5230-05	-0.2100-05	0.2950-04	0.2950-04	0.2780-02
91.0	0.562	61.2	0.7040-05	-0.4320-05	-0.7000-06	-0.1470-04	0.1470-04	0.1380-07
101.	0.988	-49.7	-0.5470-05	-0.9860-05	0.4030-05	-0.1070-04	0.1140-04	0.1070-02

TABLE VII

RUN ID H-04

COMMENTS HE TRACER BED HT 7 1/4 IN PACKED AIR FLOW 2.0 CM SMP LOOP 1 LIVE APP 1/6/69

DEAD TIME: 0.000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE PATIO	PHASE ANGLE DFGREFS	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT REAL	INPUT PULSE IMAGINARY	INPUT FRFQ CONTENT NORMALIZED	ACTUAL
0.000-00	0.974	0.000 00	92.4	0.000 00	94.9	0.000 00	1.00	94.9
0.100-01	1.00	-0.166	0.997	-0.550-01	0.997	-0.521-01	0.998	94.7
0.200-01	1.00	-0.334	0.996	-0.109	0.947	-0.103	0.992	94.1
0.300-01	1.00	-0.508	0.970	-0.159	0.971	-0.151	0.983	93.2
0.400-01	1.00	-0.688	0.949	-0.206	0.950	-0.195	0.970	92.0
0.500-01	1.00	-0.875	0.923	-0.249	0.926	-0.234	0.955	90.6
0.600-01	1.00	-1.07	0.894	-0.286	0.896	-0.269	0.938	89.0
0.700-01	1.00	-1.27	0.864	-0.318	0.870	-0.298	0.919	87.2
0.800-01	1.00	-1.48	0.834	-0.345	0.841	-0.323	0.901	85.4
0.900-01	1.00	-1.69	0.803	-0.368	0.813	-0.343	0.882	83.7
0.100	1.00	-1.90	0.774	-0.387	0.786	-0.360	0.864	82.0
0.200	0.999	-3.45	0.551	-0.503	0.581	-0.469	0.746	70.8
0.300	1.01	-5.51	0.364	-0.546	0.410	-0.503	0.649	61.5
0.400	1.00	-8.27	0.206	-0.550	0.282	-0.513	0.586	55.4
0.500	1.00	-9.59	0.794-01	-0.523	0.165	-0.502	0.528	50.1
0.600	0.995	-12.3	-0.200-01	-0.471	0.753-01	-0.469	0.475	45.0
0.700	0.991	-14.3	-0.106	-0.411	-0.579-03	-0.429	0.429	40.7
0.800	0.973	-16.2	-0.158	-0.343	-0.572-01	-0.384	0.389	36.9
0.900	0.967	-18.1	-0.193	-0.277	-0.101	-0.334	0.349	33.1
1.00	0.958	-19.8	-0.208	-0.216	-0.120	-0.286	0.313	29.7
2.00	0.856	-35.4	-0.919-01	0.475-01	-0.120	-0.168-01	0.121	11.5
3.00	0.756	-51.1	-0.604-02	0.374-01	-0.436-01	0.249-01	0.502-01	4.76
4.00	0.677	-65.5	0.954-02	0.130-01	-0.117-01	0.208-01	0.238-01	2.26
5.00	0.577	-94.2	0.592-02	0.844-03	-0.227-02	0.995-02	0.102-01	0.968
6.00	0.449	-96.4	0.247-02	-0.420-03	0.315-03	0.557-02	0.558-02	0.530
7.00	0.661	170.	-0.473-03	-0.188-03	0.150-03	0.225-02	0.275-02	0.214
8.00	0.380	52.3	-0.677-03	0.717-03	0.406-03	0.256-02	0.259-02	0.246
9.00	1.14	43.0	-0.436-03	0.825-03	0.214-03	0.790-03	0.818-03	0.774-01
10.0	0.756	-0.475-01	0.155-04	0.929-03	0.234-04	0.123-02	0.123-02	0.117

TABLE VII

RUN ID U-04

CONTD.

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	DEAD TIME= 0.0000 00 PULSES NORMALIZED		OUTPUT PULSE		INPUT PULSE		INPUT FRFQ CONTENT	
			REAL	IMAGINARY	REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
11.0	0.620	36.5	0.2900-03	0.6190-03	0.9700-03	0.5240-03	0.1100-02	0.105		
21.0	0.678	67.4	0.3790-03	-0.4100-03	-0.3430-03	-0.7470-03	0.8220-03	0.7800-01		
31.0	0.407	-94.1	0.8710-04	-0.8660-05	0.5730-05	0.2150-03	0.2040-01			
41.0	0.671	-15.4	-0.3930-05	-0.3020-04	0.6340-05	-0.4500-04	0.4540-04	0.4310-02		
51.0	0.985	-15.2	-0.2630-04	-0.8030-04	-0.4380-05	-0.8570-04	0.8580-04	0.8140-02		
61.0	0.405	27.3	0.6190-05	0.1580-04	0.3150-04	0.2760-04	0.4180-04	0.3970-02		
71.0	0.666	75.9	0.3540-04	-0.2320-04	-0.2900-04	-0.5990-04	0.6340-04	0.6070-02		
81.0	0.377	-100.	0.1310-04	-0.1940-05	-0.1270-05	0.3510-04	0.3510-04	0.3330-02		
91.0	0.649	-27.0	-0.2970-05	-0.5270-05	-0.3940-06	-0.9310-05	0.9320-05	0.8840-03		
101.	0.996	-9.07	0.2520-05	-0.1150-04	0.4320-05	-0.1100-04	0.1180-04	0.1170-02		

TABLE VII CONTD.

RUN ID H-04

COMMENTS HE TRACER BED HT 7 1/4 IN PACKED AIR FLOW 2.0 CM SMP LOOP 1 LINE APP 1/6/69

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			RFAL	IMAGINARY	RFAL	IMAGINARY		
0.0000-00	0.974	0.0000-00	92.4	0.0000-00	94.9	0.0000-00	1.00	94.9
0.1000-01	1.00	-1.35	0.995	-0.7550-01	0.997	-0.5210-01	0.998	94.7
0.2000-01	1.00	-2.69	0.981	-0.149	0.987	-0.103	0.992	94.1
0.3000-01	1.00	-4.05	0.958	-0.219	0.971	-0.151	0.983	93.2
0.4000-01	1.00	-5.41	0.926	-0.284	0.950	-0.195	0.970	92.0
0.5000-01	1.00	-6.78	0.892	-0.342	0.926	-0.234	0.955	90.6
0.6000-01	1.00	-8.15	0.852	-0.394	0.898	-0.269	0.938	89.0
0.7000-01	1.00	-9.54	0.810	-0.439	0.870	-0.298	0.919	87.2
0.8000-01	1.00	-10.9	0.766	-0.477	0.841	-0.323	0.901	85.4
0.9000-01	1.00	-12.3	0.722	-0.509	0.813	-0.343	0.882	83.7
0.100	1.00	-13.7	0.679	-0.537	0.786	-0.360	0.864	82.0
0.200	0.999	-27.1	0.303	-0.681	0.581	-0.469	0.746	70.8
0.300	1.01	-40.9	-0.1960-01	-0.636	0.410	-0.503	0.649	61.5
0.400	1.00	-55.5	-0.264	-0.525	0.282	-0.513	0.586	55.6
0.500	1.00	-68.6	-0.407	-0.337	0.165	-0.502	0.528	50.1
0.600	0.995	-83.1	-0.454	-0.130	0.7530-01	-0.469	0.475	45.0
0.700	0.991	-96.9	-0.421	0.5180-01	-0.5790-03	-0.429	0.429	40.7
0.800	0.973	-111.	-0.330	0.184	-0.5720-01	-0.384	0.389	36.9
0.900	0.967	-124.	-0.212	0.263	-0.101	-0.334	0.349	33.1
1.00	0.958	-138.	-0.9270-01	0.266	-0.128	-0.286	0.313	29.7
2.00	0.856	88.6	0.1190-01	-0.103	-0.120	-0.1680-01	0.121	11.5
3.00	0.756	-45.2	-0.9870-02	0.3660-01	-0.4360-01	0.2490-01	0.5020-01	4.76
4.00	0.677	-178.	0.8480-02	-0.1370-01	-0.1170-01	0.2080-01	0.2380-01	2.26
5.00	0.577	35.7	-0.4410-02	0.3900-02	-0.2270-02	0.9950-02	0.1020-01	0.968
6.00	0.449	-84.6	0.2510-02	0.9580-04	0.3150-03	0.5570-02	0.5580-02	0.530
7.00	0.861	63.5	-0.1670-02	0.9790-03	0.1500-03	0.2250-02	0.2250-02	0.214
8.00	0.380	-172.	-0.1530-04	-0.9660-03	0.4000-03	0.2560-02	0.2590-02	0.246
9.00	1.14	60.8	-0.6470-03	0.6530-03	0.2140-03	0.7900-03	0.8180-03	0.7760-01
10.0	0.756	-100.	0.9110-03	-0.1640-03	0.2340-04	0.1230-02	0.1230-02	0.117



TABLE VII

RUN ID H-04

CONTD.

OMEGA RAD/SEC	DEAD TIME	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPT REAL	PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
				REAL	IMAGINARY				
11.0	2.06	0.620	178.	-0.612D-03	-0.306D-03	0.970D-03	0.524D-03	0.110D-02	0.105
21.0		0.678	109.	0.555D-03	-0.572D-04	-0.343D-03	-0.747D-03	0.822D-03	0.780D-01
31.0		0.407	-153.	0.376D-04	-0.791D-04	0.573D-05	0.215D-03	0.215D-03	0.204D-01
41.0		0.671	-175.	-0.706D-05	0.297D-04	0.634D-05	-0.450D-04	0.454D-04	0.431D-02
51.0		0.985	85.3	0.837D-04	-0.112D-04	-0.438D-05	-0.857D-04	0.858D-04	0.814D-02
61.0		0.405	27.5	0.614D-05	0.158D-04	0.315D-04	0.276D-04	0.418D-04	0.397D-02
71.0		0.666	-24.2	-0.290D-04	-0.308D-04	-0.208D-04	-0.599D-04	0.634D-04	0.602D-02
81.0		0.377	59.1	-0.116D-04	0.639D-05	-0.127D-05	0.351D-04	0.351D-04	0.333D-02
91.0		0.649	37.3	0.372D-05	-0.525D-05	-0.394D-06	-0.931D-05	0.932D-05	0.884D-03
101.		0.996	-50.0	-0.562D-05	-0.103D-04	0.432D-05	-0.110D-04	0.118D-04	0.112D-02

TABLE VIII

RUN ID H-05

COMMENTS HE TRACER BED HT 7 1/4 IN PACKED AIR FLOW 2.0 CM SMP LOOP 2 LINE APP 1/6/69

DEAD TIME = 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT REAL	OUTPUT IMAGINARY	INPUT REAL	INPUT IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
0.0000-00	1.02	0.0000 00	23.5	0.0000 00	23.1	0.0000 00	1.00	23.1
0.1000-01	1.00	-0.256	0.997	-0.5300-01	0.997	-0.4930-01	0.998	23.0
0.2000-01	0.999	-0.504	0.997	-0.106	0.989	-0.9770-01	0.994	22.9
0.3000-01	0.998	-0.736	0.971	-0.156	0.975	-0.144	0.986	22.8
0.4000-01	0.996	-0.945	0.950	-0.203	0.957	-0.188	0.976	22.5
0.5000-01	0.994	-1.13	0.925	-0.245	0.935	-0.228	0.963	22.2
0.6000-01	0.992	-1.27	0.897	-0.282	0.910	-0.264	0.948	21.9
0.7000-01	0.990	-1.39	0.867	-0.314	0.883	-0.296	0.931	21.5
0.8000-01	0.989	-1.46	0.836	-0.341	0.854	-0.323	0.913	21.1
0.9000-01	0.988	-1.51	0.805	-0.364	0.824	-0.347	0.894	20.6
0.100	0.987	-1.54	0.775	-0.382	0.795	-0.366	0.875	20.2
0.200	1.00	-2.98	0.543	-0.481	0.584	-0.449	0.737	17.0
0.300	0.994	-4.81	0.381	-0.531	0.427	-0.501	0.658	15.2
0.400	1.01	-6.85	0.239	-0.541	0.300	-0.506	0.588	13.6
0.500	0.992	-8.64	0.108	-0.517	0.186	-0.499	0.532	12.3
0.600	0.990	-10.7	0.9770-02	-0.476	0.9820-01	-0.471	0.481	11.1
0.700	0.983	-12.0	-0.7140-01	-0.422	0.1760-01	-0.435	0.435	10.0
0.800	0.975	-14.2	-0.128	-0.358	-0.3690-01	-0.388	0.390	9.00
0.900	0.969	-15.4	-0.164	-0.298	-0.8160-01	-0.342	0.351	8.10
1.00	0.959	-17.4	-0.184	-0.241	-0.108	-0.297	0.316	7.29
2.00	0.862	-31.1	-0.102	0.2700-01	-0.118	-0.3330-01	0.122	2.82
3.00	0.753	-42.9	-0.1700-01	0.3340-01	-0.4770-01	0.1640-01	0.5040-01	1.14
4.00	0.715	-53.3	0.3160-02	0.1530-01	-0.1450-01	0.1630-01	0.2190-01	0.505
5.00	0.530	-83.3	0.3480-02	0.3000-02	-0.4850-02	0.7170-02	0.8650-02	0.200
6.00	0.373	-96.0	0.1930-02	0.1040-02	-0.3290-02	0.4600-02	0.5650-02	0.130
7.00	0.583	119.	-0.6620-03	-0.9410-03	-0.8460-03	0.1780-02	0.1970-02	0.4550-01
8.00	0.613	13.2	-0.6530-03	0.5920-03	-0.8130-03	0.1190-02	0.1440-02	0.3320-01
9.00	0.444	10.7	-0.7160-03	0.1790-03	-0.1510-02	0.6960-03	0.1660-02	0.3840-01
10.0	0.671	-27.8	-0.1120-03	0.1110-02	-0.9190-03	0.1390-02	0.1660-02	0.3840-01

TABLE VIII

RUN ID H-05

CONTD.

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FRFQ		CONTENT	
			REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL		
11.0	1.23	-48.4	0.7500-03	0.6070-01	0.3570-04	0.7820-03	0.7830-03	0.1810-01		
21.0	0.716	57.8	0.1670-03	-0.5040-03	-0.4720-03	-0.5720-03	0.7420-03	0.1710-01		
31.0	0.372	-89.2	0.5980-04	0.5020-04	-0.1330-03	0.1600-03	0.2080-03	0.4800-02		
41.0	0.634	-0.448	-0.5250-04	-0.2550-04	-0.8240-04	-0.4090-04	0.9200-04	0.2170-02		
51.0	0.985	-12.7	-0.1950-04	-0.8300-04	-0.7720-06	-0.8660-04	0.8660-04	0.2000-02		
61.0	1.22	-33.1	0.1900-04	0.3030-04	-0.1220-05	0.2880-04	0.2880-04	0.6650-03		
71.0	0.716	66.7	0.2090-04	-0.3450-04	-0.3270-04	-0.4590-04	0.5640-04	0.1300-02		
81.0	0.342	-87.3	0.7050-05	0.6570-05	-0.1820-04	0.2150-04	0.2820-04	0.6510-03		
91.0	0.640	12.2	-0.9920-05	-0.1240-04	-0.1470-04	-0.1200-04	0.1900-04	0.4370-03		
101.	0.994	-8.33	0.3110-05	-0.1140-04	0.4700-05	-0.1090-04	0.1190-04	0.2740-03		

TABLE VIII CONTD.

RUN ID H-05

COMMENTS HE TRACER BED HT 7 1/4 IN PACKED AIK FLOW 2.0 CM S4P LOOP 2 LINE APP 1/4/69

DFAD TIME= 7.10 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSES REAL	OUTPUT PULSES IMAGINARY	INPUT PULSES REAL	INPUT PULSES IMAGINARY	INPUT PULSES NORMALIZED	INPUT FREQ CONTENT ACTUAL
0.0000-00	1.02	0.0000-00	23.5	0.0000-00	23.1	0.0000-00	1.00	23.1
0.1000-01	1.00	-1.46	0.995	-0.7470-01	0.997	-0.4930-01	0.996	23.0
0.2000-01	0.999	-2.91	0.992	-0.149	0.999	-0.9770-01	0.994	22.9
0.3000-01	0.998	-4.35	0.960	-0.217	0.975	-0.144	0.986	22.8
0.4000-01	0.996	-5.76	0.930	-0.282	0.957	-0.188	0.976	22.5
0.5000-01	0.994	-7.14	0.895	-0.340	0.935	-0.228	0.963	22.2
0.6000-01	0.992	-8.49	0.855	-0.393	0.910	-0.264	0.948	21.9
0.7000-01	0.990	-9.81	0.812	-0.438	0.883	-0.296	0.931	21.5
0.8000-01	0.989	-11.1	0.767	-0.476	0.854	-0.323	0.913	21.1
0.9000-01	0.988	-12.3	0.722	-0.508	0.824	-0.347	0.894	20.6
0.100	0.987	-13.6	0.678	-0.535	0.795	-0.366	0.875	20.2
0.200	1.00	-17.0	0.318	-0.669	0.584	-0.449	0.737	17.0
0.300	0.994	-40.9	-0.420-02	-0.654	0.427	-0.501	0.678	15.2
0.400	1.01	-55.0	-0.243	-0.540	0.300	-0.506	0.588	13.6
0.500	0.992	-68.8	-0.394	-0.351	0.186	-0.499	0.532	12.3
0.600	0.990	-82.9	-0.450	-0.154	0.9820-01	-0.471	0.481	11.1
0.700	0.983	-94.2	-0.427	0.2850-01	0.1760-01	-0.435	0.435	10.0
0.800	0.975	-110.	-0.342	0.166	-0.3690-01	-0.388	0.390	9.00
0.900	0.969	-124.	-0.232	0.249	-0.8160-01	-0.297	0.351	8.10
1.000	0.959	-138.	-0.115	0.280	-0.108	-0.297	0.316	7.20
2.000	0.862	68.3	0.2560-01	-0.107	-0.118	-0.3330-01	0.122	2.67
3.000	0.753	-43.9	-0.1730-01	0.3370-01	-0.4770-01	0.1640-01	0.5040-01	1.14
4.000	0.715	-175.	0.1140-01	-0.1070-01	-0.1450-01	0.1630-01	0.2190-01	0.505
5.000	0.530	35.1	-0.4290-02	0.1630-02	-0.4850-02	0.7170-02	0.8650-02	0.200
6.000	0.373	-98.0	0.1870-02	0.9790-03	-0.3290-02	0.4600-02	0.5650-02	0.130
7.000	0.583	-2.78	-0.4430-03	0.1660-02	-0.8460-03	0.1780-02	0.1970-02	0.4550-01
8.000	0.613	131.	-0.2750-03	-0.8530-03	-0.8180-03	0.1190-02	0.1440-02	0.3320-01
9.000	0.444	7.79	-0.7060-03	0.2150-03	-0.1510-02	0.6960-03	0.1660-02	0.3840-01
10.00	0.671	-151.	0.9000-03	-0.5150-03	-0.9190-03	0.1390-02	0.1560-02	0.3840-01

TABLE VIII

RUN ID 4-03

CONTD.

OMEGA RAD/SEC	DEAD TIME=	AMPLITUDE PATIO	PHASE ANGLE DFGREES	PULSES NORMALIZED				INPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT PULSE NORMALIZED	INPUT PULSE NORMALIZED	CONTENT ACTUAL
				OUTPUT PULS REAL	OUTPUT PULS IMAGINARY	INPUT PULS REAL	INPUT PULS IMAGINARY						
11.0	2.10	1.23	68.1	-0.8780-03	0.4000-03	0.3570-04	0.7820-03	0.7830-03	0.1810-01				
21.0		0.716	51.0	0.1060-03	-0.5200-03	-0.4720-03	-0.5720-03	0.7420-03	0.1710-01				
31.0		0.372	141.	0.6920-06	-0.7730-04	-0.1330-03	0.1600-03	0.2080-03	0.4800-02				
41.0		0.634	106.	0.3960-04	-0.4280-04	-0.8240-04	-0.4090-04	0.9200-04	0.2120-02				
51.0		0.985	-29.1	-0.4210-04	-0.7420-04	-0.7720-06	-0.8660-04	0.8660-04	0.2000-02				
61.0		1.22	-173.	0.5930-05	-0.3470-04	-0.1220-05	0.2880-04	0.2880-04	0.6050-03				
71.0		0.716	164.	0.3160-04	0.2510-04	-0.3270-04	-0.4590-04	0.5640-04	0.1300-02				
81.0		0.342	-113.	0.9220-05	0.2810-05	-0.1820-04	0.2150-04	0.2820-04	0.6510-03				
91.0		0.840	-137.	0.2160-05	0.1580-04	-0.1470-04	-0.1200-04	0.1900-04	0.4370-03				
101.		0.994	79.2	0.1150-04	0.2620-05	0.4760-05	-0.1090-04	0.1190-04	0.2740-03				

TABLE IX  
RUN ID H-06

COMMENTS HE TRACER BED HT 7 1/4 IN PACKED AIR FLOW 2.0 CM SMP LOOP 2 LINE APP 1/6/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	0.987	0.0000 00	23.3	0.0000 00	23.0	0.0000 00	1.00	23.6
0.1000-01	1.00	0.331	0.997	-0.5300-01	0.996	-0.5870-01	0.997	23.5
0.2000-01	1.00	0.638	0.988	-0.105	0.983	-0.115	0.989	23.3
0.3000-01	1.01	0.899	0.973	-0.154	0.962	-0.168	0.977	23.0
0.4000-01	1.01	1.09	0.953	-0.200	0.935	-0.215	0.959	22.6
0.5000-01	1.02	1.20	0.929	-0.242	0.903	-0.256	0.939	22.2
0.6000-01	1.03	1.19	0.902	-0.280	0.869	-0.289	0.916	21.6
0.7000-01	1.04	1.07	0.873	-0.312	0.833	-0.316	0.891	21.0
0.8000-01	1.05	0.822	0.843	-0.340	0.799	-0.336	0.860	20.4
0.9000-01	1.06	0.457	0.813	-0.364	0.766	-0.350	0.842	19.9
0.10	1.06	-0.1110-01	0.783	-0.384	0.736	-0.360	0.820	19.3
0.200	1.05	-3.51	0.564	-0.492	0.565	-0.434	0.712	16.8
0.300	1.07	-5.77	0.391	-0.546	0.406	-0.472	0.622	14.7
0.400	1.06	-7.71	0.226	-0.523	0.281	-0.489	0.564	13.3
0.500	1.06	-10.5	0.9430-01	-0.526	0.178	-0.473	0.506	11.9
0.600	1.05	-12.4	-0.8110-02	-0.479	0.9020-01	-0.445	0.454	10.7
0.700	1.05	-14.4	-0.8910-01	-0.427	0.1810-01	-0.412	0.413	9.74
0.800	1.04	-17.2	-0.144	-0.356	-0.3070-01	-0.368	0.370	8.72
0.900	1.03	-19.1	-0.182	-0.292	-0.7430-01	-0.326	0.334	7.89
1.00	1.01	-20.9	-0.199	-0.232	-0.103	-0.285	0.303	7.14
2.00	0.892	-38.5	-0.9760-01	0.4020-01	-0.114	-0.3290-01	0.118	2.79
3.00	0.815	-53.6	-0.1190-01	0.3640-01	-0.460-01	0.1480-01	0.4700-01	1.11
4.00	0.744	-72.7	0.7090-02	0.1360-01	-0.1470-01	0.1450-01	0.2060-01	0.487
5.00	0.499	-96.4	0.4010-02	0.2190-02	-0.5250-02	0.7500-02	0.9150-02	0.216
6.00	0.424	-115.	0.2010-02	0.4480-03	-0.2940-02	0.3870-02	0.4860-02	0.115
7.00	0.504	125.	-0.2490-03	-0.1410-02	-0.2000-02	0.2000-02	0.2830-02	0.6670-01
8.00	0.9810-01	4.39	-0.1330-03	0.1800-03	-0.1210-02	0.1930-02	0.2280-02	0.5380-01
9.00	0.434	9.00	-0.3470-03	0.7010-03	-0.5370-03	0.1720-02	0.1800-02	0.4250-01
10.0	0.302	-13.4	-0.6870-04	0.6260-03	-0.7550-03	0.1950-02	0.2090-02	0.4940-01

TABLE IX

RUN ID H-06

CONTD.

DEAD TIME = 0.0000 00. PULSES NORMALIZED		OUTPUT PULSE		INPUT PULSE		INPUT FRFQ		CONTENT	
OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	RFAL REAL	IFAL IMAGINARY	RFAL REAL	IFAL IMAGINARY	NORMALIZED	ACTUAL	ACTUAL
11.0	0.625	-30.7	0.616D-03	0.315D-03	0.590D-03	0.937D-03	0.111D-02	0.261D-01	
21.0	0.732	77.2	0.279D-03	-0.431D-03	-0.490D-03	-0.502D-03	0.701D-03	0.165D-01	
31.0	0.390	-116.	0.736D-04	0.127D-04	-0.111D-03	0.156D-03	0.192D-03	0.457D-02	
41.0	0.579	25.2	0.354D-05	-0.349D-04	-0.201D-04	-0.571D-04	0.605D-04	0.143D-02	
51.0	1.05	-15.2	-0.231D-04	-0.827D-04	-0.518D-06	-0.819D-04	0.819D-04	0.193D-02	
61.0	0.489	-26.3	0.134D-04	0.127D-04	0.136D-04	0.346D-04	0.372D-04	0.878D-03	
71.0	0.693	86.5	0.285D-04	-0.277D-04	-0.374D-04	-0.434D-04	0.573D-04	0.135D-02	
81.0	0.445	-116.	0.136D-04	0.264D-05	-0.186D-04	0.249D-04	0.311D-04	0.733D-03	
91.0	0.284	36.2	-0.502D-06	-0.423D-05	-0.102D-04	-0.110D-04	0.150D-04	0.354D-03	
101.	1.06	-9.70	0.224D-05	-0.116D-04	0.447D-05	-0.103D-04	0.112D-04	0.265D-03	

TABLE IX

RUN ID H-06

COMMENTS HE TRACER BED HT 7 1/4 IN PACKED AIR FLOW 2.0 CM SMP LOOP 2 LINE APP 1/6/69

DEAD TIME= 2.05 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE PATIO	PHASE ANGLE DFGREFS	OUTPUT PULSE RFAL	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FRFQ NORMALIZED	CONTENT ACTUAL
0.0000-00	0.987	0.0000 00	23.3	0.0000 00	0.0000 00	1.00	23.6
0.1000-01	1.00	-0.844	0.996	-0.7340-01	-0.5870-01	0.997	23.5
0.2000-01	1.00	-1.71	0.992	-0.145	-0.115	0.989	23.3
0.3000-01	1.01	-2.62	0.961	-0.214	-0.168	0.977	23.0
0.4000-01	1.01	-3.61	0.933	-0.278	-0.215	0.959	22.6
0.5000-01	1.02	-4.68	0.899	-0.336	-0.256	0.939	22.2
0.6000-01	1.03	-5.86	0.861	-0.388	-0.289	0.916	21.6
0.7000-01	1.04	-7.15	0.819	-0.434	-0.316	0.891	21.0
0.8000-01	1.05	-8.57	0.776	-0.473	-0.336	0.866	20.4
0.9000-01	1.06	-10.1	0.732	-0.507	-0.350	0.842	19.9
0.100	1.06	-11.8	0.689	-0.535	-0.360	0.820	19.3
0.200	1.05	-27.0	0.322	-0.676	-0.434	0.712	16.8
0.300	1.07	-41.0	-0.3860-02	-0.666	-0.472	0.622	14.7
0.400	1.06	-54.7	-0.250	-0.543	-0.489	0.564	13.3
0.500	1.06	-69.2	-0.401	-0.354	-0.473	0.506	11.9
0.600	1.05	-82.9	-0.454	-0.152	-0.445	0.454	10.7
0.700	1.05	-96.7	-0.430	0.3120-01	-0.412	0.413	9.74
0.800	1.04	-111.	-0.346	0.168	-0.368	0.370	8.72
0.900	1.03	-125.	-0.232	0.254	-0.326	0.334	7.89
1.00	1.01	-138.	-0.114	0.284	-0.285	0.303	7.16
2.00	0.892	86.6	0.2320-01	-0.103	-0.3290-01	0.118	2.79
3.00	0.815	-46.0	-0.1660-01	-0.4460-01	0.1480-01	0.4700-01	1.11
4.00	0.744	177.	0.1040-01	-0.1130-01	0.1450-01	0.2060-01	0.487
5.00	0.499	36.3	-0.4330-02	0.1460-02	0.7500-02	0.9150-02	0.214
6.00	0.424	-99.4	0.1830-02	0.9220-02	0.3870-02	0.4860-02	0.115
7.00	0.509	22.4	-0.1330-02	0.5510-03	0.2000-02	0.2830-02	0.6670-01
8.00	0.9810-01	145.	-0.1300-04	-0.2230-03	0.1930-02	0.2280-02	0.5380-01
9.00	0.434	31.9	-0.5920-03	0.5110-03	0.1720-02	0.1800-02	0.4250-01
10.0	0.302	-108.	0.6310-03	0.3860-04	0.1950-02	0.2090-02	0.4940-01



TABLE IX

RUN ID H-06

CONTD.

OMEGA RAD/SEC	DEAD TIME*	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FRQ NORMALIZED	CONTENT ACTUAL
			AMPLITUDE PATTN	ANGLE				
11.0	0.625	117.	-0.689D-03	0.597D-04	0.590D-03	0.937D-03	0.111D-02	0.261D-01
21.0	0.732	131.	0.512D-03	-0.329D-04	-0.490D-03	-0.502D-03	0.701D-03	0.165D-01
31.0	0.390	-157.	0.638D-04	-0.399D-04	-0.111D-03	0.156D-03	0.192D-03	0.457D-02
41.0	0.579	-111.	-0.269D-04	0.225D-04	-0.201D-04	-0.571D-04	0.605D-04	0.143D-02
51.0	1.05	114.	0.784D-04	0.351D-04	-0.518D-06	-0.819D-04	0.819D-04	0.193D-02
61.0	0.489	8.87	0.394D-05	0.177D-04	0.136D-04	0.346D-04	0.372D-04	0.878D-03
71.0	0.693	27.1	-0.939D-05	-0.366D-04	-0.374D-04	-0.434D-04	0.573D-04	0.135D-02
81.0	0.445	90.3	-0.110D-04	-0.832D-05	-0.186D-04	0.249D-04	0.311D-04	0.733D-03
91.0	0.284	148.	0.412D-05	0.108D-05	-0.102D-04	-0.110D-04	0.150D-04	0.354D-03
101.	1.06	7.20	0.608D-05	-0.103D-04	0.447D-05	-0.103D-04	0.112D-04	0.265D-03

JRTRAN \*\* STOP

TABLE X

RUN ID H-07

COMMENTS HE BED HT 7 1/4 IN FLUIDIZED AIR FLOW 5.0 CM SMP LOOP 2 LINE APP 1/9/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	REAL	IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
0.0000 00	1.13	0.0000 00	86.7	0.0000 00	76.7	0.0000 00	76.7	0.0000 00	1.00	76.7
0.1000-02	1.00	-0.2500-01	1.00	-0.4350-02	1.00	-0.3910-02	1.00	-0.3910-02	1.00	76.7
0.2000-02	1.00	-0.5000-01	1.00	-0.8700-02	1.00	-0.7830-02	1.00	-0.7830-02	1.00	76.7
0.3000-02	1.00	-0.7510-01	1.00	-0.1300-01	1.00	-0.1170-01	1.00	-0.1170-01	1.00	76.7
0.4000-02	1.00	-0.100	1.00	-0.1740-01	1.00	-0.1560-01	1.00	-0.1560-01	1.00	76.7
0.5000-02	1.00	-0.125	1.00	-0.2170-01	1.00	-0.1960-01	1.00	-0.1960-01	1.00	76.7
0.6000-02	1.00	-0.150	0.999	-0.2610-01	0.999	-0.2350-01	0.999	-0.2350-01	1.00	76.7
0.7000-02	1.00	-0.175	0.999	-0.3040-01	0.999	-0.2740-01	0.999	-0.2740-01	1.00	76.7
0.8000-02	1.00	-0.201	0.999	-0.3480-01	0.999	-0.3130-01	0.999	-0.3130-01	0.999	76.6
0.9000-02	1.00	-0.226	0.999	-0.3910-01	0.999	-0.3520-01	0.999	-0.3520-01	0.999	76.6
0.1000-01	1.00	-0.251	0.998	-0.4340-01	0.998	-0.3900-01	0.999	-0.3900-01	0.999	76.6
0.2000-01	1.00	-0.509	0.994	-0.8650-01	0.993	-0.7760-01	0.996	-0.7760-01	0.996	76.4
0.3000-01	1.00	-0.781	0.986	-0.129	0.985	-0.115	0.992	-0.115	0.992	76.1
0.4000-01	1.00	-1.07	0.975	-0.170	0.974	-0.151	0.985	-0.151	0.985	75.6
0.5000-01	1.01	-1.39	0.962	-0.210	0.960	-0.185	0.978	-0.185	0.978	75.0
0.6000-01	1.01	-1.73	0.946	-0.248	0.944	-0.217	0.968	-0.217	0.968	74.3
0.7000-01	1.01	-2.12	0.928	-0.285	0.926	-0.247	0.958	-0.247	0.958	73.5
0.8000-01	1.02	-2.53	0.909	-0.319	0.906	-0.274	0.947	-0.274	0.947	72.6
0.9000-01	1.02	-2.99	0.887	-0.352	0.886	-0.299	0.935	-0.299	0.935	71.7
0.100	1.02	-3.48	0.864	-0.382	0.865	-0.321	0.923	-0.321	0.923	70.8
0.200	1.03	-9.44	0.615	-0.581	0.681	-0.458	0.820	-0.458	0.820	62.9
0.300	1.02	-14.4	0.373	-0.671	0.518	-0.546	0.753	-0.546	0.753	57.7
0.400	1.01	-20.2	0.138	-0.670	0.357	-0.574	0.676	-0.574	0.676	51.8
0.500	0.980	-25.8	-0.4530-01	-0.596	0.223	-0.568	0.610	-0.568	0.610	46.8
0.600	0.950	-31.4	-0.173	-0.489	0.113	-0.534	0.546	-0.534	0.546	41.9
0.700	0.903	-37.0	-0.245	-0.369	0.2940-01	-0.490	0.491	-0.490	0.491	37.7
0.800	0.856	-42.3	-0.276	-0.260	-0.3370-01	-0.441	0.443	-0.441	0.443	33.9
0.900	0.793	-47.6	-0.275	-0.163	-0.8180-01	-0.394	0.403	-0.394	0.403	30.9
1.000	0.733	-51.7	-0.253	-0.8800-01	-0.119	-0.346	0.366	-0.346	0.366	28.1

TABLE X

RUN ID H-07

CONTD.

OMEGA RAD/SEC	DEAD TIME	AMPLITUDE PATTN	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE		INPUT FREY CONTENT	
				REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00	0.0000 00	0.202	-70.2	-0.1730-01	0.2410-01	-0.141	-0.3980-01	0.146	11.2
3.00		0.186	4.70	-0.1130-01	0.3520-02	-0.5910-01	0.2380-01	0.6370-01	4.89
4.00		0.216	-13.2	-0.2690-02	0.6100-02	-0.1860-01	0.2460-01	0.3080-01	2.36
5.00		0.134	54.5	-0.1550-02	0.7550-03	-0.2140-02	0.1270-01	0.1290-01	0.988
6.00		0.254	37.4	-0.1150-02	0.1430-02	-0.1900-03	0.7220-02	0.7220-02	0.554
7.00		0.409	158.	-0.1230-02	-0.6620-03	0.2160-02	0.2640-02	0.3410-02	0.262
8.00		1.76	57.5	-0.1110-02	0.1230-02	0.2500-03	0.9100-03	0.9430-03	0.7240-01
9.00		6.42	74.6	-0.8500-03	0.1570-02	0.1980-03	0.1910-03	0.2750-03	0.2110-01
10.0		0.621	-143.	0.2210-03	0.2240-03	-0.5020-03	-0.7060-04	0.5070-03	0.3690-01

TABLE X CONTD.

RUN ID H-07

COMMENTS HE BED HT 7 1/4 IN FLUIDIZED AIR FLOW 5.0 CM SMP LOOP 2 LINE APP 1/9/69

DEAD TIME= 0.480 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	INPUT FREQ CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000-00	1.13	0.0000-00	86.7	0.0000-00	76.7	0.0000-00	1.00	76.7
0.1000-02	1.00	-0.5250-01	1.00	-0.4830-02	1.00	-0.3910-02	1.00	76.7
0.2000-02	1.00	-0.105	1.00	-0.9660-02	1.00	-0.7830-02	1.00	76.7
0.3000-02	1.00	-0.158	1.00	-0.1450-01	1.00	-0.1170-01	1.00	76.7
0.4000-02	1.00	-0.210	1.00	-0.1930-01	1.00	-0.1560-01	1.00	76.7
0.5000-02	1.00	-0.263	1.00	-0.2410-01	1.00	-0.1960-01	1.00	76.7
0.6000-02	1.00	-0.315	0.999	-0.2900-01	0.999	-0.2350-01	1.00	76.7
0.7000-02	1.00	-0.368	0.999	-0.3380-01	0.999	-0.2740-01	1.00	76.7
0.8000-02	1.00	-0.421	0.999	-0.3860-01	0.999	-0.3130-01	0.999	76.6
0.9000-02	1.00	-0.473	0.999	-0.4340-01	0.999	-0.3520-01	0.999	76.6
0.1000-01	1.00	-0.526	0.998	-0.4820-01	0.998	-0.3900-01	0.999	76.6
0.2000-01	1.00	-1.06	0.993	-0.9600-01	0.993	-0.7760-01	0.996	76.4
0.3000-01	1.00	-1.61	0.984	-0.143	0.985	-0.115	0.992	76.1
0.4000-01	1.00	-2.17	0.972	-0.189	0.974	-0.151	0.985	75.6
0.5000-01	1.01	-2.76	0.957	-0.233	0.960	-0.185	0.978	75.0
0.6000-01	1.01	-3.38	0.939	-0.276	0.944	-0.217	0.968	74.3
0.7000-01	1.01	-4.04	0.918	-0.316	0.926	-0.247	0.958	73.5
0.8000-01	1.02	-4.73	0.896	-0.354	0.906	-0.274	0.947	72.6
0.9000-01	1.02	-5.46	0.871	-0.390	0.886	-0.299	0.935	71.7
0.100	1.02	-6.23	0.845	-0.423	0.865	-0.321	0.923	70.8
0.200	1.03	-14.9	0.557	-0.638	0.681	-0.458	0.820	62.9
0.300	1.02	-22.6	0.273	-0.718	0.518	-0.546	0.753	57.7
0.400	1.01	-31.2	0.7420-02	-0.684	0.357	-0.574	0.676	51.8
0.500	0.980	-39.6	-0.186	-0.568	0.223	-0.568	0.610	46.8
0.600	0.950	-47.9	-0.305	-0.420	0.113	-0.534	0.546	41.9
0.700	0.903	-56.3	-0.353	-0.268	0.2940-01	-0.490	0.491	37.7
0.800	0.856	-64.3	-0.353	-0.138	-0.3370-01	-0.441	0.443	33.9
0.900	0.793	-72.4	-0.318	-0.3280-01	-0.8180-01	-0.394	0.403	30.9
1.000	0.733	-79.2	-0.266	-0.3800-01	-0.119	-0.346	0.366	28.1

TABLE X

RUN ID H-07

CONTD.

OMEGA RAD/SEC	DEAD TIME = 0.480	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED				INPUT FREQ NORMALIZED	CONTENT ACTUAL
				OUTPUT REAL	OUTPUT IMAGINARY	INPUT REAL	INPUT IMAGINARY		
2.00		0.202	-125.	0.984D-02	0.280D-01	-0.141	-0.398D-01	0.146	11.2
3.00		0.186	-77.8	0.201D-02	0.117D-01	-0.591D-01	0.238D-01	0.637D-01	4.89
4.00		0.216	-123.	0.665D-02	0.443D-03	-0.186D-01	0.246D-01	0.308D-01	2.36
5.00		0.134	-83.1	0.165D-02	0.490D-03	-0.214D-02	0.127D-01	0.129D-01	0.988
6.00		0.254	-128.	0.148D-02	-0.108D-02	-0.190D-03	0.722D-02	0.722D-02	0.554
7.00		0.409	-35.0	0.134D-02	0.379D-03	0.216D-02	0.264D-02	0.341D-02	0.262
8.00		1.76	-162.	0.615D-04	-0.166D-02	0.250D-03	0.910D-03	0.943D-03	0.724D-01
9.00		6.49	-173.	-0.112D-02	-0.138D-02	0.198D-03	0.191D-03	0.275D-03	0.211D-01
10.0		0.621	-57.7	-0.204D-03	0.240D-03	-0.502D-03	-0.706D-04	0.507D-03	0.389D-01

TABLE XI

RUN ID H-08

COMMENTS HE PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 2 LINE APP 1/7/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
0.0000 00	0.886	0.0000 00	64.7	0.0000 00	73.0	0.0000 00	1.00	73.0
0.1000-02	1.00	0.1360-02	1.00	-0.3610-02	1.00	-0.3630-02	1.00	73.0
0.2000-02	1.00	0.2710-02	1.00	-0.7220-02	1.00	-0.7270-02	1.00	73.0
0.3000-02	1.00	0.4070-02	1.00	-0.1080-01	1.00	-0.1090-01	1.00	73.0
0.4000-02	1.00	0.5430-02	1.00	-0.1440-01	1.00	-0.1450-01	1.00	73.0
0.5000-02	1.00	0.6800-02	1.00	-0.1800-01	1.00	-0.1820-01	1.00	73.0
0.6000-02	1.00	0.8170-02	1.00	-0.2160-01	1.00	-0.2180-01	1.00	73.0
0.7000-02	1.00	0.9540-02	0.999	-0.2530-01	0.999	-0.2540-01	1.00	73.0
0.8000-02	1.00	0.1090-01	0.999	-0.2890-01	0.999	-0.2900-01	1.00	73.0
0.9000-02	1.00	0.1230-01	0.999	-0.3240-01	0.999	-0.3270-01	0.999	72.9
0.1000-01	1.00	0.1370-01	0.999	-0.3600-01	0.999	-0.3630-01	0.999	72.9
0.2000-01	1.00	0.2830-01	0.995	-0.7170-01	0.995	-0.7220-01	0.997	72.8
0.3000-01	1.00	0.4480-01	0.988	-0.107	0.988	-0.108	0.994	72.5
0.4000-01	1.00	0.6380-01	0.979	-0.141	0.979	-0.142	0.990	72.2
0.5000-01	1.00	0.8620-01	0.968	-0.174	0.968	-0.175	0.984	71.8
0.6000-01	0.999	0.112	0.955	-0.205	0.955	-0.207	0.977	71.3
0.7000-01	0.999	0.143	0.940	-0.235	0.940	-0.237	0.970	70.8
0.8000-01	0.999	0.178	0.924	-0.262	0.924	-0.265	0.961	70.1
0.9000-01	0.999	0.218	0.906	-0.288	0.906	-0.292	0.952	69.5
0.100	0.999	0.262	0.888	-0.312	0.887	-0.317	0.942	68.7
0.200	1.01	0.709	0.702	-0.470	0.691	-0.475	0.839	61.2
0.300	1.02	0.497	0.536	-0.562	0.520	-0.555	0.760	55.5
0.400	1.03	0.3990-01	0.367	-0.600	0.357	-0.583	0.684	49.9
0.500	1.04	-0.432	0.226	-0.594	0.223	-0.572	0.614	44.8
0.600	1.04	-1.09	0.106	-0.564	0.112	-0.541	0.552	40.3
0.700	1.04	-1.63	0.1290-01	-0.514	0.2640-01	-0.494	0.495	36.1
0.800	1.04	-2.18	-0.5660-01	-0.460	-0.3750-01	-0.444	0.446	32.6
0.900	1.04	-2.72	-0.108	-0.404	-0.6570-01	-0.393	0.403	29.4
1.00	1.04	-3.29	-0.145	-0.349	-0.120	-0.344	0.364	26.6

TABLE XI

RUN ID H-08

CONTU.

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
2.00	1.02	-5.07	-0.146	-0.2710-01	-0.140	-0.3910-01	0.145	10.6
3.00	1.03	-8.95	-0.5720-01	0.3160-01	-0.5940-01	0.2150-01	0.6320-01	4.61
4.00	1.11	-11.9	-0.1380-01	0.2800-01	-0.1730-01	0.2200-01	0.2800-01	2.04
5.00	1.07	-24.6	-0.6860-03	0.1270-01	-0.5530-02	0.1050-01	0.1190-01	0.867
6.00	0.942	-28.5	0.1260-02	0.6410-02	-0.2070-02	0.6620-02	0.6930-02	0.506
7.00	0.711	-42.5	0.8250-03	0.2200-02	-0.1240-02	0.3070-02	0.3310-02	0.241
8.00	0.665	-46.8	0.1170-02	0.1270-02	-0.1920-03	0.2590-02	0.2600-02	0.189
9.00	0.568	-23.1	-0.2840-04	0.7270-03	-0.5480-03	0.1160-02	0.1280-02	0.9340-01
10.0	0.663	-3.47	-0.2890-04	0.1190-02	-0.1520-03	0.1790-02	0.1800-02	0.131

TABLE XI CONTD.

KUN ID H-08

COMMENTS HE PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 2 LINE APP 1/7/69

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	0.886	0.0000 00	64.7	0.0000 00	73.0	0.0000 00	1.00	73.0
0.1000-02	1.00	-0.6170-01	1.00	-0.4710-02	1.00	-0.3630-02	1.00	73.0
0.2000-02	1.00	-0.123	1.00	-0.9420-02	1.00	-0.7270-02	1.00	73.0
0.3000-02	1.00	-0.185	1.00	-0.1410-01	1.00	-0.1090-01	1.00	73.0
0.4000-02	1.00	-0.247	1.00	-0.1880-01	1.00	-0.1450-01	1.00	73.0
0.5000-02	1.00	-0.308	1.00	-0.2350-01	1.00	-0.1820-01	1.00	73.0
0.6000-02	1.00	-0.370	0.999	-0.2820-01	1.00	-0.2180-01	1.00	73.0
0.7000-02	1.00	-0.432	0.999	-0.3290-01	0.999	-0.2540-01	1.00	73.0
0.8000-02	1.00	-0.493	0.999	-0.3760-01	0.999	-0.2900-01	1.00	73.0
0.9000-02	1.00	-0.555	0.999	-0.4230-01	0.999	-0.3270-01	0.999	72.9
0.1000-01	1.00	-0.617	0.998	-0.4700-01	0.999	-0.3630-01	0.999	72.9
0.2000-01	1.00	-1.23	0.993	-0.9360-01	0.995	-0.7220-01	0.997	72.8
0.3000-01	1.00	-1.85	0.984	-0.139	0.988	-0.108	0.994	72.5
0.4000-01	1.00	-2.46	0.972	-0.184	0.979	-0.142	0.990	72.2
0.5000-01	1.00	-3.07	0.957	-0.227	0.968	-0.175	0.984	71.8
0.6000-01	0.999	-3.67	0.939	-0.267	0.955	-0.207	0.977	71.3
0.7000-01	0.999	-4.27	0.919	-0.306	0.940	-0.237	0.970	70.8
0.8000-01	0.999	-4.86	0.897	-0.343	0.924	-0.265	0.961	70.1
0.9000-01	0.999	-5.45	0.873	-0.377	0.906	-0.292	0.952	69.5
0.100	0.999	-6.04	0.848	-0.408	0.887	-0.317	0.942	68.7
0.200	1.01	-11.9	0.583	-0.612	0.691	-0.475	0.839	61.2
0.300	1.02	-18.4	0.325	-0.705	0.520	-0.555	0.760	55.5
0.400	1.03	-25.2	0.7690-01	-0.699	0.357	-0.583	0.684	49.9
0.500	1.04	-31.9	-0.117	-0.624	0.223	-0.572	0.614	44.8
0.600	1.04	-38.9	-0.262	-0.511	0.112	-0.541	0.552	40.3
0.700	1.04	-45.7	-0.349	-0.378	0.2640-01	-0.494	0.495	36.1
0.800	1.04	-52.6	-0.391	-0.250	-0.3750-01	-0.444	0.446	32.6
0.900	1.04	-59.4	-0.397	-0.131	-0.6570-01	-0.393	0.403	29.4
1.00	1.04	-66.3	-0.376	-0.2920-01	-0.120	-0.344	0.364	26.6



TABLE XI

KUN 10 H-08.

CONTD.

OMEGA RAD/SEC	DEAD TIME	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED							
				OUTPUT REAL	OUTPUT IMAGINARY	INPUT REAL	INPUT IMAGINARY	PULSE IMAGINARY	PULSE REAL	INPUT FREQ NORMALIZED	CONTENT ACTUAL
2.00	1.02	1.02	-131.0	0.640D-01	0.134	-0.140	-0.391D-01	0.145	10.6		
3.00	1.03	1.03	162.	0.515D-01	-0.402D-01	-0.594D-01	0.215D-01	0.632D-01	4.61		
4.00	1.11	1.11	96.0	-0.224D-01	-0.217D-01	-0.173D-01	0.220D-01	0.280D-01	2.04		
5.00	1.07	1.07	20.3	-0.946D-02	0.853D-02	-0.553D-02	0.105D-01	0.119D-01	0.867		
6.00	0.942	0.942	-46.7	0.320D-02	0.570D-02	-0.207D-02	0.662D-02	0.693D-02	0.506		
7.00	0.711	0.711	-124.	0.230D-02	-0.477D-03	-0.124D-02	0.307D-02	0.331D-02	0.241		
8.00	0.665	0.665	169.	-0.204D-03	-0.171D-02	-0.192D-03	0.259D-02	0.260D-02	0.189		
9.00	0.568	0.568	130.	-0.307D-03	-0.659D-03	-0.548D-03	0.116D-02	0.128D-02	0.934D-01		
10.0	0.663	0.663	86.3	-0.119D-02	-0.237D-04	-0.152D-03	0.179D-02	0.180D-02	0.131		

TABLE XII

KUN 1D H-09

COMMENTS HE PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 2 LINE APP 1/7/69

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	0.995	0.0000 00	72.9	0.0000 00	73.3	0.0000 00	1.00	73.3
0.1000-02	1.00	0.1320-01	1.00	-0.3670-02	1.00	-0.3900-02	1.00	73.3
0.2000-02	1.00	0.2640-01	1.00	-0.7340-02	1.00	-0.7800-02	1.00	73.3
0.3000-02	1.00	0.3960-01	1.00	-0.1100-01	1.00	-0.1170-01	1.00	73.3
0.4000-02	1.00	0.5280-01	1.00	-0.1470-01	1.00	-0.1560-01	1.00	73.3
0.5000-02	1.00	0.6590-01	1.00	-0.1830-01	1.00	-0.1950-01	1.00	73.3
0.6000-02	1.00	0.7910-01	0.999	-0.2200-01	0.999	-0.2340-01	1.00	73.3
0.7000-02	1.00	0.9220-01	0.999	-0.2570-01	0.999	-0.2730-01	1.00	73.3
0.8000-02	1.00	0.105	0.999	-0.2930-01	0.999	-0.3120-01	0.999	73.3
0.9000-02	1.00	0.118	0.999	-0.3300-01	0.999	-0.3500-01	0.999	73.3
0.1000-01	1.00	0.131	0.999	-0.3660-01	0.998	-0.3890-01	0.999	73.2
0.2000-01	1.00	0.259	0.994	-0.7290-01	0.993	-0.7730-01	0.996	73.0
0.3000-01	1.00	0.379	0.987	-0.108	0.985	-0.115	0.992	72.7
0.4000-01	1.00	0.488	0.978	-0.143	0.974	-0.151	0.986	72.3
0.5000-01	1.00	0.583	0.966	-0.176	0.960	-0.185	0.978	71.7
0.6000-01	1.01	0.663	0.952	-0.207	0.945	-0.217	0.969	71.0
0.7000-01	1.01	0.725	0.937	-0.237	0.927	-0.247	0.959	70.3
0.8000-01	1.01	0.770	0.919	-0.264	0.908	-0.274	0.948	69.5
0.9000-01	1.01	0.798	0.901	-0.289	0.888	-0.299	0.937	68.7
0.100	1.01	0.811	0.882	-0.313	0.868	-0.321	0.925	67.8
0.200	1.02	0.932	0.701	-0.462	0.682	-0.466	0.826	60.5
0.300	1.04	1.39	0.541	-0.559	0.509	-0.552	0.751	55.1
0.400	1.05	0.269	0.369	-0.600	0.249	-0.574	0.672	49.3
0.500	1.05	0.181	0.229	-0.592	0.217	-0.567	0.607	44.5
0.600	1.06	-0.469	0.108	-0.564	0.106	-0.533	0.544	39.9
0.700	1.05	-0.840	0.1640-01	-0.513	0.2280-01	-0.488	0.489	35.8
0.800	1.06	-1.21	-0.5320-01	-0.463	-0.4110-01	-0.439	0.441	32.3
0.900	1.05	-1.89	-0.107	-0.405	-0.6910-01	-0.388	0.398	29.1
1.000	1.05	-2.14	-0.142	-0.350	-0.123	-0.339	0.360	26.4

TABLE XII

RUN ID H-09  
LUNTU.

OMEGA RAD/SEC	DEAD TIME = 0.0000 00	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE		INPUT PULSE		INPUT FREQ		CONTENT	
			AMPLITUDE RATIO	OUTPUT REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	NORMALIZED	ACTUAL	ACTUAL	
2.00		-2.83	-0.146	-0.2960-01	-0.140	-0.3580-01	0.145	0.6190-01	0.145	10.6		
3.00		-5.16	-0.5850-01	0.3200-01	-0.5680-01	0.2470-01	0.6190-01	0.6190-01	0.6190-01	4.54		
4.00		-8.63	-0.1450-01	0.2630-01	-0.1740-01	0.2270-01	0.2860-01	0.2860-01	0.2860-01	2.09		
5.00		-13.5	-0.2300-02	0.1310-01	-0.4870-02	0.1120-01	0.1220-01	0.1220-01	0.1220-01	0.896		
6.00		-18.2	0.1180-02	0.7350-02	-0.1200-02	0.7510-02	0.7610-02	0.7610-02	0.7610-02	0.558		
7.00		-12.7	0.6320-03	0.3090-02	-0.6910-04	0.3620-02	0.3620-02	0.3620-02	0.3620-02	0.265		
8.00		-24.6	0.1210-02	0.1920-02	0.5530-03	0.2660-02	0.2660-02	0.2660-02	0.2660-02	0.197		
9.00		6.39	-0.1790-03	0.8700-03	-0.9810-04	0.1070-02	0.1070-02	0.1070-02	0.1070-02	0.7860-01		
10.0		-15.8	0.5750-03	0.1090-02	0.3800-03	0.1780-02	0.1820-02	0.1820-02	0.1820-02	0.133		

TABLE XII CONTD.

KUN 10 H-09

1/7/69

COMMENTS HE PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOIP 2 LINE APP

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	INPUT FREQ CONTENT ACTUAL
			DEAD TIME	1.10				
0.0000-00	0.995	0.0000-00	72.9	0.0000-00	73.3	0.0000-00	1.00	73.3
0.1000-02	1.00	-0.4980-01	1.00	-0.4770-02	1.00	-0.3900-02	1.00	73.3
0.2000-02	1.00	-0.9970-01	1.00	-0.9540-02	1.00	-0.7800-02	1.00	73.3
0.3000-02	1.00	-0.149	1.00	-0.1430-01	1.00	-0.1170-01	1.00	73.3
0.4000-02	1.00	-0.199	1.00	-0.1910-01	1.00	-0.1560-01	1.00	73.3
0.5000-02	1.00	-0.249	1.00	-0.2380-01	1.00	-0.1950-01	1.00	73.3
0.6000-02	1.00	-0.299	0.999	-0.2860-01	0.999	-0.2340-01	1.00	73.3
0.7000-02	1.00	-0.349	0.999	-0.3340-01	0.999	-0.2730-01	1.00	73.3
0.8000-02	1.00	-0.399	0.999	-0.3810-01	0.999	-0.3120-01	0.999	73.3
0.9000-02	1.00	-0.449	0.998	-0.4290-01	0.999	-0.3500-01	0.999	73.3
0.1000-01	1.00	-0.499	0.998	-0.4760-01	0.998	-0.3890-01	0.999	73.2
0.2000-01	1.00	-1.00	0.992	-0.9480-01	0.993	-0.7730-01	0.996	73.0
0.3000-01	1.00	-1.51	0.983	-0.141	0.985	-0.115	0.992	72.7
0.4000-01	1.00	-2.03	0.971	-0.186	0.974	-0.151	0.986	72.3
0.5000-01	1.00	-2.57	0.955	-0.229	0.960	-0.185	0.978	71.7
0.6000-01	1.01	-3.12	0.936	-0.269	0.945	-0.217	0.969	71.0
0.7000-01	1.01	-3.69	0.916	-0.308	0.927	-0.247	0.959	70.3
0.8000-01	1.01	-4.27	0.893	-0.344	0.908	-0.274	0.948	69.5
0.9000-01	1.01	-4.87	0.868	-0.377	0.888	-0.299	0.937	68.7
0.100	1.01	-5.49	0.843	-0.408	0.868	-0.321	0.925	67.8
0.200	1.02	-11.7	0.583	-0.604	0.682	-0.466	0.826	60.5
0.300	1.04	-17.5	0.331	-0.704	0.509	-0.552	0.751	55.1
0.400	1.05	-24.9	0.7830-01	-0.700	0.349	-0.574	0.672	49.3
0.500	1.05	-31.3	-0.115	-0.625	0.217	-0.567	0.607	44.5
0.600	1.06	-38.3	-0.260	-0.511	0.106	-0.533	0.544	39.9
0.700	1.06	-45.0	-0.345	-0.380	0.2280-01	-0.488	0.489	35.8
0.800	1.06	-51.6	-0.391	-0.254	-0.4110-01	-0.439	0.441	32.3
0.900	1.05	-58.6	-0.397	-0.133	-0.6910-01	-0.388	0.398	29.1
1.00	1.05	-65.2	-0.377	-0.3250-01	-0.123	-0.339	0.360	26.4

TABLE XII

KUN 10 H-09

CONTD.

OMEGA RAD/SEC	DEAD TIME	1.10	PULSES NORMALIZED				INPUT PULSE		INPUT FREQ		CONTENT ACTUAL
			AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT REAL	OUTPUT IMAGINARY	REAL	IMAGINARY	NORMALIZED	NORMALIZED	
2.00		1.03	-129.	0.6180-01	0.135	-0.140	-0.3580-01	0.145	10.6		
3.00		1.08	166.	0.5270-01	-0.4080-01	-0.5680-01	0.2470-01	0.6190-01	4.54		
4.00		1.05	99.3	-0.2060-01	-0.2190-01	-0.1740-01	0.2270-01	0.2860-01	2.09		
5.00		1.09	31.3	-0.1090-01	0.7680-02	-0.4870-02	0.1120-01	0.1220-01	0.896		
6.00		0.979	-36.4	0.3410-02	0.6620-02	-0.1200-02	0.7510-02	0.7610-02	0.558		
7.00		0.871	-93.8	0.3150-02	-0.1510-02	-0.6910-04	0.3620-02	0.3620-02	0.265		
8.00		0.846	-169.	0.1440-03	-0.2270-02	0.3530-03	0.2660-02	0.2660-02	0.197		
9.00		0.828	159.	-0.2390-03	-0.8560-03	-0.9810-04	0.1070-02	0.1070-02	0.7860-01		
10.0		0.677	73.9	-0.1090-02	0.5800-03	0.3800-03	0.1780-02	0.1820-02	0.133		

TABLE XIII

RUN ID H-10

COMMENTS HE PACKED RED HT 7 1/4 IN AIR RATL 4.0 CM SMP LOOP 3 LINE APP 1/7/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	REAL	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
0.0000 00	1.05	0.0000 00	68.8	0.0000 00	65.3	0.0000 00	0.0000 00	1.00	65.3
0.1000-02	1.00	0.9650-02	1.00	-0.3020-02	1.00	-0.3180-02	-0.3180-02	1.00	65.3
0.2000-02	1.00	0.1930-01	1.00	-0.6030-02	1.00	-0.6370-02	-0.6370-02	1.00	65.3
0.3000-02	1.00	0.2890-01	1.00	-0.9040-02	1.00	-0.9550-02	-0.9550-02	1.00	65.3
0.4000-02	1.00	0.3860-01	1.00	-0.1210-01	1.00	-0.1270-01	-0.1270-01	1.00	65.3
0.5000-02	1.00	0.4820-01	1.00	-0.1510-01	1.00	-0.1590-01	-0.1590-01	1.00	65.3
0.6000-02	1.00	0.5790-01	1.00	-0.1810-01	1.00	-0.1910-01	-0.1910-01	1.00	65.3
0.7000-02	1.00	0.6750-01	1.00	-0.2110-01	1.00	-0.2230-01	-0.2230-01	1.00	65.3
0.8000-02	1.00	0.7710-01	1.00	-0.2410-01	0.999	-0.2550-01	-0.2550-01	1.00	65.3
0.9000-02	1.00	0.8670-01	0.999	-0.2710-01	0.999	-0.2860-01	-0.2860-01	1.00	65.3
0.1000-01	1.00	0.9630-01	0.999	-0.3010-01	0.999	-0.3180-01	-0.3180-01	1.00	65.3
0.2000-01	1.00	0.192	0.997	-0.6010-01	0.996	-0.6340-01	-0.6340-01	0.998	65.2
0.3000-01	1.00	0.285	0.993	-0.8990-01	0.985	-0.9470-01	-0.9470-01	0.996	65.1
0.4000-01	1.00	0.375	0.988	-0.119	0.977	-0.126	-0.126	0.993	64.9
0.5000-01	1.00	0.460	0.981	-0.148	0.977	-0.156	-0.156	0.990	64.6
0.6000-01	1.00	0.541	0.973	-0.177	0.968	-0.185	-0.185	0.985	64.4
0.7000-01	1.01	0.615	0.964	-0.204	0.957	-0.213	-0.213	0.980	64.0
0.8000-01	1.01	0.681	0.953	-0.231	0.944	-0.241	-0.241	0.974	63.6
0.9000-01	1.01	0.740	0.942	-0.257	0.930	-0.267	-0.267	0.968	63.2
0.100	1.01	0.789	0.929	-0.282	0.916	-0.292	-0.292	0.961	62.8
0.200	1.03	0.625	0.766	-0.480	0.736	-0.472	-0.472	0.874	57.1
0.300	1.05	-0.549	0.583	-0.590	0.561	-0.557	-0.557	0.790	51.6
0.400	1.05	-1.59	0.407	-0.637	0.404	-0.595	-0.595	0.719	47.0
0.500	1.05	-2.27	0.252	-0.638	0.262	-0.595	-0.595	0.650	42.5
0.600	1.06	-3.37	0.120	-0.609	0.147	-0.566	-0.566	0.585	38.2
0.700	1.06	-4.59	0.1460-01	-0.559	0.5600-01	-0.525	-0.525	0.528	34.5
0.800	1.05	-5.37	-0.6240-01	-0.498	-0.1470-01	-0.477	-0.477	0.477	31.2
0.900	1.05	-6.16	-0.118	-0.437	-0.0740-01	-0.427	-0.427	0.432	28.2
1.00	1.04	-6.97	-0.159	-0.378	-0.107	-0.378	-0.378	0.392	25.6

TABLE XIII

RUN ID H-10

CONTD.

OMEGA RAD/SEC	DEAD TIME*	0.0000 00	PULSES NORMALIZED		PHASE ANGLE		OUTPUT PULSE		INPUT PULSE		INPUT PULSE		INPUT FREQ		CONTENT	
			AMPLITUDE RATIO	DEGREES	REAL	IMAGINARY	REAL	IMAGINARY	REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL		
2.00	1.00	-11.8	-0.158	-0.232U-01	-0.150	-0.547D-01	0.159	10.4								
3.00	0.996	-16.5	-0.590D-01	0.368U-01	-0.673D-01	0.187D-01	0.698D-01	4.56								
4.00	1.03	-25.1	-0.121D-01	0.293U-01	-0.227D-01	0.208D-01	0.308D-01	2.01								
5.00	0.869	-37.8	-0.234D-03	0.123U-01	-0.388D-02	0.110D-01	0.141D-01	0.923								
6.00	0.778	-39.1	0.907D-03	0.608U-02	-0.402U-02	0.680D-02	0.790D-02	0.516								
7.00	0.418	-45.0	0.527D-03	0.200U-02	-0.248U-02	0.427D-02	0.494D-02	0.323								
8.00	0.738	-12.5	0.410D-04	0.201U-02	-0.534D-03	0.268D-02	0.273D-02	0.178								
9.00	1.13	-9.05	-0.747D-03	0.188U-02	-0.913D-03	0.154D-02	0.179D-02	0.117								
10.0	1.22	-25.1	0.354D-03	0.202U-02	-0.439U-03	0.162D-02	0.168D-02	0.110								

TABLE XIII CONTD.

RUN ID H-10

1/7/69

COMMENTS HE PACKED NED HT 7 1/4 IN AIR RATE 4.0 CH SMP LOOP 3 LINE APP

DEAD TIME= 1.20 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT REAL	OUTPUT IMAGINARY	INPUT REAL	INPUT IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
0.0000 00	1.05	0.0000 00	68.8	0.0000 00	.65.3	0.0000 00	1.00	65.3
0.1000-02	1.00	-0.5910-01	1.00	-0.4220-02	1.00	-0.3180-02	1.00	65.3
0.2000-02	1.00	-0.1118	1.00	-0.8430-02	1.00	-0.6370-02	1.00	65.3
0.3000-02	1.00	-0.1777	1.00	-0.1260-01	1.00	-0.9550-02	1.00	65.3
0.4000-02	1.00	-0.236	1.00	-0.1690-01	1.00	-0.1270-01	1.00	65.3
0.5000-02	1.00	-0.296	1.00	-0.2110-01	1.00	-0.1590-01	1.00	65.3
0.6000-02	1.00	-0.355	1.00	-0.2530-01	1.00	-0.1910-01	1.00	65.3
0.7000-02	1.00	-0.414	0.999	-0.2950-01	1.00	-0.2230-01	1.00	65.3
0.8000-02	1.00	-0.473	0.999	-0.3370-01	0.999	-0.2550-01	1.00	65.3
0.9000-02	1.00	-0.532	0.999	-0.3790-01	0.999	-0.2860-01	1.00	65.3
0.1000-01	1.00	-0.591	0.999	-0.4210-01	0.999	-0.3180-01	1.00	65.3
0.2000-01	1.00	-1.18	0.995	-0.8400-01	0.996	-0.6340-01	0.998	65.2
0.3000-01	1.00	-1.78	0.989	-0.126	0.992	-0.9470-01	0.996	65.1
0.4000-01	1.00	-2.38	0.981	-0.167	0.985	-0.126	0.993	64.9
0.5000-01	1.00	-2.98	0.971	-0.207	0.977	-0.156	0.990	64.6
0.6000-01	1.00	-3.58	0.958	-0.246	0.968	-0.185	0.985	64.4
0.7000-01	1.01	-4.20	0.943	-0.284	0.957	-0.213	0.980	64.0
0.8000-01	1.01	-4.82	0.927	-0.321	0.944	-0.241	0.974	63.6
0.9000-01	1.01	-5.45	0.909	-0.357	0.930	-0.267	0.968	63.2
0.100	1.01	-6.09	0.889	-0.391	0.916	-0.292	0.961	62.8
0.200	1.03	-13.1	0.630	-0.648	0.736	-0.472	0.874	57.1
0.300	1.05	-21.2	0.338	-0.757	0.561	-0.557	0.790	51.6
0.400	1.05	-29.1	0.6700-01	-0.753	0.404	-0.595	0.719	47.0
0.500	1.05	-36.6	-0.153	-0.669	0.262	-0.595	0.650	42.5
0.600	1.06	-44.6	-0.311	-0.538	0.147	-0.566	0.585	38.2
0.700	1.06	-52.7	-0.406	-0.384	0.1600-01	-0.525	0.528	34.5
0.800	1.05	-60.4	-0.444	-0.234	-0.1470-01	-0.477	0.477	31.2
0.900	1.05	-68.0	-0.442	-0.102	-0.6740-01	-0.427	0.432	28.2
1.00	1.04	-75.7	-0.410	0.1120-01	-0.107	-0.378	0.392	25.6



TABLE XIII

RUN 10 H-10

CONTD.

OMEGA RAD/SEC	DEAD TIME=	1.20	PHASE ANGLE DEGREES	PULSES NORMALIZED				INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
				AMPLITUDE RATIO	OUTPUT REAL	OUTPUT IMAGINARY	REAL				
2.00			-149.	0.101	0.124	-0.150	-0.5470-01	0.159	10.4		
3.00			137.	0.3660-01	-0.5910-01	-0.6730-01	0.1870-01	0.6980-01	4.56		
4.00			59.9	-0.3020-01	-0.9480-02	-0.2270-01	0.2080-01	0.3080-01	2.01		
5.00			-21.6	-0.3660-02	0.1170-01	-0.8880-02	0.1100-01	0.1410-01	0.923		
6.00			-91.6	0.5370-02	0.2980-02	-0.4020-02	0.6800-02	0.7900-02	0.516		
7.00			-166.	0.1430-02	-0.1490-02	-0.2480-02	0.4270-02	0.4940-02	0.323		
8.00			157.	-0.3910-03	-0.1970-02	-0.5340-03	0.2680-02	0.2730-02	0.178		
9.00			92.2	-0.1700-02	-0.1100-02	-0.9130-03	0.1540-02	0.1790-02	0.117		
10.0			7.38	-0.7870-03	0.1900-02	-0.4390-03	0.1620-02	0.1680-02	0.110		

TABLE XIV

RUN 10 H-11

COMMENTS HE PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 3 LINE APP 1/7/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	1.02	0.0000 00	66.3	0.0000 00	64.9	0.0000 00	1.00	64.9
0.1000-02	1.00	0.1840-01	1.00	-0.2990-02	1.00	-0.3310-02	1.00	64.9
0.2000-02	1.00	0.3670-01	1.00	-0.5980-02	1.00	-0.6620-02	1.00	64.9
0.3000-02	1.00	0.5510-01	1.00	-0.8960-02	1.00	-0.9930-02	1.00	64.9
0.4000-02	1.00	0.7340-01	1.00	-0.1200-01	1.00	-0.1930-01	1.00	64.9
0.5000-02	1.00	0.9170-01	1.00	-0.1490-01	1.00	-0.1650-01	1.00	64.9
0.6000-02	1.00	0.110	1.00	-0.1790-01	1.00	-0.1980-01	1.00	64.9
0.7000-02	1.00	0.128	1.00	-0.2090-01	1.00	-0.2310-01	1.00	64.9
0.8000-02	1.00	0.147	0.999	-0.2390-01	0.999	-0.2650-01	1.00	64.9
0.9000-02	1.00	0.165	0.999	-0.2690-01	0.999	-0.2980-01	1.00	64.9
0.1000-01	1.00	0.183	0.999	-0.2990-01	0.999	-0.3310-01	1.00	64.9
0.2000-01	1.00	0.365	0.997	-0.5960-01	0.996	-0.6590-01	0.998	64.8
0.3000-01	1.00	0.544	0.993	-0.8900-01	0.991	-0.9840-01	0.996	64.7
0.4000-01	1.00	0.719	0.988	-0.118	0.984	-0.130	0.993	64.5
0.5000-01	1.00	0.888	0.981	-0.147	0.975	-0.161	0.989	64.2
0.6000-01	1.00	1.05	0.972	-0.174	0.965	-0.191	0.984	63.9
0.7000-01	1.01	1.21	0.963	-0.202	0.953	-0.221	0.972	63.5
0.8000-01	1.01	1.35	0.952	-0.228	0.939	-0.248	0.965	63.1
0.9000-01	1.01	1.49	0.940	-0.253	0.925	-0.275	0.965	62.7
0.100	1.01	1.61	0.927	-0.278	0.909	-0.300	0.957	62.2
0.200	1.03	2.19	0.767	-0.465	0.724	-0.477	0.867	56.3
0.300	1.05	2.08	0.598	-0.569	0.549	-0.562	0.786	51.0
0.400	1.06	2.06	0.433	-0.624	0.386	-0.601	0.715	46.4
0.500	1.08	1.65	0.279	-0.634	0.242	-0.594	0.642	41.7
0.600	1.08	0.830	0.150	-0.610	0.130	-0.564	0.579	37.6
0.700	1.08	0.416	0.4440-01	-0.567	0.3720-01	-0.524	0.525	34.1
0.800	1.09	0.112	-0.3850-01	-0.513	-0.3640-01	-0.472	0.473	30.7
0.900	1.09	-0.494	-0.9980-01	-0.453	-0.8830-01	-0.418	0.427	27.7
1.00	1.08	-0.964	-0.143	-0.393	-0.126	-0.366	0.387	25.1

TABLE XIV

KUN 10 H-11

CUNTD.

OMEGA RAD/SEC	DEAD TIME= 0.0000 00	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE		INPUT FREQ. CONTENT	
				OUTPUT REAL	OUTPUT IMAGINARY	INPUT REAL	INPUT IMAGINARY	INPUT NORMALIZED	ACTUAL
2.00		1.07	2.54	-0.156	-0.4520-01	-0.149	-0.3590-01	0.153	9.92
3.00		1.14	1.38	-0.6400-01	0.2740-01	-0.5550-01	0.2540-01	0.6110-01	3.97
4.00		1.60	-2.43	-0.2100-01	0.3020-01	-0.1390-01	0.1830-01	0.2300-01	1.49
5.00		1.38	-38.4	-0.6450-02	0.1130-01	-0.8770-02	0.3530-02	0.9450-02	0.614
6.00		0.766	-65.9	0.1130-02	0.8130-02	-0.9080-02	0.5670-02	0.1070-01	0.696
7.00		0.344	-26.8	-0.6910-03	0.3540-02	-0.6430-02	0.8260-02	0.1050-01	0.680
8.00		0.374	-10.1	0.1030-02	0.3450-02	0.1100-02	0.9560-02	0.9620-02	0.625
9.00		0.325	130.	-0.2000-02	0.5130-03	0.5170-02	0.3700-02	0.6350-02	0.413
10.0		0.289	39.7	0.1380-02	0.6410-03	0.5080-02	-0.1340-02	0.5250-02	0.341

TABLE XIV CONTD.

KUN ID H-11

COMMENTS HE PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 3 LINE APP 1/7/69

UMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
			DEAD TIME	1.30				
0.0000-00	1.02	0.0000 00	66.3	0.0000 00	64.9	0.0000 00	1.00	64.9
0.1000-02	1.00	-0.5610-01	1.00	-0.4290-02	1.00	-0.3310-02	1.00	64.9
0.2000-02	1.00	-0.112	1.00	-0.8580-02	1.00	-0.6620-02	1.00	64.9
0.3000-02	1.00	-0.168	1.00	-0.1290-01	1.00	-0.9930-02	1.00	64.9
0.4000-02	1.00	-0.225	1.00	-0.1720-01	1.00	-0.1320-01	1.00	64.9
0.5000-02	1.00	-0.281	1.00	-0.2140-01	1.00	-0.1650-01	1.00	64.9
0.6000-02	1.00	-0.337	1.00	-0.2570-01	1.00	-0.1980-01	1.00	64.9
0.7000-02	1.00	-0.393	0.999	-0.3000-01	1.00	-0.2310-01	1.00	64.9
0.8000-02	1.00	-0.449	0.999	-0.3430-01	0.999	-0.2650-01	1.00	64.9
0.9000-02	1.00	-0.505	0.999	-0.3860-01	0.999	-0.2980-01	1.00	64.9
0.1000-01	1.00	-0.562	0.999	-0.4280-01	0.999	-0.3310-01	1.00	64.9
0.2000-01	1.00	-1.12	0.995	-0.8550-01	0.996	-0.6590-01	0.998	64.8
0.3000-01	1.00	-1.69	0.989	-0.128	0.991	-0.9840-01	0.996	64.7
0.4000-01	1.00	-2.26	0.980	-0.169	0.984	-0.130	0.993	64.5
0.5000-01	1.00	-2.84	0.969	-0.210	0.975	-0.161	0.989	64.2
0.6000-01	1.00	-3.42	0.956	-0.250	0.965	-0.191	0.984	63.9
0.7000-01	1.01	-4.01	0.941	-0.288	0.953	-0.221	0.978	63.5
0.8000-01	1.01	-4.61	0.923	-0.326	0.939	-0.248	0.972	63.1
0.9000-01	1.01	-5.22	0.904	-0.361	0.925	-0.275	0.965	62.7
0.100	1.01	-5.84	0.884	-0.396	0.909	-0.300	0.957	62.2
0.200	1.03	-12.7	0.622	-0.646	0.724	-0.477	0.867	56.3
0.300	1.05	-20.3	0.336	-0.754	0.549	-0.562	0.786	51.0
0.400	1.06	-27.7	0.6580-01	-0.757	0.386	-0.601	0.715	46.4
0.500	1.08	-35.6	-0.161	-0.674	0.242	-0.594	0.642	41.7
0.600	1.08	-43.9	-0.322	-0.539	0.130	-0.564	0.579	37.6
0.700	1.08	-51.7	-0.421	-0.383	0.3720-01	-0.524	0.525	34.1
0.800	1.09	-59.5	-0.462	-0.226	-0.3640-01	-0.472	0.473	30.7
0.900	1.09	-67.5	-0.456	-0.8480-01	-0.8830-01	-0.418	0.427	27.7
1.000	1.08	-75.4	-0.417	0.3290-01	-0.126	-0.366	0.387	25.1

TABLE XIV

RUN ID H-11

COUNT.

OMEGA RAD/SEC	DEAD TIME*	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE		INPUT FREQ CONTENT	
				REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00	1.30	1.07	-146.	0.111	0.119	-0.149	-0.3590-01	0.153	9.92
3.00	1.30	1.14	138.	0.2760-01	-0.6390-01	-0.5550-01	0.2540-01	0.6110-01	3.97
4.00	1.30	1.60	59.6	-0.3650-01	-0.4400-02	-0.1390-01	0.1830-01	0.2300-01	1.49
5.00	1.30	1.38	-50.8	-0.3860-02	0.1250-01	-0.8770-02	0.3530-02	0.9450-02	0.614
6.00	1.30	0.766	-153.	0.8180-02	-0.6910-03	-0.9080-02	0.5670-02	0.1070-01	0.696
7.00	1.30	0.344	172.	0.1780-02	-0.3130-02	-0.6430-02	0.8260-02	0.1050-01	0.680
8.00	1.30	0.374	114.	-0.3430-02	-0.1080-02	0.1100-02	0.9560-02	0.9620-02	0.625
9.00	1.30	0.325	180.	-0.1690-02	-0.1190-02	0.5170-02	0.3700-02	0.6350-02	0.413
10.0	1.30	0.289	14.9	0.1520-02	0.3120-05	0.5080-02	-0.1340-02	0.5250-02	0.341

TABLE XV

RUN ID H-12

COMMENTS HE FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SHP LOOP 2 LINE APP 1/9/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	0.900	0.0000 00	64.1	0.0000 00	71.3	0.0000 00	1.00	71.3
0.1000-02	1.00	-0.4100-01	1.00	-0.4360-02	1.00	-0.3650-02	1.00	71.3
0.2000-02	1.00	-0.8200-01	1.00	-0.8720-02	1.00	-0.7290-02	1.00	71.3
0.3000-02	1.00	-0.123	1.00	-0.1310-01	1.00	-0.1090-01	1.00	71.3
0.4000-02	1.00	-0.164	1.00	-0.1740-01	1.00	-0.1460-01	1.00	71.2
0.5000-02	1.00	-0.205	1.00	-0.2180-01	1.00	-0.1820-01	1.00	71.2
0.6000-02	1.00	-0.246	0.999	-0.2620-01	1.00	-0.2190-01	1.00	71.2
0.7000-02	1.00	-0.287	0.999	-0.3050-01	0.999	-0.2550-01	1.00	71.2
0.8000-02	1.00	-0.328	0.999	-0.3490-01	0.999	-0.2910-01	1.00	71.2
0.9000-02	1.00	-0.369	0.999	-0.3920-01	0.999	-0.3280-01	0.999	71.2
0.1000-01	1.00	-0.409	0.998	-0.4350-01	0.999	-0.3640-01	0.999	71.2
0.2000-01	1.00	-0.817	0.993	-0.8670-01	0.995	-0.7250-01	0.997	71.1
0.3000-01	0.999	-1.22	0.985	-0.129	0.988	-0.108	0.994	70.8
0.4000-01	0.999	-1.62	0.974	-0.170	0.979	-0.143	0.990	70.5
0.5000-01	0.999	-2.01	0.960	-0.210	0.968	-0.176	0.984	70.1
0.6000-01	0.998	-2.40	0.944	-0.248	0.955	-0.208	0.978	69.7
0.7000-01	0.998	-2.78	0.925	-0.283	0.940	-0.239	0.970	69.1
0.8000-01	0.997	-3.15	0.905	-0.317	0.923	-0.268	0.961	68.5
0.9000-01	0.997	-3.51	0.883	-0.349	0.905	-0.295	0.952	67.8
0.100	0.997	-3.86	0.860	-0.378	0.886	-0.320	0.942	67.1
0.200	1.01	-7.58	0.616	-0.564	0.681	-0.475	0.830	59.1
0.300	1.01	-12.8	0.387	-0.649	0.516	-0.541	0.747	53.2
0.400	0.988	-17.7	0.168	-0.649	0.362	-0.574	0.679	48.4
0.500	0.973	-22.1	-0.2280-02	-0.589	0.225	-0.562	0.605	43.1
0.600	0.947	-27.2	-0.126	-0.499	0.123	-0.529	0.544	38.7
0.700	0.910	-31.5	-0.202	-0.398	0.3980-01	-0.489	0.491	35.0
0.800	0.876	-35.9	-0.244	-0.302	-0.2350-01	-0.442	0.443	31.6
0.900	0.832	-39.8	-0.258	-0.214	-0.7380-01	-0.395	0.402	28.6
1.00	0.800	-43.3	-0.252	-0.140	-0.109	-0.344	0.361	25.7

TABLE XV

KUN ID H-12

CONTD.

OMEGA RAD/SEC	DEAD TIME	0.000D 00	PULSES NORMALIZED	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL		
				AMPLITUDE RATIO	PHASE ANGLE DEGREES	REAL	IMAGINARY			REAL	IMAGINARY
2.00				0.364	-72.6	-0.323D-01	0.436D-01	-0.141	-0.489D-01	0.149	10.6
3.00				0.109	-33.1	-0.443D-02	0.546D-02	-0.614D-01	0.197D-01	0.645D-01	4.60
4.00				0.282	-3.16	-0.539D-02	0.595D-02	-0.202D-01	0.200D-01	0.284D-01	2.03
5.00				0.229	-31.7	-0.214D-03	0.291D-02	-0.748D-02	0.103D-01	0.128D-01	0.909
6.00				0.139	-95.1	0.973D-03	0.446D-03	-0.382D-02	0.670D-02	0.772D-02	0.550
7.00				0.570	66.9	-0.248D-02	-0.471D-03	-0.247D-02	0.368D-02	0.443D-02	0.316
8.00				0.841	-15.6	-0.197D-03	0.191D-02	-0.838D-03	0.213D-02	0.228D-02	0.163
9.00				0.366	-16.0	-0.158D-03	0.775D-03	-0.996D-03	0.192D-02	0.216D-02	0.154
10.0				0.112	-126.	0.207D-03	-0.630D-04	-0.639D-03	0.183D-02	0.193D-02	0.138

TABLE XV CONTD.

RUN ID H-12

COMMENTS HE FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 2 LINE APP 1/9/69

DEAD TIME= 1.80 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000-00	0.900	0.0000 00	64.1	0.0000 00	71.3	0.0000 00	1.00	71.3
0.1000-02	1.00	-0.144	1.00	-0.6160-02	1.00	-0.3650-02	1.00	71.3
0.2000-02	1.00	-0.288	1.00	-0.1230-01	1.00	-0.7290-02	1.00	71.3
0.3000-02	1.00	-0.432	1.00	-0.1850-01	1.00	-0.1090-01	1.00	71.3
0.4000-02	1.00	-0.576	1.00	-0.2460-01	1.00	-0.1460-01	1.00	71.2
0.5000-02	1.00	-0.721	0.999	-0.3080-01	1.00	-0.1820-01	1.00	71.2
0.6000-02	1.00	-0.865	0.999	-0.3690-01	1.00	-0.2190-01	1.00	71.2
0.7000-02	1.00	-1.01	0.999	-0.4310-01	0.999	-0.2550-01	1.00	71.2
0.8000-02	1.00	-1.15	0.998	-0.4920-01	0.999	-0.2910-01	1.00	71.2
0.9000-02	1.00	-1.30	0.998	-0.5540-01	0.999	-0.3280-01	0.999	71.2
0.1000-01	1.00	-1.44	0.997	-0.6150-01	0.999	-0.3640-01	0.999	71.2
0.2000-01	1.00	-2.88	0.990	-0.122	0.995	-0.7250-01	0.997	71.1
0.3000-01	0.999	-4.32	0.977	-0.182	0.988	-0.108	0.994	70.8
0.4000-01	0.999	-5.75	0.959	-0.240	0.979	-0.143	0.990	70.5
0.5000-01	0.999	-7.17	0.938	-0.295	0.968	-0.176	0.984	70.1
0.6000-01	0.998	-8.59	0.912	-0.348	0.955	-0.208	0.978	69.7
0.7000-01	0.998	-10.0	0.882	-0.398	0.940	-0.239	0.970	69.1
0.8000-01	0.997	-11.4	0.850	-0.444	0.923	-0.268	0.961	68.5
0.9000-01	0.997	-12.8	0.815	-0.486	0.905	-0.295	0.952	67.8
0.100	0.997	-14.2	0.778	-0.525	0.886	-0.320	0.942	67.1
0.200	1.01	-28.2	0.378	-0.744	0.681	-0.475	0.830	59.1
0.300	1.01	-43.8	-0.1600-02	-0.755	0.516	-0.541	0.747	53.2
0.400	0.988	-59.0	-0.302	-0.599	0.362	-0.574	0.679	48.4
0.500	0.973	-73.7	-0.463	-0.364	0.225	-0.562	0.605	43.1
0.600	0.947	-89.1	-0.499	-0.124	0.123	-0.529	0.544	38.7
0.700	0.910	-104.	-0.441	0.7020-01	0.3980-01	-0.489	0.491	35.0
0.800	0.876	-118.	-0.331	0.202	-0.2350-01	-0.442	0.443	31.6
0.900	0.832	-133.	-0.201	0.268	-0.7380-01	-0.395	0.402	28.6
1.00	0.800	-146.	-0.7930-01	0.278	-0.109	-0.344	0.361	25.7



TABLE XV

RUN ID H-12

CONTD.

OMEGA RAD/SEC	DEAD TIME=	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED				INPUT REAL	INPUT IMAGINARY	PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
				1.80	OUTPUT REAL	OUTPUT IMAGINARY	REAL					
2.00		0.364	81.1	0.967D-02	-0.534D-01	-0.141	-0.489D-01	0.149	0.149	10.6		
3.00		0.109	17.5	-0.703D-02	0.435D-04	-0.614D-01	0.197D-01	0.645D-01	0.645D-01	4.60		
4.00		0.282	-55.7	0.145D-02	0.790D-02	-0.202D-01	0.200D-01	0.284D-01	0.284D-01	2.03		
5.00		0.229	173.	0.140D-02	-0.257D-02	-0.748D-02	0.103D-01	0.128D-01	0.128D-01	0.909		
6.00		0.139	6.10	-0.626D-03	0.868D-03	-0.382D-02	0.670D-02	0.772D-02	0.772D-02	0.550		
7.00		0.570	65.0	-0.250D-02	-0.387D-03	-0.247D-02	0.368D-02	0.443D-02	0.443D-02	0.316		
8.00		0.841	-121.	0.190D-02	-0.306D-03	-0.838D-03	0.213D-02	0.228D-02	0.228D-02	0.163		
9.00		0.366	136.	-0.228D-03	-0.758D-03	-0.996D-03	0.192D-02	0.216D-02	0.216D-02	0.154		
10.0		0.112	-77.6	0.184D-03	0.113D-03	-0.639D-03	0.183D-02	0.193D-02	0.193D-02	0.138		

ORTRAN \*\* STOP

TABLE XVI

RUN ID H-13

COMMENTS HE FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 3 LINE APP 1/9/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
0.0000 00	1.10	0.0000 00	22.6	0.0000 00	20.6	0.0000 00	1.00	20.6
0.1000-02	1.00	-0.6800-01	1.00	-0.4270-02	1.00	-0.3080-02	1.00	20.6
0.2000-02	1.00	-0.136	1.00	-0.8540-02	1.00	-0.6170-02	1.00	20.6
0.3000-02	1.00	-0.204	1.00	-0.1280-01	1.00	-0.9250-02	1.00	20.6
0.4000-02	1.00	-0.272	1.00	-0.1710-01	1.00	-0.1230-01	1.00	20.6
0.5000-02	1.00	-0.340	1.00	-0.2130-01	1.00	-0.1540-01	1.00	20.6
0.6000-02	1.00	-0.408	1.00	-0.2560-01	1.00	-0.1850-01	1.00	20.6
0.7000-02	1.00	-0.476	0.999	-0.2990-01	1.00	-0.2160-01	1.00	20.6
0.8000-02	1.00	-0.544	0.999	-0.3410-01	0.999	-0.2470-01	1.00	20.6
0.9000-02	1.00	-0.612	0.999	-0.3840-01	0.999	-0.2770-01	1.00	20.6
0.1000-01	1.00	-0.680	0.999	-0.4270-01	0.999	-0.3080-01	1.00	20.6
0.2000-01	1.00	-1.36	0.995	-0.8510-01	0.997	-0.6150-01	0.999	20.6
0.3000-01	1.00	-2.04	0.988	-0.127	0.993	-0.9190-01	0.997	20.5
0.4000-01	1.00	-2.72	0.980	-0.168	0.987	-0.122	0.994	20.5
0.5000-01	1.00	-3.40	0.968	-0.209	0.979	-0.151	0.991	20.4
0.6000-01	0.999	-4.08	0.955	-0.248	0.971	-0.180	0.987	20.3
0.7000-01	0.999	-4.76	0.939	-0.287	0.961	-0.208	0.983	20.3
0.8000-01	0.999	-5.44	0.922	-0.324	0.949	-0.235	0.978	20.1
0.9000-01	0.999	-6.12	0.902	-0.359	0.936	-0.261	0.972	20.0
0.100	0.998	-6.80	0.881	-0.393	0.923	-0.286	0.966	19.9
0.200	0.993	-13.6	0.614	-0.632	0.751	-0.473	0.887	18.3
0.300	0.987	-20.3	0.336	-0.720	0.572	-0.566	0.805	16.6
0.400	0.981	-27.2	0.8600-01	-0.714	0.411	-0.607	0.733	15.1
0.500	0.968	-34.6	-0.123	-0.632	0.266	-0.609	0.665	13.7
0.600	0.942	-42.0	-0.265	-0.500	0.147	-0.583	0.601	12.4
0.700	0.912	-48.8	-0.341	-0.361	0.5090-01	-0.543	0.545	11.2
0.800	0.887	-55.4	-0.373	-0.229	-0.2620-01	-0.493	0.493	10.2
0.900	0.859	-62.5	-0.366	-0.110	-0.8320-01	-0.438	0.445	9.18
1.00	0.824	-69.3	-0.332	-0.1590-01	-0.124	-0.384	0.403	8.31

TABLE XVI

RUN ID H-13

CONTD.

OMEGA RAD/SEC	DEAD TIME = 0.0000 00	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
				REAL	IMAGINARY	REAL	IMAGINARY		
2.00		0.468	-140.	0.406D-01	0.649D-01	-0.156	-0.505D-01	0.164	3.37
3.00		0.303	141.	0.101D-01	-0.177D-01	-0.625D-01	0.249D-01	0.673D-01	1.39
4.00		0.237	58.2	-0.785D-02	-0.685D-03	-0.199D-01	0.266D-01	0.332D-01	0.684
5.00		0.408	-17.3	-0.147D-02	0.520D-02	-0.722D-02	0.111D-01	0.132D-01	0.273
6.00		0.421	-81.6	0.268D-02	0.873D-03	-0.112D-02	0.659D-02	0.669D-02	0.138
7.00		0.775	-180.	0.150D-03	-0.295D-02	-0.190D-03	0.381D-02	0.382D-02	0.786D-01
8.00		0.264	104.	-0.866D-03	-0.441D-03	-0.798D-03	0.359D-02	0.368D-02	0.758D-01
9.00		0.873	-11.6	-0.124D-02	0.851D-03	-0.159D-02	0.671D-03	0.172D-02	0.355D-01
10.0		0.228	-22.0	0.160D-03	0.250D-03	0.240D-03	0.128D-02	0.130D-02	0.268D-01

TABLE XVI CONTD.

RUN ID H-13

COMMENTS HE FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 3 LINE APP 1/9/69

DEAD TIME= 0.800 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
0.0000-00	1.10	0.0000 00	22.6	0.0000 00	20.6	0.0000 00	1.00	20.6
0.1000-02	1.00	-0.114	1.00	-0.5070-02	1.00	-0.3080-02	1.00	20.6
0.2000-02	1.00	-0.228	1.00	-0.1010-01	1.00	-0.6170-02	1.00	20.6
0.3000-02	1.00	-0.341	1.00	-0.1520-01	1.00	-0.9250-02	1.00	20.6
0.4000-02	1.00	-0.455	1.00	-0.2030-01	1.00	-0.1230-01	1.00	20.6
0.5000-02	1.00	-0.569	1.00	-0.2530-01	1.00	-0.1540-01	1.00	20.6
0.6000-02	1.00	-0.683	0.999	-0.3040-01	1.00	-0.1850-01	1.00	20.6
0.7000-02	1.00	-0.797	0.999	-0.3550-01	1.00	-0.2160-01	1.00	20.6
0.8000-02	1.00	-0.910	0.999	-0.4050-01	0.999	-0.2470-01	1.00	20.6
0.9000-02	1.00	-1.02	0.999	-0.4560-01	0.999	-0.2770-01	1.00	20.6
0.1000-01	1.00	-1.14	0.998	-0.5060-01	0.999	-0.3080-01	1.00	20.6
0.2000-01	1.00	-2.28	0.993	-0.101	0.997	-0.6150-01	0.999	20.6
0.3000-01	1.00	-3.41	0.985	-0.151	0.993	-0.9190-01	0.997	20.5
0.4000-01	1.00	-4.55	0.974	-0.200	0.987	-0.122	0.994	20.5
0.5000-01	1.00	-5.69	0.959	-0.247	0.979	-0.151	0.991	20.4
0.6000-01	0.999	-6.83	0.942	-0.294	0.971	-0.180	0.987	20.3
0.7000-01	0.999	-7.97	0.922	-0.339	0.961	-0.208	0.983	20.3
0.8000-01	0.999	-9.11	0.899	-0.382	0.949	-0.235	0.978	20.1
0.9000-01	0.999	-10.2	0.874	-0.423	0.936	-0.261	0.972	20.0
0.100	0.998	-11.4	0.847	-0.462	0.923	-0.286	0.966	19.9
0.200	0.993	-22.7	0.506	-0.722	0.751	-0.473	0.887	18.3
0.300	0.987	-34.0	0.155	-0.779	0.572	-0.566	0.805	16.6
0.400	0.981	-45.5	-0.143	-0.705	0.411	-0.607	0.733	15.1
0.500	0.968	-57.5	-0.359	-0.534	0.266	-0.609	0.665	13.7
0.600	0.942	-69.5	-0.466	-0.322	0.147	-0.583	0.601	12.4
0.700	0.912	-80.8	-0.481	-0.125	0.5090-01	-0.543	0.545	11.2
0.800	0.887	-92.1	-0.436	0.3930-01	-0.2620-01	-0.493	0.493	10.2
0.900	0.859	-104.	-0.348	0.159	-0.8320-01	-0.438	0.445	9.18
1.00	0.824	-115.	-0.243	0.227	-0.124	-0.384	0.403	8.31

TABLE XVI

RUN ID H-13

CONTD.

OMEGA RAD/SEC	DEAD TIME*	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED				INPUT PULSE		INPUT FREQ		CONTENT	
				REAL	IMAGINARY	REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL	NORMALIZED	ACTUAL
2.00	0.800	0.468	128.	0.6370-01	-0.4250-01	-0.156	-0.5050-01	0.164	0.6730-01	3.37			
3.00		0.303	3.91	-0.1940-01	0.6230-02	-0.6250-01	0.2490-01	0.6730-01	0.6730-01	1.39			
4.00		0.237	-125.	0.7870-02	0.2260-03	-0.1990-01	0.2660-01	0.3320-01	0.3320-01	0.684			
5.00		0.408	114.	-0.2980-02	-0.4510-02	-0.7220-02	0.1110-01	0.1320-01	0.1320-01	0.273			
6.00		0.421	3.40	-0.6360-03	0.2740-02	-0.1120-02	0.6590-02	0.6690-02	0.6690-02	0.138			
7.00		0.775	-141.	0.1980-02	-0.2190-02	-0.1900-03	0.3810-02	0.3820-02	0.3820-02	0.7860-01			
8.00		0.264	97.8	-0.9120-03	-0.3370-03	-0.7980-03	0.3590-02	0.3680-02	0.3680-02	0.7580-01			
9.00		0.873	-64.1	-0.7740-04	0.1500-02	-0.1590-02	0.6710-03	0.1720-02	0.1720-02	0.3550-01			
10.0		0.228	-120.	0.2240-03	-0.1940-03	0.2400-03	0.1280-02	0.1300-02	0.1300-02	0.2680-01			

TABLE XVII

KUN ID H-14

COMMENTS HE FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 3 LINE APP 1/9/69

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT REAL	PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY				
0.0000 00	0.927	0.0000 00	21.4	0.0000 00	23.1	0.0000 00	1.00	23.1
0.1000-02	1.00	-0.5540-01	1.00	-0.4120-02	1.00	-0.3160-02	1.00	23.1
0.2000-02	1.00	-0.111	1.00	-0.8240-02	1.00	-0.6310-02	1.00	23.1
0.3000-02	1.00	-0.166	1.00	-0.1240-01	1.00	-0.9470-02	1.00	23.1
0.4000-02	1.00	-0.221	1.00	-0.1650-01	1.00	-0.1260-01	1.00	23.1
0.5000-02	1.00	-0.277	1.00	-0.2060-01	1.00	-0.1580-01	1.00	23.1
0.6000-02	1.00	-0.332	1.00	-0.2470-01	1.00	-0.1890-01	1.00	23.1
0.7000-02	1.00	-0.388	0.999	-0.2880-01	1.00	-0.2210-01	1.00	23.1
0.8000-02	1.00	-0.443	0.999	-0.3300-01	0.999	-0.2520-01	1.00	23.1
0.9000-02	1.00	-0.498	0.999	-0.3710-01	0.999	-0.2840-01	1.00	23.1
0.1000-01	1.00	-0.554	0.999	-0.4120-01	0.999	-0.3150-01	1.00	23.1
0.2000-01	1.00	-1.11	0.995	-0.8220-01	0.996	-0.6290-01	0.998	23.1
0.3000-01	1.00	-1.66	0.989	-0.123	0.992	-0.9400-01	0.996	23.0
0.4000-01	1.00	-2.22	0.981	-0.163	0.986	-0.125	0.994	23.0
0.5000-01	1.00	-2.78	0.970	-0.202	0.978	-0.155	0.990	22.9
0.6000-01	1.00	-3.34	0.957	-0.240	0.969	-0.184	0.986	22.8
0.7000-01	1.00	-3.90	0.942	-0.277	0.958	-0.212	0.981	22.7
0.8000-01	1.00	-4.47	0.925	-0.313	0.946	-0.239	0.976	22.6
0.9000-01	1.00	-5.03	0.907	-0.347	0.933	-0.266	0.970	22.4
0.100	1.00	-5.61	0.886	-0.380	0.918	-0.291	0.963	22.3
0.200	1.00	-11.6	0.631	-0.614	0.741	-0.475	0.880	20.4
0.300	0.989	-17.8	0.360	-0.702	0.563	-0.565	0.798	18.4
0.400	0.970	-23.9	0.119	-0.695	0.402	-0.605	0.727	16.8
0.500	0.949	-29.9	-0.7530-01	-0.617	0.255	-0.604	0.656	15.2
0.600	0.923	-36.2	-0.208	-0.501	0.138	-0.571	0.588	13.6
0.700	0.884	-42.6	-0.285	-0.374	0.4880-01	-0.530	0.532	12.3
0.800	0.839	-48.4	-0.316	-0.253	-0.2410-01	-0.482	0.482	11.1
0.900	0.799	-53.9	-0.314	-0.151	-0.7850-01	-0.429	0.436	10.1
1.00	0.756	-60.0	-0.292	-0.6640-01	-0.117	-0.378	0.396	9.15

TABLE XVII

RUN ID H-14

CONTD.

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ		CONTENT	
			REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	NORMALIZED	ACTUAL	ACTUAL
2.00	0.246	-111.	0.276D-02	0.402D-01	-0.157	-0.466D-01	0.163	0.163	3.78	3.78
3.00	0.137	25.3	-0.958D-02	-0.545D-03	-0.648D-01	0.262D-01	0.698D-01	0.698D-01	1.61	1.61
4.00	0.331	-26.0	-0.254D-02	0.104D-01	-0.207D-01	0.248D-01	0.323D-01	0.323D-01	0.747	0.747
5.00	0.338	-86.6	0.416D-02	0.244D-02	-0.649D-02	0.127D-01	0.143D-01	0.143D-01	0.330	0.330
6.00	0.307	-161.	0.156D-02	-0.222D-02	-0.237D-02	0.853D-02	0.885D-02	0.885D-02	0.205	0.205
7.00	0.625	116.	-0.256D-02	-0.138D-02	-0.195D-03	0.465D-02	0.465D-02	0.465D-02	0.107	0.107
8.00	0.585	45.0	-0.104D-02	0.152D-02	0.582D-03	0.309D-02	0.315D-02	0.315D-02	0.728D-01	0.728D-01
9.00	0.766	-63.1	0.125D-02	0.856D-03	-0.256D-03	0.196D-02	0.198D-02	0.198D-02	0.458D-01	0.458D-01
10.0	0.442	-175.	0.889D-04	-0.852D-03	-0.172D-04	0.194D-02	0.194D-02	0.194D-02	0.448D-01	0.448D-01

TABLE XVII CONTD.

RUN ID H-14

COMMENTS HE FLUIDIZED RED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 3 LINE APP 1/9/69

DEAD TIME= 0.800 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	0.927	0.0000 00	21.4	0.0000 00	23.1	0.0000 00	1.00	23.1
0.1000-02	1.00	-0.101	1.00	-0.4920-02	1.00	-0.3160-02	1.00	23.1
0.2000-02	1.00	-0.202	1.00	-0.9840-02	1.00	-0.6310-02	1.00	23.1
0.3000-02	1.00	-0.304	1.00	-0.1480-01	1.00	-0.9470-02	1.00	23.1
0.4000-02	1.00	-0.405	1.00	-0.1970-01	1.00	-0.1260-01	1.00	23.1
0.5000-02	1.00	-0.506	1.00	-0.2460-01	1.00	-0.1580-01	1.00	23.1
0.6000-02	1.00	-0.607	0.999	-0.2950-01	1.00	-0.1890-01	1.00	23.1
0.7000-02	1.00	-0.708	0.999	-0.3440-01	1.00	-0.2210-01	1.00	23.1
0.8000-02	1.00	-0.810	0.999	-0.3940-01	0.999	-0.2520-01	1.00	23.1
0.9000-02	1.00	-0.911	0.999	-0.4430-01	0.999	-0.2840-01	1.00	23.1
0.1000-01	1.00	-1.01	0.998	-0.4920-01	0.999	-0.3150-01	1.00	23.1
0.2000-01	1.00	-2.02	0.994	-0.9810-01	0.996	-0.6290-01	0.998	23.1
0.3000-01	1.00	-3.04	0.986	-0.146	0.992	-0.9400-01	0.996	23.0
0.4000-01	1.00	-4.05	0.975	-0.194	0.986	-0.125	0.994	23.0
0.5000-01	1.00	-5.07	0.961	-0.240	0.978	-0.155	0.990	22.9
0.6000-01	1.00	-6.09	0.944	-0.286	0.969	-0.184	0.986	22.8
0.7000-01	1.00	-7.11	0.925	-0.329	0.958	-0.212	0.981	22.7
0.8000-01	1.00	-8.13	0.903	-0.371	0.946	-0.239	0.976	22.6
0.9000-01	1.00	-9.16	0.879	-0.411	0.933	-0.266	0.970	22.4
0.100	1.00	-10.2	0.853	-0.449	0.918	-0.291	0.963	22.3
0.200	1.00	-20.7	0.525	-0.707	0.741	-0.475	0.880	20.4
0.300	0.989	-31.5	0.183	-0.768	0.563	-0.565	0.798	18.4
0.400	0.970	-42.2	-0.106	-0.697	0.402	-0.605	0.727	16.8
0.500	0.949	-52.8	-0.310	-0.539	0.255	-0.604	0.656	15.2
0.600	0.923	-63.7	-0.416	-0.348	0.138	-0.571	0.588	13.6
0.700	0.884	-74.7	-0.440	-0.165	0.4880-01	-0.530	0.532	12.3
0.800	0.839	-85.0	-0.404	-0.1470-01	-0.2410-01	-0.482	0.482	11.1
0.900	0.799	-95.2	-0.335	0.9340-01	-0.7850-01	-0.429	0.436	10.1
1.00	0.756	-106.	-0.251	0.163	-0.117	-0.378	0.396	9.15



TABLE XVII

KUN ID H-14

CONTD.

OMEGA RAD/SEC	DEAD TIME=	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NDRHALIZED		INPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
				REAL	IMAGINARY	REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00	0.800	0.246	158.	0.401D-01	-0.393D-02	-0.157	-0.466D-01	0.163	0.698D-01	0.163	3.78
3.00		0.137	-112.	0.670D-02	0.687D-02	-0.646D-01	0.262D-01	0.323D-01	0.698D-01	0.323D-01	1.61
4.00		0.331	151.	0.193D-02	-0.105D-01	-0.207D-01	0.248D-01	0.143D-01	0.323D-01	0.143D-01	0.747
5.00		0.338	44.2	-0.457D-02	0.155D-02	-0.649D-02	0.127D-01	0.885D-02	0.323D-01	0.143D-01	0.330
6.00		0.307	-75.5	0.235D-02	0.136D-02	-0.237D-02	0.853D-02	0.465D-02	0.885D-02	0.465D-02	0.205
7.00		0.625	155.	-0.111D-02	-0.269D-02	-0.195D-03	0.465D-02	0.309D-02	0.465D-02	0.315D-02	0.728D-01
8.00		0.585	38.4	-0.856D-03	0.163D-02	0.582D-03	0.309D-02	0.196D-02	0.315D-02	0.196D-02	0.458D-01
9.00		0.766	-116.	0.144D-02	-0.473D-03	-0.256D-03	0.196D-02	0.194D-02	0.196D-02	0.194D-02	0.448D-01
10.0		0.442	87.1	-0.856D-03	0.361D-04	-0.172D-04	0.194D-02	0.194D-02	0.194D-02	0.194D-02	0.448D-01

TABLE XVIII

RUN ID H-15

COMMENTS HE FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CM SMP LOOP 2 LINE APP 1/22/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
0.0000 00	1.09	0.0000 00	59.0	0.0000 00	54.3	0.0000 00	1.00	54.3
0.1000-02	1.00	-0.2350-01	1.00	-0.3480-02	1.00	-0.3070-02	1.00	54.3
0.2000-02	1.00	-0.4700-01	1.00	-0.6950-02	1.00	-0.6130-02	1.00	54.3
0.3000-02	1.00	-0.7050-01	1.00	-0.1040-01	1.00	-0.9200-02	1.00	54.3
0.4000-02	1.00	-0.9400-01	1.00	-0.1390-01	1.00	-0.1230-01	1.00	54.3
0.5000-02	1.00	-0.118	1.00	-0.1740-01	1.00	-0.1530-01	1.00	54.3
0.6000-02	1.00	-0.141	1.00	-0.2090-01	1.00	-0.1840-01	1.00	54.3
0.7000-02	1.00	-0.165	1.00	-0.2430-01	1.00	-0.2150-01	1.00	54.3
0.8000-02	1.00	-0.188	0.999	-0.2780-01	0.999	-0.2450-01	1.00	54.3
0.9000-02	1.00	-0.212	0.999	-0.3130-01	0.999	-0.2760-01	1.00	54.3
0.1000-01	1.00	-0.235	0.999	-0.3470-01	0.999	-0.3060-01	1.00	54.3
0.2000-01	1.00	-0.471	0.996	-0.6940-01	0.997	-0.6120-01	0.999	54.2
0.3000-01	1.00	-0.707	0.992	-0.104	0.993	-0.9140-01	0.997	54.1
0.4000-01	1.00	-0.945	0.986	-0.138	0.987	-0.121	0.995	54.0
0.5000-01	1.00	-1.18	0.978	-0.171	0.981	-0.151	0.992	53.9
0.6000-01	1.00	-1.43	0.969	-0.204	0.972	-0.180	0.989	53.7
0.7000-01	1.00	-1.67	0.958	-0.236	0.962	-0.208	0.985	53.5
0.8000-01	1.00	-1.92	0.946	-0.268	0.951	-0.235	0.980	53.2
0.9000-01	1.00	-2.17	0.932	-0.298	0.939	-0.262	0.975	52.9
0.100	1.00	-2.42	0.917	-0.328	0.926	-0.288	0.969	52.6
0.200	1.02	-5.30	0.712	-0.560	0.749	-0.483	0.891	48.4
0.300	1.03	-8.97	0.472	-0.671	0.556	-0.573	0.798	43.4
0.400	1.03	-13.3	0.250	-0.690	0.391	-0.598	0.715	38.8
0.500	1.01	-17.6	0.6400-01	-0.645	0.254	-0.591	0.644	35.0
0.600	0.979	-21.5	-0.7320-01	-0.561	0.141	-0.560	0.578	31.4
0.700	0.948	-25.2	-0.162	-0.464	0.5390-01	-0.515	0.518	28.1
0.800	0.911	-28.6	-0.213	-0.370	-0.1080-01	-0.468	0.468	25.4
0.900	0.870	-31.7	-0.238	-0.284	-0.6200-01	-0.421	0.426	23.1
1.00	0.830	-34.4	-0.244	-0.208	-0.101	-0.373	0.387	21.0

TABLE XVIII

RUN ID H-15

CONTD.

OMEGA RAD/SEC	DEAD TIME= 0.0000 00	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
				REAL	IMAGINARY	REAL	IMAGINARY		
2.00		0.500	-42.3	-0.730D-01	0.277D-01	-0.145	-0.572D-01	0.156	8.48
3.00		0.423	-31.9	-0.201D-01	0.193D-01	-0.644D-01	0.136D-01	0.659D-01	3.58
4.00		0.498	-32.1	-0.555D-02	0.142D-01	-0.246D-01	0.182D-01	0.306D-01	1.66
5.00		0.447	-52.4	0.982D-03	0.605D-02	-0.939D-02	0.999D-02	0.137D-01	0.744
6.00		0.337	-59.4	0.124D-02	0.217D-02	-0.367D-02	0.645D-02	0.742D-02	0.403
7.00		0.217	67.9	-0.102D-02	-0.249D-03	-0.282D-02	0.391D-02	0.482D-02	0.262
8.00		0.705	2.94	-0.712D-03	0.178D-02	-0.879D-03	0.257D-02	0.272D-02	0.148
9.00		0.738	-63.4	0.947D-04	0.143D-02	-0.168D-02	0.984D-03	0.195D-02	0.106
10.0		0.449	-58.2	0.573D-03	0.881D-03	-0.998D-03	0.212D-02	0.234D-02	0.127

TABLE XVIII CONTD.

RUN ID H-15

COMMENTS HE FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CM SMP LOOP 2 LINE APP 1/22/69

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	1.09	0.0000 00	59.0	0.0000 00	54.3	0.0000 00	1.00	54.3
0.1000-02	1.00	-0.7510-01	1.00	-0.4380-02	1.00	-0.3070-02	1.00	54.3
0.2000-02	1.00	-0.150	1.00	-0.8750-02	1.00	-0.6130-02	1.00	54.3
0.3000-02	1.00	-0.225	1.00	-0.1310-01	1.00	-0.9200-02	1.00	54.3
0.4000-02	1.00	-0.300	1.00	-0.1750-01	1.00	-0.1230-01	1.00	54.3
0.5000-02	1.00	-0.375	1.00	-0.2190-01	1.00	-0.1530-01	1.00	54.3
0.6000-02	1.00	-0.450	1.00	-0.2630-01	1.00	-0.1840-01	1.00	54.3
0.7000-02	1.00	-0.526	0.999	-0.3060-01	1.00	-0.2150-01	1.00	54.3
0.8000-02	1.00	-0.601	0.999	-0.3500-01	0.999	-0.2450-01	1.00	54.3
0.9000-02	1.00	-0.676	0.999	-0.3940-01	0.999	-0.2760-01	1.00	54.3
0.1000-01	1.00	-0.751	0.999	-0.4370-01	0.999	-0.3060-01	1.00	54.3
0.2000-01	1.00	-1.50	0.995	-0.8730-01	0.997	-0.6120-01	0.999	54.2
0.3000-01	1.00	-2.25	0.989	-0.130	0.987	-0.9140-01	0.997	54.1
0.4000-01	1.00	-3.01	0.980	-0.173	0.987	-0.121	0.995	54.0
0.5000-01	1.00	-3.76	0.970	-0.215	0.981	-0.151	0.992	53.9
0.6000-01	1.00	-4.52	0.957	-0.256	0.972	-0.180	0.989	53.7
0.7000-01	1.00	-5.28	0.941	-0.296	0.962	-0.208	0.985	53.5
0.8000-01	1.00	-6.04	0.924	-0.335	0.951	-0.235	0.980	53.2
0.9000-01	1.00	-6.81	0.905	-0.373	0.939	-0.262	0.975	52.9
0.100	1.00	-7.58	0.884	-0.409	0.926	-0.288	0.969	52.6
0.200	1.02	-15.6	0.601	-0.678	0.749	-0.483	0.891	48.4
0.300	1.03	-24.4	0.276	-0.772	0.556	-0.573	0.798	43.4
0.400	1.03	-33.9	-0.9420-02	-0.733	0.391	-0.598	0.715	38.8
0.500	1.01	-43.4	-0.223	-0.609	0.254	-0.591	0.644	35.0
0.600	0.979	-52.5	-0.351	-0.444	0.141	-0.560	0.578	31.4
0.700	0.948	-61.3	-0.404	-0.280	0.5390-01	-0.515	0.518	28.1
0.800	0.911	-69.9	-0.404	-0.137	-0.1080-01	-0.468	0.468	25.4
0.900	0.870	-78.1	-0.370	-0.2290-01	-0.6200-01	-0.421	0.426	23.1
1.00	0.830	-85.9	-0.315	0.6180-01	-0.101	-0.373	0.387	21.0

TABLE XVIII

RUN ID H-15

CONTO.

OMEGA RAD/SEC	DEAD TIME	0.900	PULSES NORMALIZED						INPUT FREQ CONTENT	
			AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT REAL	PULSE IMAGINARY	INPUT REAL	PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
2.00	0.500	-145.	0.4350-01	0.6480-01	-0.145	-0.5720-01	0.156	8.48		
3.00	0.423	173.	0.2640-01	-0.8860-02	-0.6440-01	0.1360-01	0.6590-01	3.58		
4.00	0.498	122.	-0.1300-02	-0.1520-01	-0.2460-01	0.1820-01	0.3060-01	1.66		
5.00	0.447	49.7	-0.6120-02	-0.3150-03	-0.9390-02	0.9990-02	0.1370-01	0.744		
6.00	0.337	-8.79	-0.8920-03	0.2340-02	-0.3670-02	0.6450-02	0.7420-02	0.403		
7.00	0.217	67.0	-0.1020-02	-0.2320-03	-0.2820-02	0.3910-02	0.4820-02	0.262		
8.00	0.705	-49.6	0.9800-03	0.1650-02	-0.8790-03	0.2570-02	0.2720-02	0.148		
9.00	0.738	-168.	0.1370-02	-0.4410-03	-0.1680-02	0.9840-03	0.1950-02	0.106		
10.0	0.449	146.	-0.1590-03	-0.1040-02	-0.9980-03	0.2120-02	0.2340-02	0.127		

TABLE XIX

RUN ID H-17

COMMENTS HE FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CM SMP LOOP 3 LINE APP 1/22/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	0.924	0.0000 00	18.9	0.0000 00	20.5	0.0000 00	1.00	20.5
0.1000 02	1.00	-0.2500 01	1.00	-0.3430 02	1.00	-0.2990 02	1.00	20.5
0.2000 02	1.00	-0.5000 01	1.00	-0.6850 02	1.00	-0.5980 02	1.00	20.5
0.3000 02	1.00	-0.7490 01	1.00	-0.1030 01	1.00	-0.8970 02	1.00	20.5
0.4000 02	1.00	-0.9990 01	1.00	-0.1370 01	1.00	-0.1200 01	1.00	20.5
0.5000 02	1.00	-0.125	1.00	-0.1710 01	1.00	-0.1500 01	1.00	20.5
0.6000 02	1.00	-0.150	1.00	-0.2060 01	1.00	-0.1790 01	1.00	20.5
0.7000 02	1.00	-0.175	1.00	-0.2400 01	1.00	-0.2090 01	1.00	20.5
0.8000 02	1.00	-0.200	0.999	-0.2740 01	1.00	-0.2390 01	1.00	20.5
0.9000 02	1.00	-0.225	0.999	-0.3080 01	0.999	-0.2690 01	1.00	20.5
0.1000 01	1.00	-0.250	0.999	-0.3430 01	0.999	-0.2990 01	1.00	20.5
0.2000 01	1.00	-0.501	0.997	-0.6840 01	0.997	-0.5970 01	0.999	20.4
0.3000 01	1.00	-0.754	0.993	-0.102	0.993	-0.8920 01	0.997	20.4
0.4000 01	1.00	-1.01	0.987	-0.136	0.988	-0.118	0.995	20.4
0.5000 01	1.00	-1.27	0.980	-0.169	0.981	-0.147	0.992	20.3
0.6000 01	1.00	-1.54	0.971	-0.202	0.973	-0.175	0.989	20.2
0.7000 01	1.00	-1.81	0.961	-0.234	0.964	-0.203	0.985	20.1
0.8000 01	1.01	-2.09	0.949	-0.265	0.953	-0.229	0.980	20.1
0.9000 01	1.01	-2.38	0.936	-0.296	0.941	-0.255	0.975	19.9
0.100	1.01	-2.68	0.921	-0.326	0.928	-0.280	0.970	19.8
0.200	1.02	-6.22	0.721	-0.565	0.761	-0.472	0.895	18.3
0.300	1.03	-10.6	0.477	-0.684	0.577	-0.568	0.810	16.6
0.400	1.02	-14.8	0.249	-0.703	0.413	-0.605	0.732	15.0
0.500	1.01	-18.6	0.6360 01	-0.662	0.270	-0.602	0.660	13.5
0.600	0.998	-22.8	-0.7890 01	-0.585	0.154	-0.571	0.591	12.1
0.700	0.977	-27.2	-0.179	-0.489	0.6560 01	-0.529	0.533	10.9
0.800	0.944	-31.1	-0.239	-0.389	-0.4320 02	-0.484	0.484	9.89
0.900	0.913	-34.3	-0.268	-0.297	-0.5910 01	-0.434	0.438	8.96
1.000	0.886	-37.6	-0.277	-0.217	-0.9850 01	-0.385	0.397	8.13

TABLE XIX

KUN 1D H-17

CONTO.

DEAD TIME= 0.0000 00 PULSES NORMALIZED		OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
OMEGA RAU/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	REAL	IMAGINARY	REAL	IMAGINARY	ACTUAL
2.00	0.630	-61.4	-0.7920-01	0.6270-01	-0.148	-0.6250-01	3.28
3.00	0.487	-79.4	-0.9120-03	0.3340-01	-0.6790-01	0.1070-01	1.41
4.00	0.396	-98.9	0.8680-02	0.8880-02	-0.2560-01	0.1820-01	0.642
5.00	0.239	-137.	0.3540-02	0.5720-04	-0.1110-01	0.9850-02	0.303
6.00	0.341	-158.	0.2560-02	-0.1290-02	-0.5560-02	0.6280-02	0.172
7.00	0.470	118.	-0.7020-03	-0.2390-02	-0.3770-02	0.3740-02	0.109
8.00	0.515	62.6	-0.1500-02	0.2080-03	-0.9820-03	0.2770-02	0.6020-01
9.00	0.264	19.0	-0.4890-03	0.2180-03	-0.1490-02	0.1390-02	0.4160-01
10.0	0.260	22.0	-0.3740-03	0.3630-03	-0.8100-03	0.1830-02	0.4100-01

TABLE XIX CONTD.

KUN ID H-17

COMMENTS HE FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CM SMP LOOP 3 LINE APP 1/22/69

DEAD TIME= 0.800 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	0.924	0.0000 00	18.9	0.0000 00	20.5	0.0000 00	1.00	20.5
0.1000-02	1.00	-0.7080-01	1.00	-0.4230-02	1.00	-0.2990-02	1.00	20.5
0.2000-02	1.00	-0.142	1.00	-0.8450-02	1.00	-0.5980-02	1.00	20.5
0.3000-02	1.00	-0.212	1.00	-0.1270-01	1.00	-0.8970-02	1.00	20.5
0.4000-02	1.00	-0.283	1.00	-0.1690-01	1.00	-0.1200-01	1.00	20.5
0.5000-02	1.00	-0.354	1.00	-0.2110-01	1.00	-0.1500-01	1.00	20.5
0.6000-02	1.00	-0.425	1.00	-0.2540-01	1.00	-0.1790-01	1.00	20.5
0.7000-02	1.00	-0.496	0.999	-0.2960-01	1.00	-0.2090-01	1.00	20.5
0.8000-02	1.00	-0.567	0.999	-0.3380-01	1.00	-0.2390-01	1.00	20.5
0.9000-02	1.00	-0.637	0.999	-0.3800-01	0.999	-0.2690-01	1.00	20.5
0.1000-01	1.00	-0.708	0.999	-0.4220-01	0.999	-0.2990-01	1.00	20.5
0.2000-01	1.00	-1.42	0.996	-0.8430-01	0.997	-0.5970-01	0.999	20.4
0.3000-01	1.00	-2.13	0.990	-0.126	0.993	-0.8920-01	0.997	20.4
0.4000-01	1.00	-2.84	0.982	-0.167	0.988	-0.118	0.995	20.4
0.5000-01	1.00	-3.56	0.972	-0.208	0.981	-0.147	0.992	20.3
0.6000-01	1.00	-4.29	0.960	-0.248	0.973	-0.175	0.989	20.2
0.7000-01	1.00	-5.02	0.946	-0.287	0.964	-0.203	0.985	20.1
0.8000-01	1.01	-5.76	0.930	-0.326	0.953	-0.229	0.980	20.1
0.9000-01	1.01	-6.51	0.912	-0.363	0.941	-0.255	0.975	19.9
0.100	1.01	-7.26	0.892	-0.398	0.928	-0.280	0.970	19.8
0.200	1.02	-15.4	0.622	-0.673	0.761	-0.472	0.895	18.3
0.300	1.03	-24.3	0.301	-0.777	0.577	-0.568	0.810	16.6
0.400	1.02	-33.1	0.1560-01	-0.746	0.413	-0.605	0.732	15.0
0.500	1.01	-41.6	-0.199	-0.634	0.270	-0.602	0.660	13.5
0.600	0.998	-50.3	-0.340	-0.482	0.154	-0.571	0.591	12.1
0.700	0.977	-59.3	-0.411	-0.319	-0.6560-01	-0.529	0.533	10.9
0.800	0.944	-67.7	-0.424	-0.169	-0.4320-02	-0.484	0.484	9.89
0.900	0.913	-75.6	-0.397	-0.4640-01	-0.5910-01	-0.434	0.438	8.96
1.000	0.886	-83.4	-0.349	0.4740-01	-0.9850-01	-0.385	0.397	8.13



TABLE XIX

RUN ID H-17

CONTD.

OMEGA RAD/SEC	DEAD TIME	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED				INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
				OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY				
2.00	0.800	0.630	-153.	0.6500-01	0.7730-01	-0.148	-0.6250-01	0.160	3.28		
3.00		0.487	143.	0.2320-01	-0.2400-01	-0.6790-01	0.1070-01	0.6870-01	1.41		
4.00		0.396	77.8	-0.9190-02	-0.8360-02	-0.2560-01	0.1820-01	0.3140-01	0.642		
5.00		0.239	-6.61	-0.2360-02	0.2640-02	-0.1110-01	0.9850-02	0.1480-01	0.303		
6.00		0.341	-73.3	0.1510-02	0.2430-02	-0.5560-02	0.6280-02	0.8390-02	0.172		
7.00		0.470	158.	0.9660-03	-0.2300-02	-0.3770-02	0.3740-02	0.5310-02	0.109		
8.00		0.515	55.9	-0.1470-02	0.3810-03	-0.9820-03	0.2770-02	0.2940-02	0.6020-01		
9.00		0.264	-33.6	-0.1250-03	0.5210-03	-0.1490-02	0.1390-02	0.2030-02	0.4160-01		
10.0		0.260	-76.4	0.4140-03	0.3170-03	-0.8100-03	0.1830-02	0.2000-02	0.4100-01		

TABLE XX

KUN ID H-19

COMMENTS HE FLUIDIZED BED HT 7 5/8 IN AIR RATE 8.0 CH SMP LOOP 3 LINE APP 1/22/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000-00	1.03	0.0000 00	12.7	0.0000 00	12.3	0.0000 00	1.00	12.3
0.1000-02	1.00	0.2090-02	1.00	-0.2890-02	1.00	-0.2930-02	1.00	12.3
0.2000-02	1.00	0.4190-02	1.00	-0.5780-02	1.00	-0.5850-02	1.00	12.3
0.3000-02	1.00	0.6280-02	1.00	-0.8670-02	1.00	-0.8780-02	1.00	12.3
0.4000-02	1.00	0.8370-02	1.00	-0.1160-01	1.00	-0.1170-01	1.00	12.3
0.5000-02	1.00	0.1050-01	1.00	-0.1450-01	1.00	-0.1460-01	1.00	12.3
0.6000-02	1.00	0.1250-01	1.00	-0.1730-01	1.00	-0.1760-01	1.00	12.3
0.7000-02	1.00	0.1460-01	1.00	-0.2020-01	1.00	-0.2050-01	1.00	12.3
0.8000-02	1.00	0.1670-01	1.00	-0.2310-01	1.00	-0.2340-01	1.00	12.3
0.9000-02	1.00	0.1880-01	1.00	-0.2600-01	0.999	-0.2630-01	1.00	12.3
0.1000-01	1.00	0.2080-01	0.999	-0.2890-01	0.999	-0.2930-01	1.00	12.3
0.2000-01	1.00	0.4080-01	0.998	-0.5770-01	0.997	-0.5840-01	0.999	12.3
0.3000-01	1.00	0.5920-01	0.995	-0.8640-01	0.994	-0.8740-01	0.998	12.3
0.4000-01	1.00	0.7520-01	0.990	-0.115	0.989	-0.116	0.996	12.3
0.5000-01	1.00	0.8810-01	0.985	-0.143	0.983	-0.144	0.993	12.2
0.6000-01	1.00	0.9700-01	0.979	-0.171	0.975	-0.172	0.990	12.2
0.7000-01	1.00	0.101	0.971	-0.199	0.967	-0.200	0.987	12.2
0.8000-01	1.01	0.100	0.962	-0.226	0.957	-0.226	0.983	12.1
0.9000-01	1.01	0.9270-01	0.953	-0.252	0.946	-0.252	0.979	12.1
0.100	1.01	0.7870-01	0.942	-0.278	0.934	-0.277	0.974	12.0
0.200	1.03	-0.548	0.787	-0.499	0.769	-0.478	0.906	11.2
0.300	1.05	-2.18	0.583	-0.631	0.578	-0.579	0.818	10.1
0.400	1.06	-4.43	0.379	-0.677	0.407	-0.610	0.733	9.03
0.500	1.05	-6.58	0.206	-0.661	0.267	-0.602	0.658	8.11
0.600	1.04	-8.37	0.7180-01	-0.614	0.154	-0.572	0.593	7.30
0.700	1.03	-10.1	-0.3010-01	-0.552	0.6550-01	-0.531	0.535	6.59
0.800	1.02	-12.0	-0.106	-0.483	-0.3020-02	-0.487	0.487	6.00
0.900	0.991	-13.6	-0.160	-0.412	-0.5890-01	-0.442	0.446	5.49
1.000	0.965	-14.6	-0.193	-0.342	-0.104	-0.394	0.407	5.02

TABLE XX

RUN ID H-19

CONTD.

OMEGA RAD/SEC	DEAD TIME*	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
				REAL	IMAGINARY	REAL	IMAGINARY		
2.00	0.0000 00	0.812	-20.5	-0.137	-0.553D-03	-0.157	-0.594D-01	0.168	2.07
3.00		0.614	-20.3	-0.386D-01	0.302D-01	-0.760D-01	0.243D-01	0.798D-01	0.983
4.00		0.504	-16.2	-0.685D-02	0.184D-01	-0.233D-01	0.312D-01	0.389D-01	0.480
5.00		0.337	21.6	-0.251D-02	0.557D-02	-0.854D-03	0.181D-01	0.181D-01	0.224
6.00		0.389	60.1	-0.157D-02	0.459D-02	0.822D-02	0.937D-02	0.125D-01	0.154
7.00		0.222	165.	-0.191D-02	0.808D-03	0.925D-02	-0.122D-02	0.933D-02	0.115
8.00		0.183	174.	-0.119D-02	0.154D-02	0.741D-02	-0.766D-02	0.107D-01	0.131
9.00		0.151	-137.	-0.107D-02	0.116D-02	-0.812D-04	-0.104D-01	0.104D-01	0.128
10.0		0.108	-137.	-0.339D-03	0.104D-02	-0.422D-02	-0.914D-02	0.101D-01	0.124

TABLE XX CONTD.

KUN ID H-19

COMMENTS HE FLUIDIZED BED HT 7 5/8 IN AIR RATE 8.0 CM SMP LOOP 3 LINE APP 1/22/69

DEAD TIME= 0.850 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000-00	1.03	0.0000-00	12.7	0.0000-00	12.3	0.0000-00	1.00	12.3
0.1000-02	1.00	-0.4660-01	1.00	-0.3740-02	1.00	-0.2930-02	1.00	12.3
0.2000-02	1.00	-0.9320-01	1.00	-0.7480-02	1.00	-0.5850-02	1.00	12.3
0.3000-02	1.00	-0.140	1.00	-0.1120-01	1.00	-0.8780-02	1.00	12.3
0.4000-02	1.00	-0.186	1.00	-0.1500-01	1.00	-0.1170-01	1.00	12.3
0.5000-02	1.00	-0.233	1.00	-0.1670-01	1.00	-0.1460-01	1.00	12.3
0.6000-02	1.00	-0.280	1.00	-0.2240-01	1.00	-0.1760-01	1.00	12.3
0.7000-02	1.00	-0.326	1.00	-0.2620-01	1.00	-0.2050-01	1.00	12.3
0.8000-02	1.00	-0.373	0.999	-0.2990-01	1.00	-0.2340-01	1.00	12.3
0.9000-02	1.00	-0.420	0.999	-0.3370-01	0.999	-0.2630-01	1.00	12.3
0.1000-01	1.00	-0.466	0.999	-0.3740-01	0.999	-0.2930-01	1.00	12.3
0.2000-01	1.00	-0.933	0.996	-0.7470-01	0.997	-0.5840-01	0.999	12.3
0.3000-01	1.00	-1.40	0.992	-0.112	0.994	-0.8740-01	0.998	12.3
0.4000-01	1.00	-1.87	0.986	-0.149	0.989	-0.116	0.996	12.3
0.5000-01	1.00	-2.35	0.978	-0.185	0.983	-0.144	0.993	12.2
0.6000-01	1.00	-2.83	0.969	-0.221	0.975	-0.172	0.990	12.2
0.7000-01	1.00	-3.31	0.958	-0.256	0.967	-0.200	0.987	12.2
0.8000-01	1.01	-3.80	0.945	-0.291	0.957	-0.226	0.983	12.1
0.9000-01	1.01	-4.29	0.931	-0.324	0.946	-0.252	0.979	12.1
0.100	1.01	-4.79	0.915	-0.357	0.934	-0.277	0.974	12.0
0.200	1.03	-10.3	0.691	-0.625	0.769	-0.478	0.906	11.2
0.300	1.05	-16.8	0.405	-0.758	0.578	-0.579	0.818	10.1
0.400	1.06	-23.9	0.132	-0.764	0.407	-0.610	0.733	9.03
0.500	1.05	-30.9	-0.8480-01	-0.688	0.267	-0.602	0.658	8.11
0.600	1.04	-37.6	-0.237	-0.571	0.154	-0.572	0.593	7.30
0.700	1.03	-44.2	-0.334	-0.440	0.6550-01	-0.531	0.535	6.59
0.800	1.02	-51.0	-0.387	-0.309	-0.3020-02	-0.487	0.487	6.00
0.900	0.991	-57.5	-0.401	-0.186	-0.5890-01	-0.442	0.446	5.49
1.000	0.965	-63.3	-0.384	-0.8120-01	-0.104	-0.394	0.407	5.02

TABLE XX

RUN ID H-19

CONTD.

OMEGA RAD/SEC	DEAD TIME	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	INPUT FREQ CONTENT	ACTUAL
				OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY					
2.00	0.850	0.812	-118.	0.1700-01	0.135	-0.157	-0.5940-01	0.168	2.07	0.983
3.00		0.614	-166.	0.4890-01	-0.3520-02	-0.7600-01	0.2430-01	0.7980-01	0.983	0.480
4.00		0.504	149.	0.1920-02	-0.1950-01	-0.2330-01	0.3120-01	0.3890-01	0.480	0.224
5.00		0.337	138.	-0.3860-02	-0.4730-02	-0.8540-03	0.1810-01	0.1810-01	0.224	0.154
6.00		0.389	128.	-0.4840-02	0.2840-03	0.8220-02	0.9370-02	0.1250-01	0.154	0.131
7.00		0.222	-176.	-0.2070-02	0.1380-03	0.9250-02	-0.1220-02	0.9330-02	0.131	0.128
8.00		0.183	144.	-0.2750-03	0.1930-02	0.7410-02	-0.7660-02	0.1070-01	0.128	0.124
9.00		0.151	145.	0.9180-03	0.1280-02	-0.8120-04	-0.1040-01	0.1040-01	0.124	
10.0		0.108	95.9	0.1030-02	-0.3530-03	-0.4220-02	-0.9140-02	0.1010-01	0.124	

TABLE XXI

RUN ID H-21

COMMENTS HE FLUIDIZED BED HT 7 5/8 IN AIR RATE 8.0 CM SMP LOOP 4 LINE APP 1/22/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	1.14	0.0000 00	19.3	0.0000 00	16.9	0.0000 00	1.00	16.9
0.1000-02	1.00	-0.1230-01	1.00	-0.3190-02	1.00	-0.2980-02	1.00	16.9
0.2000-02	1.00	-0.2450-01	1.00	-0.6390-02	1.00	-0.5960-02	1.00	16.9
0.3000-02	1.00	-0.3680-01	1.00	-0.9580-02	1.00	-0.8940-02	1.00	16.9
0.4000-02	1.00	-0.4900-01	1.00	-0.1280-01	1.00	-0.1190-01	1.00	16.9
0.5000-02	1.00	-0.6130-01	1.00	-0.1600-01	1.00	-0.1490-01	1.00	16.9
0.6000-02	1.00	-0.7350-01	1.00	-0.1920-01	1.00	-0.1790-01	1.00	16.9
0.7000-02	1.00	-0.8580-01	1.00	-0.2240-01	1.00	-0.2090-01	1.00	16.9
0.8000-02	1.00	-0.9810-01	1.00	-0.2560-01	1.00	-0.2380-01	1.00	16.9
0.9000-02	1.00	-0.110	0.999	-0.2870-01	0.999	-0.2680-01	1.00	16.9
0.1000-01	1.00	-0.123	0.999	-0.3190-01	0.999	-0.2980-01	1.00	16.9
0.2000-01	1.00	-0.246	0.997	-0.6380-01	0.997	-0.5950-01	0.999	16.9
0.3000-01	1.00	-0.370	0.993	-0.9540-01	0.993	-0.8900-01	0.997	16.8
0.4000-01	1.00	-0.496	0.988	-0.127	0.988	-0.118	0.995	16.8
0.5000-01	1.00	-0.624	0.982	-0.158	0.982	-0.147	0.993	16.8
0.6000-01	1.00	-0.755	0.974	-0.188	0.974	-0.175	0.989	16.7
0.7000-01	1.00	-0.889	0.964	-0.218	0.965	-0.203	0.986	16.6
0.8000-01	1.00	-1.03	0.953	-0.248	0.954	-0.230	0.981	16.6
0.9000-01	1.00	-1.17	0.942	-0.276	0.942	-0.256	0.976	16.5
0.100	1.01	-1.32	0.928	-0.304	0.930	-0.281	0.971	16.4
0.200	1.02	-3.15	0.747	-0.529	0.759	-0.477	0.896	15.1
0.300	1.04	-5.84	0.525	-0.646	0.567	-0.568	0.803	13.5
0.400	1.04	-9.19	0.318	-0.674	0.406	-0.592	0.718	12.1
0.500	1.02	-12.5	0.146	-0.650	0.276	-0.589	0.650	11.0
0.600	1.00	-15.2	0.8780-02	-0.593	0.163	-0.567	0.590	9.96
0.700	0.985	-17.7	-0.9280-01	-0.516	0.6960-01	-0.527	0.532	8.98
0.800	0.963	-20.4	-0.160	-0.432	0.9260-03	-0.478	0.478	8.07
0.900	0.931	-22.9	-0.199	-0.352	-0.4900-01	-0.431	0.434	7.33
1.000	0.897	-24.8	-0.219	-0.282	-0.9010-01	-0.388	0.398	6.72

TABLE XXI

RUN ID H-21

CONTO.

DEAD TIME= 0.000D 00 PULSES NDRMALIZED

UMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DFGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT REAL	INPUT PULSE IMAGINARY	INPUT FREQ NDRMALIZED	CONTENT ACTUAL
2.00	0.659	-33.3	-0.104	0.158D-01	-0.146	-0.671D-01	0.160	2.70
3.00	0.535	-34.7	-0.276D-01	0.242D-01	-0.681D-01	0.784D-02	0.686D-01	1.16
4.00	0.472	-37.9	-0.585D-02	0.141D-01	-0.281D-01	0.160D-01	0.324D-01	0.546
5.00	0.302	-25.7	-0.253D-02	0.484D-02	-0.145D-01	0.108D-01	0.1R1D-01	0.305
6.00	0.348	-21.7	-0.165D-02	0.344D-02	-0.807D-02	0.742D-02	0.110D-01	0.185
7.00	0.169	-1.22	-0.810D-03	0.819D-03	-0.489D-02	0.473D-02	0.680D-02	0.115
8.00	0.283	-13.7	-0.315D-03	0.132D-02	-0.219D-02	0.428D-02	0.4R1D-02	0.811D-01
9.00	0.577	15.9	-0.158D-02	0.178D-02	-0.179D-02	0.372D-02	0.413D-02	0.696D-01
10.0	0.298	5.59	-0.281D-03	0.889D-03	-0.648D-03	0.306D-02	0.313D-02	0.528D-01

TABLE XXI CONTD.

KUN ID H-21

COMMENTS HE FLUIDIZED BED HT 7 5/8 IN AIR RATE 8.0 CM SMP LOOP 4 LINE APP 1/22/69

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000-00	1.14	0.0000 00	19.3	0.0000 00	16.9	0.0000 00	1.00	16.9
0.1000-02	1.00	-0.3800-01	1.00	-0.3640-02	1.00	-0.2980-02	1.00	16.9
0.2000-02	1.00	-0.7610-01	1.00	-0.7290-02	1.00	-0.5960-02	1.00	16.9
0.3000-02	1.00	-0.114	1.00	-0.1090-01	1.00	-0.8940-02	1.00	16.9
0.4000-02	1.00	-0.152	1.00	-0.1460-01	1.00	-0.1190-01	1.00	16.9
0.5000-02	1.00	-0.190	1.00	-0.1820-01	1.00	-0.1490-01	1.00	16.9
0.6000-02	1.00	-0.228	1.00	-0.2190-01	1.00	-0.1790-01	1.00	16.9
0.7000-02	1.00	-0.266	1.00	-0.2550-01	1.00	-0.2090-01	1.00	16.9
0.8000-02	1.00	-0.304	0.999	-0.2910-01	1.00	-0.2380-01	1.00	16.9
0.9000-02	1.00	-0.342	0.999	-0.3280-01	0.999	-0.2680-01	1.00	16.9
0.1000-01	1.00	-0.380	0.999	-0.3640-01	0.999	-0.2980-01	1.00	16.9
0.2000-01	1.00	-0.761	0.996	-0.7270-01	0.997	-0.5950-01	0.999	16.9
0.3000-01	1.00	-1.14	0.992	-0.109	0.993	-0.8900-01	0.997	16.8
0.4000-01	1.00	-1.53	0.986	-0.145	0.988	-0.118	0.995	16.8
0.5000-01	1.00	-1.91	0.978	-0.180	0.982	-0.147	0.993	16.8
0.6000-01	1.00	-2.30	0.968	-0.215	0.974	-0.175	0.989	16.7
0.7000-01	1.00	-2.69	0.957	-0.249	0.965	-0.203	0.986	16.6
0.8000-01	1.00	-3.09	0.944	-0.282	0.954	-0.230	0.981	16.6
0.9000-01	1.00	-3.49	0.930	-0.314	0.942	-0.256	0.976	16.5
0.100	1.01	-3.89	0.914	-0.346	0.930	-0.281	0.971	16.4
0.200	1.02	-8.31	0.696	-0.594	0.759	-0.477	0.896	15.1
0.300	1.04	-13.6	0.433	-0.710	0.567	-0.568	0.803	13.5
0.400	1.04	-19.5	0.192	-0.720	0.406	-0.592	0.718	12.1
0.500	1.02	-25.3	-0.2900-02	-0.666	0.276	-0.589	0.650	11.0
0.600	1.00	-30.7	-0.150	-0.574	0.163	-0.567	0.590	9.96
0.700	0.985	-35.8	-0.248	-0.461	0.6960-01	-0.527	0.532	8.98
0.800	0.963	-41.0	-0.301	-0.348	0.9260-03	-0.478	0.478	8.07
0.900	0.931	-46.1	-0.321	-0.246	-0.4900-01	-0.431	0.434	7.33
1.000	0.897	-50.5	-0.320	-0.159	-0.9010-01	-0.388	0.398	6.72



TABLE XXI

RUN 10 H-21

CONTD.

OMEGA RAD/SEC	DEAD TIME=	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED				INPUT PULSE				INPUT FREQ CONTENT	
				REAL	IMAGINARY	REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL		
2.00	0.450	0.659	-84.9	-0.5260-01	0.9170-01	-0.146	-0.6710-01	0.160	0.6860-01	0.160	2.70	0.160	2.70
3.00		0.535	-112.	0.1760-01	0.3230-01	-0.6810-01	0.7840-02	0.6860-01	0.6860-01	0.6860-01	1.16	0.6860-01	1.16
4.00		0.472	-141.	0.1510-01	0.2490-02	-0.2810-01	0.1600-01	0.3240-01	0.3240-01	0.3240-01	0.546	0.3240-01	0.546
5.00		0.302	-155.	0.5360-02	-0.1070-02	-0.1450-01	0.1080-01	0.1810-01	0.1810-01	0.1810-01	0.305	0.1810-01	0.305
6.00		0.348	-176.	0.2960-02	-0.2400-02	-0.8070-02	0.7420-02	0.1100-01	0.1100-01	0.1100-01	0.185	0.1100-01	0.185
7.00		0.169	178.	0.8030-03	-0.8250-03	-0.4890-02	0.4730-02	0.6800-02	0.6800-02	0.6800-02	0.115	0.6800-02	0.115
8.00		0.283	140.	-0.3030-03	-0.1330-02	-0.2190-02	0.4280-02	0.4810-02	0.4810-02	0.4810-02	0.8110-01	0.4810-02	0.8110-01
9.00		0.577	144.	-0.4310-03	-0.2340-02	-0.1790-02	0.3720-02	0.4130-02	0.4130-02	0.4130-02	0.6960-01	0.4130-02	0.6960-01
10.00		0.298	108.	-0.8100-03	-0.4620-03	-0.6480-03	0.3060-02	0.3130-02	0.3130-02	0.3130-02	0.5280-01	0.3130-02	0.5280-01

TABLE XXII

RUN 10 F-01

COMMENTS FREON-12 TRACER RED IN AIR RATE 6.3 CM

12/27/68

DFAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	ACTUAL
0.0000 00	0.890	0.0000 00	311.	0.0000 00	350.	0.0000 00	1.00	350.
0.1000-01	0.987	-9.25	0.942	-0.275	0.987	-0.122	0.995	348.
0.2000-01	0.948	-18.3	0.784	-0.495	0.950	-0.236	0.978	342.
0.3000-01	0.886	-26.9	0.568	-0.623	0.891	-0.337	0.952	333.
0.4000-01	0.805	-34.8	0.347	-0.652	0.816	-0.420	0.918	321.
0.5000-01	0.710	-41.4	0.163	-0.601	0.731	-0.483	0.876	306.
0.6000-01	0.611	-46.3	0.4740-01	-0.505	0.643	-0.524	0.829	290.
0.7000-01	0.517	-48.5	-0.2050-01	-0.402	0.557	-0.545	0.779	272.
0.8000-01	0.438	-47.6	-0.3690-01	-0.317	0.477	-0.550	0.728	255.
0.9000-01	0.384	-43.8	-0.3090-01	-0.259	0.408	-0.542	0.678	237.
0.100	0.356	-38.8	-0.2020-01	-0.224	0.349	-0.526	0.631	221.
0.200	0.367	-26.9	-0.2930-01	-0.137	0.9690-01	-0.368	0.381	133.
0.300	0.331	-26.5	-0.3140-01	-0.8590-01	0.3110-01	-0.275	0.277	96.7
0.400	0.347	-34.8	-0.4680-01	-0.6010-01	-0.1180-01	-0.219	0.220	76.8
0.500	0.320	-41.4	-0.4880-01	-0.3610-01	-0.3970-01	-0.186	0.190	66.4
0.600	0.290	-46.3	-0.4370-01	-0.1750-01	-0.6040-01	-0.151	0.162	56.8
0.700	0.296	-54.7	-0.4160-01	-0.3730-02	-0.7090-01	-0.122	0.141	49.3
0.800	0.247	-60.8	-0.2990-01	0.5960-02	-0.8030-01	-0.9390-01	0.124	43.2
0.900	0.240	-71.4	-0.2250-01	0.1290-01	-0.8070-01	-0.7180-01	0.108	37.8
1.00	0.195	-75.6	-0.1410-01	0.1310-01	-0.8320-01	-0.5340-01	0.9890-01	34.6
2.00	0.2350-01	-53.5	0.3630-04	0.5770-03	-0.1880-01	0.1580-01	0.2460-01	8.60
3.00	0.6760-01	110.	-0.3900-03	-0.1470-03	-0.2060-04	0.6170-02	0.6170-02	2.16
4.00	0.177	62.5	-0.3070-03	0.6960-04	-0.4540-03	0.1720-02	0.1780-02	0.624
5.00	0.168	-45.7	0.1650-04	0.1770-03	-0.6840-03	0.8050-03	0.1060-02	0.369
6.00	0.8100-01	-133.	0.5820-04	-0.4510-04	-0.8530-04	0.9050-03	0.9090-03	0.318
7.00	0.840	-91.4	-0.1300-03	0.1010-03	-0.1160-03	-0.1580-03	0.1960-03	0.6850-01
8.00	0.955	132.	0.2190-03	-0.1670-04	-0.1670-03	-0.1580-03	0.2290-03	0.8020-01
9.00	0.249	103.	-0.1060-03	-0.6200-04	-0.1460-03	0.4720-03	0.4940-03	0.173
10.0	0.378	77.3	-0.1090-03	-0.3540-04	-0.1550-03	0.2610-03	0.3040-03	0.106

TABLE XXII

RUN ID F-01

CONTU.

DEAD TIME= 0.0000 00 PULSES NDRHALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ		CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	NORMALIZED	
11.0	0.208	0.383	0.1880-04	0.5170-04	0.9200-04	0.2470-03	0.2640-03	0.9230-01	
21.0	0.275	-41.6	-0.1410-04	-0.8140-05	-0.1880-04	-0.5630-04	0.5930-04	0.2070-01	
31.0	0.3880-01	-125.	0.1160-05	-0.4080-06	-0.8490-05	0.3050-04	0.3160-04	0.1110-01	
41.0	0.163	-86.3	-0.1650-05	0.7530-06	-0.5270-05	-0.9820-05	0.1110-04	0.3900-02	
51.0	0.277	-59.0	-0.7840-05	0.3420-06	-0.1560-04	-0.2360-04	0.2830-04	0.9900-02	
61.0	0.338	27.3	-0.7410-06	0.2960-05	0.8440-06	0.7860-05	0.7900-05	0.2760-02	
71.0	0.352	-22.7	-0.7310-06	-0.7760-06	-0.1060-05	-0.2840-05	0.3030-05	0.1060-02	
81.0	0.6130-01	148.	-0.5130-07	-0.2410-06	-0.1370-05	0.3780-05	0.4020-05	0.1410-02	
91.0	0.416	-122.	-0.3610-06	0.8900-06	-0.1360-05	-0.1860-05	0.2310-05	0.8070-03	
101.	0.326	-39.4	-0.1040-05	-0.9300-06	-0.6630-06	-0.4230-05	0.4280-05	0.1500-02	

TABLE XXII CONTD.

RUN ID F-01

12/27/68

COMMENTS FREUN-12 TRACER FED IN AIR RATE 6.3 CM

DEAD TIME= 1.85 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE PATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000-00	0.890	0.0000 00	311.	0.0000 00	350.	0.0000 00	1.00	350.
0.1000-01	0.987	-10.3	0.937.	-0.292	0.987	-0.122	0.995	348.
0.2000-01	0.948	-20.4	0.765	-0.524	0.950	-0.236	0.978	342.
0.3000-01	0.886	-30.1	0.533	-0.654	0.891	-0.337	0.952	333.
0.4000-01	0.805	-39.0	0.297	-0.676	0.816	-0.420	0.918	321.
0.5000-01	0.710	-46.7	0.107	-0.613	0.731	-0.483	0.876	306.
0.6000-01	0.611	-52.6	-0.157D-01	-0.506	0.643	-0.524	0.829	290.
0.7000-01	0.517	-55.9	-0.723D-01	-0.396	0.557	-0.545	0.779	272.
0.8000-01	0.438	-56.1	-0.832D-01	-0.308	0.477	-0.550	0.728	255.
0.9000-01	0.384	-53.3	-0.734D-01	-0.250	0.408	-0.542	0.678	237.
0.100	0.356	-49.4	-0.610D-01	-0.216	0.349	-0.526	0.631	221.
0.200	0.367	-48.1	-0.767D-01	-0.117	0.949D-01	-0.368	0.381	133.
0.300	0.331	-58.3	-0.720D-01	-0.565D-01	0.311D-01	-0.275	0.277	96.7
0.400	0.347	-77.2	-0.751D-01	-0.129D-01	0.118D-01	-0.219	0.220	76.8
0.500	0.320	-94.4	-0.582D-01	0.172D-01	0.397D-01	-0.186	0.190	66.4
0.600	0.290	-110.	-0.351D-01	0.314D-01	0.604D-01	-0.151	0.162	56.8
0.700	0.296	-129.	-0.149D-01	0.390D-01	0.709D-01	-0.122	0.141	49.3
0.800	0.247	-146.	0.322D-02	0.303D-01	0.803D-01	-0.939D-01	0.124	43.2
0.900	0.240	-167.	0.149D-01	0.212D-01	0.807D-01	-0.718D-01	0.108	37.8
1.00	0.195	178.	0.165D-01	0.996D-02	0.632D-01	-0.534D-01	0.989D-01	34.6
2.00	0.235D-01	94.5	-0.336D-03	-0.470D-03	0.188D-01	0.158D-01	0.246D-01	8.60
3.00	0.676D-01	152.	-0.110D-03	-0.370D-03	0.206D-04	0.617D-02	0.617D-02	2.16
4.00	0.177	-1.49	-0.722D-04	0.307D-03	0.454D-03	0.172D-02	0.178D-02	0.624
5.00	0.168	144.	0.145D-04	-0.177D-03	0.684D-03	0.805D-03	0.106D-02	0.369
6.00	0.810D-01	-49.1	0.509D-04	0.532D-04	0.853D-04	0.905D-03	0.909D-03	0.318
7.00	0.840	-113.	-0.828D-04	0.142D-03	0.116D-03	-0.158D-03	0.196D-03	0.685D-01
8.00	0.955	4.28	-0.148D-03	-0.162D-03	0.167D-03	-0.158D-03	0.229D-03	0.802D-01
9.00	0.249	-131.	0.113D-03	-0.494D-04	0.146D-03	0.472D-03	0.494D-03	0.173
10.0	0.378	97.3	-0.904D-04	-0.706D-04	0.155D-03	0.261D-03	0.304D-03	0.106

TABLE XXII

RUN ID F-01

CONTD.

OMEGA RAD/SEC	DFAD TIME=	1.85	PULSES NORMALIZED		PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
			AMPLITUDE RATIO	AMPLITUDE RATIO		REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
11.0	0.208	-85.6	0.5790-04	-0.1510-04	0.9200-04	0.2470-03	0.2640-03	0.9230-01			
21.0	0.275	-108.	-0.1320-04	0.9570-05	-0.1860-04	-0.5630-04	0.5930-04	0.2070-01			
31.0	0.3880-01	-171.	0.5130-06	-0.1120-05	-0.8490-05	0.3050-04	0.3160-04	0.1110-01			
41.0	0.163	-112.	-0.1150-05	0.1400-05	-0.5270-05	-0.9820-05	0.1110-04	0.3900-02			
51.0	0.277	-64.8	-0.7770-05	0.1140-05	-0.1560-04	-0.2360-04	0.2830-04	0.9900-02			
61.0	0.338	36.4	-0.1350-05	0.2300-05	0.8440-06	0.7860-05	0.7900-05	0.2760-02			
71.0	0.352	11.5	-0.1680-06	-0.1050-05	-0.1060-05	-0.2840-05	0.3030-05	0.1060-02			
81.0	0.6130-01	-158.	0.1450-06	-0.1820-06	-0.1370-05	0.3780-05	0.4020-05	0.1410-02			
91.0	0.416	-47.5	-0.9540-06	-0.1060-06	-0.1360-05	-0.1860-05	0.2310-05	0.8070-03			
101.	0.326	54.9	0.1010-05	-0.9710-06	-0.6630-06	-0.4230-05	0.4280-05	0.1500-02			

TABLE XXIII

RUN ID F-02

1/9/69

COMMENTS F- 12 BED HT 7 1/4 IN FLUIDIZED AIR FLOW 5.0 CM SMP LOOP 5 LINE APP

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000-00	1.07	0.0000 00	179.	0.0000 00	168.	0.0000 00	1.00	168.
0.1000-02	1.00	-0.525	1.00	-0.2340-01	1.00	-0.1250-01	1.00	168.
0.2000-02	1.00	-1.25	0.998	-0.4680-01	0.999	-0.2500-01	1.00	168.
0.3000-02	0.999	-1.87	0.996	-0.7010-01	0.999	-0.3750-01	1.00	168.
0.4000-02	0.999	-2.50	0.994	-0.9330-01	0.998	-0.5000-01	0.999	168.
0.5000-02	0.998	-3.12	0.990	-0.116	0.997	-0.6250-01	0.999	168.
0.6000-02	0.997	-3.74	0.985	-0.139	0.995	-0.7490-01	0.998	168.
0.7000-02	0.996	-4.37	0.980	-0.162	0.993	-0.8730-01	0.997	168.
0.8000-02	0.995	-4.99	0.974	-0.184	0.991	-0.9960-01	0.996	168.
0.9000-02	0.994	-5.61	0.968	-0.207	0.989	-0.112	0.996	168.
0.1000-01	0.992	-6.23	0.960	-0.229	0.987	-0.124	0.994	167.
0.2000-01	0.970	-12.3	0.848	-0.424	0.948	-0.241	0.978	165.
0.3000-01	0.933	-18.2	0.687	-0.563	0.888	-0.343	0.952	160.
0.4000-01	0.885	-23.8	0.504	-0.635	0.811	-0.427	0.917	154.
0.5000-01	0.826	-26.8	0.330	-0.643	0.725	-0.490	0.875	147.
0.6000-01	0.761	-33.2	0.183	-0.603	0.636	-0.531	0.828	139.
0.7000-01	0.693	-36.8	0.7480-01	-0.535	0.549	-0.552	0.778	131.
0.8000-01	0.626	-39.5	0.4280-02	-0.456	0.469	-0.557	0.728	123.
0.9000-01	0.561	-41.2	-0.3510-01	-0.379	0.398	-0.550	0.679	114.
0.100	0.501	-41.8	-0.5220-01	-0.313	0.339	-0.535	0.633	107.
0.200	0.385	2.85	0.3880-01	-0.137	0.8300-01	-0.361	0.370	62.3
0.300	0.485	-10.8	-0.1840-01	-0.131	0.1340-01	-0.272	0.273	45.9
0.400	0.441	-14.2	-0.3480-01	-0.9330-01	-0.2450-01	-0.224	0.226	38.0
0.500	0.449	-16.5	-0.4890-01	-0.7160-01	-0.5920-01	-0.184	0.193	32.5
0.600	0.443	-17.3	-0.5460-01	-0.4960-01	-0.8430-01	-0.144	0.167	28.0
0.700	0.400	-25.0	-0.5110-01	-0.2270-01	-0.9180-01	-0.106	0.140	23.5
0.800	0.391	-20.9	-0.4510-01	-0.1350-01	-0.9530-01	-0.7340-01	0.120	20.2
0.900	0.385	-29.0	-0.3940-01	-0.1490-02	-0.8760-01	-0.5300-01	0.102	17.2
1.000	0.333	-25.5	-0.3070-01	0.3130-02	-0.8720-01	-0.3120-01	0.9260-01	15.6

TABLE XXIII

RUN ID F-02  
 CONTD.

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	DEAD TIME = 0.0000 00 PULSES NORMALIZED		OUTPUT PULSE		INPUT PULSE		INPUT FREQ		CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	NORMALIZED	
2.00	0.354	-29.3	-0.4930-03	0.6820-02	-0.1060-01	0.1610-01	0.1930-01	0.3920-02	0.1930-01	3.25	
3.00	0.273	-53.7	0.1060-02	0.1640-03	0.1810-02	0.3480-02	0.3920-02	0.3920-02	0.3920-02	0.660	
4.00	0.179	175.	-0.7270-04	-0.1140-03	0.3530-03	0.6650-03	0.7530-03	0.7530-03	0.7530-03	0.127	
5.00	1.31	14.3	-0.4350-03	0.1380-03	-0.2960-03	0.1840-03	0.3490-03	0.3490-03	0.3490-03	0.5870-01	
6.00	0.142	-12.0	0.4790-04	0.1490-04	0.3080-03	0.1730-03	0.3530-03	0.3530-03	0.3530-03	0.5950-01	
7.00	0.113	31.5	-0.2980-04	-0.5510-04	-0.4820-03	-0.2800-03	0.5570-03	0.5570-03	0.5570-03	0.9380-01	
8.00	0.922	-15.8	-0.1580-03	0.1920-03	-0.2220-03	0.1540-03	0.2700-03	0.2700-03	0.2700-03	0.4540-01	
9.00	0.151	-43.0	0.2410-04	0.7010-04	-0.2010-03	0.4500-03	0.4930-03	0.4930-03	0.4930-03	0.8290-01	
10.0	0.218	11.2	0.5090-04	-0.1970-04	0.2120-03	-0.1340-03	0.2510-03	0.2510-03	0.2510-03	0.4220-01	

TABLE XXIII CONTD.

RUN ID F-02

COMMENTS F- 12 BED HT 7 1/4 IN FLUIDIZED AIR FLOW 5.0 CM SMP LOOP 5 LINE APP 1/9/69

DEAD TIME\* 0.450 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	ACTUAL
0.0000-00	1.07	0.0000 00	179.	0.0000 00	168.	0.0000 00	1.00	168.
0.1000-02	1.00	-0.650	1.00	-0.2390-01	1.00	-0.1250-01	1.00	168.
0.2000-02	1.00	-1.30	0.998	-0.4770-01	0.999	-0.2500-01	1.00	168.
0.3000-02	0.999	-1.95	0.996	-0.7150-01	0.999	-0.3750-01	1.00	168.
0.4000-02	0.999	-2.60	0.993	-0.9510-01	0.998	-0.5000-01	0.999	168.
0.5000-02	0.998	-3.25	0.990	-0.119	0.997	-0.6250-01	0.999	168.
0.6000-02	0.997	-3.90	0.985	-0.142	0.995	-0.7490-01	0.998	168.
0.7000-02	0.996	-4.55	0.980	-0.165	0.993	-0.8730-01	0.997	168.
0.8000-02	0.995	-5.19	0.974	-0.188	0.991	-0.9960-01	0.996	168.
0.9000-02	0.994	-5.84	0.967	-0.211	0.989	-0.112	0.996	168.
0.1000-01	0.992	-6.49	0.959	-0.233	0.987	-0.124	0.994	167.
0.2000-01	0.970	-12.9	0.844	-0.432	0.948	-0.241	0.978	165.
0.3000-01	0.933	-19.0	0.679	-0.573	0.888	-0.343	0.952	160.
0.4000-01	0.885	-24.8	0.493	-0.644	0.811	-0.427	0.917	154.
0.5000-01	0.826	-30.1	0.315	-0.651	0.725	-0.490	0.875	147.
0.6000-01	0.761	-34.8	0.167	-0.608	0.636	-0.531	0.828	139.
0.7000-01	0.693	-36.6	0.5790-01	-0.537	0.549	-0.552	0.778	131.
0.8000-01	0.626	-41.6	-0.1210-01	-0.455	0.469	-0.557	0.728	123.
0.9000-01	0.561	-43.5	-0.5040-01	-0.378	0.398	-0.550	0.679	114.
0.100	0.501	-44.4	-0.6630-01	-0.310	0.339	-0.535	0.633	107.
0.200	0.385	-2.30	0.2640-01	-0.140	0.8300-01	-0.361	0.370	62.3
0.300	0.485	-18.6	-0.3590-01	-0.127	0.1340-01	-0.272	0.273	45.9
0.400	0.441	-24.5	-0.5090-01	-0.8550-01	-0.2450-01	-0.224	0.226	38.0
0.500	0.449	-29.3	-0.6360-01	-0.5890-01	-0.5920-01	-0.184	0.193	32.5
0.600	0.443	-32.8	-0.6580-01	-0.3320-01	-0.8430-01	-0.144	0.167	28.0
0.700	0.400	-43.0	-0.5560-01	-0.5810-02	-0.9180-01	-0.106	0.140	23.5
0.800	0.391	-41.5	-0.4690-01	0.3220-02	-0.9530-01	-0.7340-01	0.120	20.2
0.900	0.385	-52.2	-0.3680-01	0.1410-01	-0.8760-01	-0.5300-01	0.102	17.2
1.000	0.333	-51.3	-0.2630-01	0.1620-01	-0.8720-01	-0.3120-01	0.9260-01	15.6



TABLE XXIII

RUN ID F-02

CONTD.

DEAD TIME: 0.450		PULSES NORMALIZED		PULSES NORMALIZED		PULSES NORMALIZED		PULSES NORMALIZED		PULSES NORMALIZED		PULSES NORMALIZED	
OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	INPUT FREQ NORMALIZED	CONTENT ACTUAL	CONTENT ACTUAL	CONTENT ACTUAL	CONTENT ACTUAL	CONTENT ACTUAL
2.00	0.354	-80.8	0.504D-02	0.463D-02	-0.106D-01	0.161D-01	0.193D-01	0.193D-01	3.25	3.25	3.25	3.25	3.25
3.00	0.273	-131.	0.391D-03	-0.995D-03	0.181D-02	0.348D-02	0.392D-02	0.392D-02	0.660	0.660	0.660	0.660	0.660
4.00	0.179	72.2	-0.944D-04	0.967D-04	0.353D-03	0.665D-03	0.753D-03	0.753D-03	0.127	0.127	0.127	0.127	0.127
5.00	1.31	-115.	0.380D-03	0.252D-03	-0.296D-03	0.184D-03	0.349D-03	0.349D-03	0.587D-01	0.587D-01	0.587D-01	0.587D-01	0.587D-01
6.00	0.142	-167.	-0.370D-04	-0.340D-04	0.308D-03	0.173D-03	0.353D-03	0.353D-03	0.595D-01	0.595D-01	0.595D-01	0.595D-01	0.595D-01
7.00	0.113	-149.	0.303D-04	0.549D-04	-0.482D-03	-0.280D-03	0.557D-03	0.557D-03	0.938D-01	0.938D-01	0.938D-01	0.938D-01	0.938D-01
8.00	0.922	138.	0.569D-04	-0.242D-03	-0.222D-03	0.154D-03	0.270D-03	0.270D-03	0.454D-01	0.454D-01	0.454D-01	0.454D-01	0.454D-01
9.00	0.151	84.9	-0.701D-04	-0.241D-04	-0.201D-03	0.450D-03	0.493D-03	0.493D-03	0.829D-01	0.829D-01	0.829D-01	0.829D-01	0.829D-01
10.0	0.218	113.	0.848D-05	0.539D-04	0.212D-03	-0.134D-03	0.251D-03	0.251D-03	0.422D-01	0.422D-01	0.422D-01	0.422D-01	0.422D-01

TABLE XXIV

RUN ID F-03

COMMENTS F-12 PACKED BED HT 7 1/4 IN AIR FLOW 2.0 CM SMP LOOP 2 LINE APP 1/6/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	INPUT FREQ CONTENT ACTUAL
0.0000-00	0.717	0.0000 00	100.	0.0000 00	140.	0.0000 00	1.00	140.
0.1000-02	0.957	19.6	1.00	-0.2180-01	0.977	-0.372	1.05	146.
0.2000-02	1.00	9.39	0.999	-0.4360-01	0.976	-0.206	0.998	139.
0.3000-02	1.01	5.51	0.997	-0.6540-01	0.976	-0.159	0.988	138.
0.4000-02	1.01	3.31	0.995	-0.8710-01	0.975	-0.142	0.985	137.
0.5000-02	1.02	1.79	0.992	-0.109	0.973	-0.138	0.983	137.
0.6000-02	1.02	0.624	0.988	-0.130	0.972	-0.139	0.981	137.
0.7000-02	1.02	-0.347	0.984	-0.151	0.970	-0.143	0.980	137.
0.8000-02	1.02	-1.19	0.979	-0.173	0.967	-0.150	0.979	137.
0.9000-02	1.02	-1.96	0.974	-0.194	0.965	-0.158	0.978	136.
0.1000-01	1.02	-2.66	0.968	-0.214	0.962	-0.167	0.976	136.
0.2000-01	1.01	-8.39	0.878	-0.406	0.920	-0.271	0.959	134.
0.3000-01	0.997	-13.3	0.743	-0.556	0.853	-0.371	0.930	130.
0.4000-01	0.983	-17.8	0.584	-0.655	0.770	-0.453	0.893	125.
0.5000-01	0.967	-22.1	0.421	-0.705	0.677	-0.512	0.849	118.
0.6000-01	0.951	-26.0	0.269	-0.712	0.583	-0.548	0.800	112.
0.7000-01	0.938	-29.9	0.138	-0.688	0.493	-0.563	0.748	104.
0.8000-01	0.928	-33.6	0.2960-01	-0.646	0.412	-0.562	0.697	97.2
0.9000-01	0.920	-37.5	-0.5740-01	-0.593	0.343	-0.549	0.647	90.3
0.100	0.914	-41.6	-0.127	-0.536	0.286	-0.530	0.602	84.0
0.200	0.671	-81.7	-0.232	-0.5800-01	0.3590-01	-0.355	0.356	49.7
0.300	0.456	-116.	-0.9690-01	0.6520-01	-0.3750-01	-0.253	0.256	35.7
0.400	0.294	-146.	-0.1290-01	0.5800-01	-0.7420-01	-0.188	0.202	28.2
0.500	0.154	-176.	0.1300-01	0.2170-01	-0.9520-01	-0.135	0.165	23.0
0.600	0.8360-01	145.	0.1130-01	0.1240-02	-0.103	-0.9000-01	0.137	19.0
0.700	0.2420-01	136.	0.2650-02	-0.7190-03	-0.9930-01	-0.5460-01	0.113	15.8
0.800	0.1820-01	127.	0.1390-02	-0.1050-02	-0.9220-01	-0.2590-01	0.9580-01	13.4
0.900	0.2300-01	69.3	-0.5190-03	-0.1710-02	-0.7780-01	-0.5300-02	0.7800-01	10.9
1.00	0.1250-01	63.2	-0.2240-03	-0.7760-03	-0.6390-01	0.1040-01	0.6470-01	9.03

TABLE XXIV

RUN ID F-03

CONTD.

DEAD TIME = 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
2.00	0.1310-01	37.0	-0.6540-04	0.8060-04	-0.2860-03	0.7940-02	0.7940-02	1.11
3.00	0.652	132.	-0.2980-03	-0.1050-03	0.1850-03	0.4470-03	0.4840-03	0.6750-01
4.00	1.22	65.7	-0.3690-03	-0.6240-03	-0.5880-03	0.6530-04	0.5920-03	0.8260-01
5.00	0.243	-68.9	0.1310-03	0.1200-03	-0.2660-03	0.6800-03	0.7300-03	0.102
6.00	0.418	93.3	-0.8170-04	0.4500-04	0.1190-03	0.1890-03	0.2230-03	0.3110-01
7.00	0.689	-83.3	-0.4290-04	0.1490-03	-0.2230-03	-0.3650-04	0.2260-03	0.3150-01
8.00	0.643	-50.8	-0.4920-04	0.7870-04	-0.1430-03	0.1790-04	0.1440-03	0.2020-01
9.00	0.311	50.1	-0.4710-04	0.5600-04	0.4090-04	0.2320-03	0.2350-03	0.3280-01
10.0	0.340	125.	0.4160-04	0.6350-04	0.8310-04	-0.2070-03	0.2230-03	0.3120-01

TABLE XXIV CONTD.

RUN ID F-03

1/6/69

COMMENTS F-12 PACKED BED HT 7 1/4 IN AIR FLOW 2.0 CM SMP LOOP 2 LINE APP

DEAD TIME= 26.4 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE RFAL	INPUT PULSE IMAGINARY	REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
0.0000-00	0.717	0.0000 00	100.	0.0000 00	140.	0.0000 00	1.00	140.
0.1000-02	0.957	18.1	0.999	-0.4820-01	0.977	-0.372	1.05	146.
0.2000-02	1.00	6.36	0.995	-0.9630-01	0.976	-0.206	0.998	139.
0.3000-02	1.01	0.970	0.989	-0.144	0.976	-0.159	0.988	138.
0.4000-02	1.01	-2.74	0.980	-0.191	0.975	-0.142	0.985	137.
0.5000-02	1.02	-5.77	0.969	-0.238	0.973	-0.138	0.983	137.
0.6000-02	1.02	-8.45	0.955	-0.284	0.972	-0.139	0.981	137.
0.7000-02	1.02	-10.9	0.940	-0.330	0.970	-0.143	0.980	137.
0.8000-02	1.02	-13.3	0.921	-0.374	0.967	-0.150	0.979	137.
0.9000-02	1.02	-15.6	0.901	-0.417	0.965	-0.158	0.978	136.
0.1000-01	1.02	-17.8	0.879	-0.460	0.962	-0.167	0.976	136.
0.2000-01	1.01	-38.6	0.554	-0.792	0.920	-0.271	0.959	134.
0.3000-01	0.997	-58.7	0.127	-0.919	0.853	-0.371	0.930	130.
0.4000-01	0.983	-78.3	-0.282	-0.831	0.770	-0.453	0.893	125.
0.5000-01	0.967	-97.7	-0.578	-0.583	0.677	-0.512	0.849	118.
0.6000-01	0.951	-117.	-0.715	-0.260	0.583	-0.548	0.800	112.
0.7000-01	0.938	-136.	-0.700	0.5560-01	0.493	-0.563	0.748	104.
0.8000-01	0.928	-155.	-0.569	0.307	0.412	-0.562	0.697	97.2
0.9000-01	0.920	-174. <sup>143</sup>	-0.370	0.467	0.343	-0.549	0.647	90.3
0.100	0.914	167.	-0.146	0.530	0.286	-0.530	0.602	84.0
0.200	0.671	-24.3	-0.7590-01	-0.227	0.3590-01	-0.355	0.356	49.7
0.300	0.456	151.	0.7140-01	0.9230-01	-0.3750-01	-0.253	0.256	35.7
0.400	0.294	-31.0	-0.4720-01	-0.3620-01	-0.7420-01	-0.188	0.202	28.2
0.500	0.154	148.	0.2340-01	0.9810-02	-0.9520-01	-0.135	0.165	23.0
0.600	0.8360-01	-42.6	-0.1140-01	0.2680-03	-0.103	-0.9000-01	0.137	19.0
0.700	0.2420-01	157.	0.2730-02	0.2850-03	-0.9930-01	-0.5460-01	0.113	15.8
0.800	0.1820-01	-2.66	-0.1700-02	-0.3930-03	-0.9220-01	-0.2590-01	0.9580-01	13.4
0.900	0.2300-01	148.	0.1580-02	-0.8460-03	-0.7780-01	-0.5300-02	0.7800-01	10.9
1.00	0.1250-01	10.6	-0.8080-03	-0.1840-04	-0.6390-01	0.1040-01	0.6470-01	9.03

TABLE XXIV

RUN ID F-03

CONTD.

OMEGA RAD/SEC	DEAD TIME	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE		INPUT FREQ CONTENT	
				REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00		0.131D-01	-108.	0.997D-04	-0.289D-04	-0.286D-03	0.794D-02	0.794D-02	1.11
3.00		0.652	-66.0	0.299D-03	-0.100D-03	0.185D-03	0.447D-03	0.484D-03	0.675D-01
4.00		1.22	135.	0.456D-03	-0.564D-03	-0.588D-03	0.653D-04	0.592D-03	0.826D-01
5.00		0.243	-72.0	0.137D-03	0.113D-03	-0.266D-03	0.680D-03	0.730D-03	0.102
6.00		0.418	17.6	0.234D-04	0.903D-04	0.119D-03	0.189D-03	0.223D-03	0.311D-01
7.00		0.689	128.	0.115D-03	-0.105D-03	-0.223D-03	-0.365D-04	0.226D-03	0.315D-01
8.00		0.643	88.3	-0.142D-04	-0.917D-04	-0.143D-03	0.179D-04	0.144D-03	0.202D-01
9.00		0.311	117.	-0.702D-04	-0.209D-04	0.409D-04	0.232D-03	0.235D-03	0.328D-01
10.0		0.340	119.	0.481D-04	0.587D-04	0.831D-04	-0.207D-03	0.223D-03	0.312D-01

TABLE XXV

RUN ID F-04

COMMENTS F-12 PACKED RED HT 7 1/4 IN AIR FLOW 2.0 CM SMP LOOP 2 LINE APP 1/6/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	ACTUAL
0.0000 00	0.841	0.0000 00	110.	0.0000 00	130.	0.0000 00	1.00	130.
0.1000-02	1.00	-0.425	1.00	-0.2180-01	1.00	-0.1430-01	1.00	130.
0.2000-02	1.00	-0.850	0.999	-0.4350-01	0.999	-0.2870-01	1.00	130.
0.3000-02	1.00	-1.27	0.997	-0.6520-01	0.998	-0.4300-01	0.999	130.
0.4000-02	1.00	-1.70	0.995	-0.8680-01	0.997	-0.5730-01	0.999	130.
0.5000-02	1.00	-2.12	0.992	-0.108	0.996	-0.7150-01	0.998	130.
0.6000-02	0.999	-2.55	0.988	-0.130	0.994	-0.8570-01	0.997	130.
0.7000-02	0.995	-2.97	0.984	-0.151	0.991	-0.9980-01	0.996	130.
0.8000-02	0.999	-3.39	0.979	-0.172	0.989	-0.114	0.995	130.
0.9000-02	0.998	-3.82	0.974	-0.193	0.986	-0.128	0.994	130.
0.1000-01	0.999	-4.24	0.968	-0.213	0.983	-0.142	0.993	130.
0.2000-01	0.993	-8.42	0.877	-0.403	0.933	-0.272	0.972	127.
0.3000-01	0.986	-12.5	0.743	-0.551	0.857	-0.382	0.938	122.
0.4000-01	0.976	-16.4	0.586	-0.648	0.763	-0.465	0.894	117.
0.5000-01	0.967	-20.2	0.426	-0.695	0.662	-0.522	0.843	110.
0.6000-01	0.959	-23.9	0.278	-0.702	0.562	-0.551	0.787	103.
0.7000-01	0.952	-27.6	0.151	-0.679	0.472	-0.558	0.731	95.4
0.8000-01	0.948	-31.4	0.4680-01	-0.640	0.394	-0.550	0.677	88.3
0.9000-01	0.945	-35.5	-0.3800-01	-0.592	0.331	-0.534	0.628	81.9
0.100	0.939	-39.9	-0.107	-0.539	0.281	-0.514	0.586	76.4
0.200	0.728	-77.1	-0.241	-0.7470-01	0.2600-01	-0.346	0.347	45.3
0.300	0.484	-113.	-0.103	0.6520-01	-0.4040-01	-0.249	0.252	37.9
0.400	0.303	-146.	-0.1230-01	0.5790-01	-0.7390-01	-0.181	0.195	25.5
0.500	0.171	-177.	0.1440-01	0.2330-01	-0.9040-01	-0.132	0.160	20.9
0.600	0.6030-01	176.	0.6590-02	0.5060-02	-0.103	-0.9190-01	0.138	18.0
0.700	0.5640-01	160.	0.6200-02	0.7960-03	-0.9840-01	-0.5050-01	0.111	14.5
0.800	0.3300-01	108.	0.1680-02	-0.2570-02	-0.8970-01	-0.2480-01	0.9300-01	12.1
0.900	0.2010-01	-21.6	-0.1440-02	0.5000-03	-0.7570-01	-0.3170-02	0.7570-01	9.88
1.00	0.1040-01	179.	0.6430-03	-0.1100-03	-0.6180-01	0.9540-02	0.6260-01	8.16

## TABLE XXV

RUN ID F-04

CONTD.

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	DEAD TIME= 0.0000 00 PULSES NORMALIZED		OUTPUT PULSE		INPUT PULSE		INPUT FREQ		CONTENT	
			REAL	IMAGINARY	REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL	ACTUAL	ACTUAL
2.00	0.140	33.3	-0.6300-03	0.8310-03	-0.4730-03	0.7050-02	0.7070-02	0.922				
3.00	0.904	104.	-0.7410-03	0.6020-03	0.8490-03	0.6270-03	0.1060-02	0.139				
4.00	0.292	72.4	0.8950-04	-0.1070-03	-0.2560-03	-0.4030-03	0.4770-03	0.6230-01				
5.00	2.38	-11.7	-0.5960-03	0.5050-03	-0.2880-03	0.1570-03	0.3280-03	0.4280-01				
6.00	0.249	149.	0.7470-04	-0.2790-04	-0.3160-03	-0.5790-04	0.3210-03	0.4190-01				
7.00	0.365	81.4	-0.2030-04	0.1110-03	-0.3100-03	0.9290-05	0.3100-03	0.4040-01				
8.00	0.389	-82.9	-0.4040-04	0.1420-03	-0.3740-03	-0.5810-04	0.3790-03	0.4940-01				
9.00	0.150	132.	0.5260-06	-0.3820-04	-0.1900-03	0.1690-03	0.2540-03	0.3320-01				
10.0	0.145	32.8	-0.8980-05	0.1970-04	0.2160-04	0.1480-03	0.1500-03	0.1960-01				

TABLE XXV CONTD.

RUN ID F-04

COMMENTS F-12 PACKED BED HT 7 1/4 IN AIR FLOW 2.0 CM SMP LOOP 2 LINE APP 1/6/69

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
			DEAD TIME	26.0				
0.0000-00	0.841	0.0000 00	110.	0.0000 00	130.	0.0000 00	1.00	130.
0.1000-02	1.00	-1.91	0.999	-0.4770-01	1.00	-0.1430-01	1.00	130.
0.2000-02	1.00	-3.83	0.995	-0.9530-01	0.998	-0.2870-01	1.00	130.
0.3000-02	1.00	-5.74	0.989	-0.143	0.998	-0.4300-01	0.999	130.
0.4000-02	1.00	-7.66	0.980	-0.190	0.997	-0.5730-01	0.999	130.
0.5000-02	1.00	-9.57	0.969	-0.236	0.996	-0.7150-01	0.998	130.
0.6000-02	0.999	-11.5	0.956	-0.282	0.994	-0.8570-01	0.997	130.
0.7000-02	0.999	-13.4	0.941	-0.327	0.991	-0.9980-01	0.996	130.
0.8000-02	0.999	-15.3	0.923	-0.370	0.989	-0.114	0.995	130.
0.9000-02	0.999	-17.2	0.903	-0.413	0.986	-0.128	0.994	130.
0.1000-01	0.998	-19.1	0.880	-0.455	0.983	-0.142	0.993	130.
0.2000-01	0.993	-30.2	0.561	-0.786	0.933	-0.272	0.972	127.
0.3000-01	0.985	-57.2	0.141	-0.914	0.857	-0.382	0.938	122.
0.4000-01	0.976	-76.0	-0.262	-0.833	0.763	-0.466	0.894	117.
0.5000-01	0.967	-94.7	-0.556	-0.596	0.662	-0.522	0.843	110.
0.6000-01	0.959	-113.	-0.698	-0.286	0.562	-0.551	0.787	103.
0.7000-01	0.952	-132.	-0.696	0.2080-01	0.472	-0.558	0.731	95.4
0.8000-01	0.948	-151.	-0.582	0.271	0.394	-0.550	0.677	80.3
0.9000-01	0.945	-170.	-0.399	0.439	0.331	-0.534	0.628	81.9
0.100	0.939	171.	-0.186	0.517	0.281	-0.514	0.586	76.4
0.200	0.728	-15.0	-0.4700-01	-0.248	0.2600-01	-0.346	0.347	45.3
0.300	0.484	160.	0.5950-01	0.106	-0.4040-01	-0.249	0.252	32.9
0.400	0.303	-21.6	-0.4100-01	-0.4260-01	-0.7390-01	-0.181	0.195	25.5
0.500	0.171	158.	0.2280-01	0.1510-01	-0.9040-01	-0.132	0.160	20.9
0.600	0.6030-01	1.89	-0.6010-02	-0.5740-02	-0.103	-0.9190-01	0.138	18.0
0.700	0.5640-01	-163.	0.4450-02	0.4380-02	-0.9860-01	-0.5050-01	0.111	14.5
0.800	0.3300-01	-4.02	-0.3010-02	-0.6090-03	-0.8970-01	-0.2480-01	0.9300-01	12.1
0.900	0.2010-01	77.7	-0.2610-03	-0.1500-02	-0.7570-01	-0.3170-02	0.7570-01	9.68
1.00	0.1040-01	129.	0.3320-03	-0.5610-03	-0.6180-01	0.9540-02	0.6260-01	8.16



TABLE XXV

RUN ID F-04

CONTD.

OMEGA RAD/SEC	DEAD TIME=	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE		INPUT FRQ CONTENT	
				REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00	26.0	0.148	-66.1	0.922D-03	0.486D-03	-0.473D-03	0.705D-02	0.707D-02	0.922
3.00		0.904	-44.6	0.945D-03	-0.135D-03	0.849D-03	0.627D-03	0.106D-02	0.138
4.00		0.292	-126.	-0.503D-04	0.130D-03	-0.256D-03	-0.403D-03	0.477D-03	0.623D-01
5.00		2.36	99.9	-0.251D-03	-0.740D-03	-0.286D-03	0.157D-03	0.328D-03	0.428D-01
6.00		0.249	-149.	0.598D-04	0.527D-04	-0.316D-03	-0.579D-04	0.321D-03	0.419D-01
7.00		0.365	93.6	0.363D-05	-0.113D-03	-0.310D-03	0.929D-05	0.310D-03	0.404D-01
8.00		0.389	-120.	0.543D-04	0.137D-03	-0.374D-03	-0.581D-04	0.379D-03	0.494D-01
9.00		0.150	45.1	-0.382D-04	-0.238D-05	-0.190D-03	0.169D-03	0.254D-03	0.332D-01
10.0		0.145	-104.	0.200D-04	-0.828D-05	0.216D-04	0.148D-03	0.150D-03	0.196D-01

TABLE XXVI

RUN ID F-05

COMMENTS F- 12 PACKED BED HT 7 1/4 IN AIR RATE 2.0 CM SMP LOOP 3 LINE APP 1/6/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES		OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
		REAL	IMAGINARY	REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
0.0000 00	1.25	0.0000 00	0.0000 00	211.	0.0000 00	169.	0.0000 00	1.00	169.
0.1000-02	1.00	-0.377	-0.2040-01	1.00	-0.2040-01	1.00	-0.1380-01	1.00	169.
0.2000-02	1.00	-0.755	-0.4070-01	0.999	-0.4070-01	0.999	-0.2760-01	1.00	169.
0.3000-02	1.00	-1.13	-0.6100-01	0.998	-0.6100-01	0.999	-0.4130-01	0.999	169.
0.4000-02	1.00	-1.51	-0.8130-01	0.996	-0.8130-01	0.997	-0.5510-01	0.999	169.
0.5000-02	1.00	-1.89	-0.101	0.993	-0.101	0.996	-0.6870-01	0.998	169.
0.6000-02	1.00	-2.26	-0.122	0.990	-0.122	0.994	-0.8240-01	0.998	169.
0.7000-02	1.00	-2.64	-0.142	0.987	-0.142	0.992	-0.9600-01	0.997	168.
0.8000-02	1.00	-3.02	-0.161	0.982	-0.161	0.990	-0.109	0.996	168.
0.9000-02	1.00	-3.40	-0.181	0.978	-0.181	0.987	-0.123	0.995	168.
0.1000-01	0.999	-3.78	-0.201	0.973	-0.201	0.984	-0.136	0.994	168.
0.2000-01	0.998	-7.55	-0.383	0.894	-0.383	0.939	-0.263	0.975	165.
0.3000-01	0.994	-11.3	-0.533	0.775	-0.533	0.869	-0.372	0.946	160.
0.4000-01	0.990	-15.1	-0.640	0.630	-0.640	0.783	-0.458	0.907	153.
0.5000-01	0.984	-18.9	-0.703	0.474	-0.703	0.688	-0.520	0.862	146.
0.6000-01	0.976	-22.7	-0.725	0.323	-0.725	0.592	-0.557	0.813	137.
0.7000-01	0.967	-26.4	-0.713	0.186	-0.713	0.501	-0.575	0.762	129.
0.8000-01	0.957	-30.1	-0.678	0.7030-01	-0.678	0.419	-0.577	0.713	120.
0.9000-01	0.946	-33.7	-0.629	-0.2420-01	-0.629	0.347	-0.567	0.665	112.
0.100	0.935	-37.2	-0.573	-0.9880-01	-0.573	0.286	-0.552	0.621	105.
0.200	0.784	-76.5	-0.8140-01	-0.260	-0.8140-01	0.2310-01	-0.347	0.348	58.8
0.300	0.548	-112.	0.6950-01	-0.114	0.6950-01	-0.4050-01	-0.240	0.243	41.1
0.400	0.339	-143.	0.6270-01	-0.1720-01	0.6270-01	-0.7050-01	-0.179	0.192	32.4
0.500	0.183	-170.	0.2790-01	0.1180-01	0.2790-01	-0.9050-01	-0.139	0.166	28.0
0.600	0.9530-01	174.	0.7980-02	0.1040-01	0.7980-02	-0.100	-0.9420-01	0.137	23.2
0.700	0.4910-01	157.	0.7010-03	0.5850-02	0.7010-03	-0.104	-0.5990-01	0.120	20.3
0.800	0.3130-01	150.	0.7450-03	0.3120-02	0.7450-03	-0.9850-01	-0.2870-01	0.103	17.3
0.900	0.1980-01	82.3	-0.1740-02	-0.1040-03	-0.1740-02	-0.8750-01	-0.6500-02	0.8770-01	14.8
1.00	0.1360-01	24.0	-0.2380-03	-0.9720-03	-0.2380-03	-0.7240-01	0.1310-01	0.7360-01	12.4

TABLE XXVI

RUN 10 F-05

CONTD.

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
2.00	0.222D-01	89.7	-0.272D-03	0.974D-04	0.433D-02	0.123D-01	0.130D-01	2.20
3.00	0.131	-43.2	0.189D-03	-0.232D-03	0.226D-02	-0.302D-03	0.228D-02	0.385
4.00	0.850D-01	150.	0.543D-04	0.315D-04	-0.372D-03	-0.639D-03	0.739D-03	0.125
5.00	0.214	79.7	-0.914D-04	-0.854D-05	-0.114D-03	0.406D-03	0.422D-03	0.713D-01
6.00	1.21	-129.	-0.896D-04	-0.103D-04	0.527D-04	-0.525D-04	0.744D-04	0.126D-01
7.00	0.307	72.1	0.136D-04	-0.916D-04	-0.270D-03	-0.134D-03	0.301D-03	0.509D-01
8.00	0.433	105.	-0.765D-04	-0.984D-04	-0.176D-03	0.228D-03	0.288D-03	0.486D-01
9.00	0.915D-01	35.0	-0.164D-04	0.325D-04	0.565D-04	0.394D-03	0.398D-03	0.673D-01
10.0	0.151	-98.5	-0.160D-04	-0.899D-06	0.216D-04	-0.104D-03	0.106D-03	0.180D-01

TABLE XXVI CONT'D.

RUN ID F-05

1/6/69

COMMENTS F- 12 PACKED BED HT 7 1/4 IN AIR RATE 2.0 CM SMP LOOP 3 LINE APP

OMEGA RAD/SEC	AMPLITUDE FATH	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FRFQ NORMALIZED	CONTENT ACTUAL
			OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY				
0.0000-00	1.25	0.0000-00	211.	0.0000-00	169.	0.0000-00	1.00	169.
0.1000-02	1.00	-1.86	0.999	-0.4620-01	1.00	-0.1380-01	1.00	169.
0.2000-02	1.00	-3.71	0.995	-0.9220-01	0.999	-0.2760-01	1.00	169.
0.3000-02	1.00	-5.57	0.990	-0.138	0.999	-0.4130-01	0.999	169.
0.4000-02	1.00	-7.42	0.982	-0.183	0.997	-0.5510-01	0.999	169.
0.5000-02	1.00	-9.28	0.972	-0.228	0.996	-0.6870-01	0.998	169.
0.6000-02	1.00	-11.1	0.959	-0.273	0.994	-0.8240-01	0.998	169.
0.7000-02	1.00	-13.0	0.945	-0.316	0.992	-0.9600-01	0.997	168.
0.8000-02	1.00	-14.8	0.928	-0.359	0.990	-0.109	0.996	168.
0.9000-02	1.00	-16.7	0.910	-0.401	0.987	-0.123	0.995	168.
0.1000-01	0.999	-18.6	0.889	-0.442	0.984	-0.136	0.994	168.
0.2000-01	0.998	-37.1	0.589	-0.774	0.939	-0.263	0.975	165.
0.3000-01	0.994	-55.7	0.182	-0.923	0.869	-0.372	0.946	160.
0.4000-01	0.990	-74.3	-0.226	-0.369	0.783	-0.458	0.907	153.
0.5000-01	0.984	-92.8	-0.544	-0.650	0.688	-0.520	0.862	146.
0.6000-01	0.976	-111.	-0.717	-0.339	0.592	-0.557	0.813	137.
0.7000-01	0.967	-130.	-0.737	-0.1510-01	0.501	-0.575	0.762	129.
0.8000-01	0.957	-148.	-0.630	0.259	0.419	-0.577	0.713	120.
0.9000-01	0.946	-167.	-0.443	0.447	0.347	-0.567	0.665	112.
0.100	0.935	175.	-0.221	0.537	0.286	-0.552	0.621	105.
0.200	0.784	-12.1	-0.3930-01	-0.270	0.2310-01	-0.347	0.348	58.8
0.300	0.548	165.	0.5610-01	0.121	-0.4050-01	-0.240	0.243	41.1
0.400	0.339	-14.4	-0.3820-01	-0.5260-01	-0.7050-01	-0.179	0.192	32.4
0.500	0.183	171.	0.2030-01	0.2240-01	-0.9050-01	-0.139	0.166	28.0
0.600	0.9530-01	7.34	-0.8310-02	-0.1010-01	-0.100	-0.9420-01	0.137	23.2
0.700	0.4910-01	-158.	0.3620-02	0.4650-02	-0.104	-0.5990-01	0.120	20.3
0.800	0.3130-01	47.8	-0.1410-02	-0.2890-02	-0.9850-01	-0.2870-01	0.103	17.3
0.900	0.1980-01	-168.	0.1670-02	0.4840-03	-0.8750-01	-0.6500-02	0.8770-01	14.8
1.00	0.1360-01	-14.2	-0.9110-03	0.4150-03	-0.7240-01	0.1310-01	0.7360-01	12.4

TABLE XXVI

RUN ID F-05

CONTO.

OMEGA RAD/SEC	DEAD TIME	25.8	PULSES NORMALIZED				PULSES NORMALIZED				INPUT FREQ NORMALIZED	CONTENT ACTUAL
			AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY				
2.00	0.2220-01	13.3	0.3110-04	0.2870-03	0.4330-02	0.1230-01	0.1300-01	2.20				
3.00	0.131	-158.	-0.2890-03	-0.7490-04	0.2260-02	-0.3020-03	0.2280-02	0.385				
4.00	0.8500-01	-2.59	-0.3400-04	-0.5280-04	-0.3720-03	-0.6390-03	0.7390-03	0.125				
5.00	0.218	-111.	0.9130-04	-0.9310-05	-0.1140-03	0.4060-03	0.4220-03	0.7130-01				
6.00	1.21	2.06	0.6610-04	-0.6130-04	0.5270-04	-0.5250-04	0.7440-04	0.1260-01				
7.00	0.307	164.	0.9090-04	0.1740-04	-0.2700-03	-0.1340-03	0.3010-03	0.5090-01				
8.00	0.433	159.	0.3500-04	-0.1200-03	-0.1760-03	0.2280-03	0.2880-03	0.4860-01				
9.00	0.9150-01	50.9	-0.2470-04	0.2680-04	0.5650-04	0.3940-03	0.3980-03	0.6730-01				
10.0	0.151	-121.	-0.1520-04	0.5260-05	0.2160-04	-0.1040-03	0.1060-03	0.1800-01				

TABLE XXVII

RUN ID F-06

COMMENTS F-12 PACKED BED HT 7 1/4 IN AIR RATE 2.0 CM SMP LDRP 3 LINE APP 1/6/69

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE NORMALIZED		INPUT PULSE NORMALIZED		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000-00	0.971	0.0000-00	184.	0.0000-00	189.	0.0000-00	1.00	189.
0.1000-02	1.00	-0.242	1.00	-0.2010-01	1.00	-0.1590-01	1.00	189.
0.2000-02	1.00	-0.484	0.999	-0.4030-01	0.999	-0.3180-01	1.00	189.
0.3000-02	1.00	-0.727	0.998	-0.6030-01	0.998	-0.4760-01	0.999	189.
0.4000-02	1.00	-0.971	0.996	-0.8040-01	0.996	-0.6340-01	0.998	189.
0.5000-02	1.00	-1.22	0.993	-0.100	0.994	-0.7910-01	0.997	189.
0.6000-02	1.00	-1.46	0.990	-0.120	0.992	-0.9480-01	0.996	189.
0.7000-02	1.00	-1.71	0.987	-0.140	0.989	-0.110	0.995	198.
0.8000-02	1.00	-1.96	0.983	-0.160	0.985	-0.126	0.993	188.
0.9000-02	1.00	-2.21	0.978	-0.179	0.981	-0.141	0.991	188.
0.1000-01	1.00	-2.46	0.973	-0.198	0.977	-0.156	0.989	187.
0.2000-01	1.02	-5.16	0.897	-0.380	0.913	-0.293	0.959	182.
0.3000-01	1.03	-8.28	0.780	-0.529	0.821	-0.439	0.913	173.
0.4000-01	1.05	-12.0	0.637	-0.638	0.719	-0.469	0.858	163.
0.5000-01	1.06	-16.2	0.482	-0.703	0.620	-0.508	0.802	152.
0.6000-01	1.07	-20.8	0.331	-0.727	0.532	-0.527	0.749	142.
0.7000-01	1.06	-25.4	0.192	-0.718	0.455	-0.535	0.702	133.
0.8000-01	1.04	-29.7	0.7420-01	-0.683	0.387	-0.535	0.661	125.
0.9000-01	1.02	-33.4	-0.2700-01	-0.633	0.324	-0.531	0.622	118.
0.100	0.999	-36.6	-0.9730-01	-0.575	0.265	-0.520	0.584	111.
0.200	0.876	-76.3	-0.262	-0.8610-01	0.2450-01	-0.313	0.314	59.5
0.300	0.598	-114.	-0.117	0.6930-01	-0.2760-01	-0.226	0.228	43.1
0.400	0.404	-144.	-0.1820-01	0.6670-01	-0.5970-01	-0.161	0.171	32.4
0.500	0.236	-178.	0.1440-01	0.2980-01	-0.6580-01	-0.124	0.140	26.6
0.600	0.113	156.	0.1230-01	0.5600-02	-0.7910-01	-0.8980-01	0.120	22.7
0.700	0.6250-01	128.	0.6130-02	-0.1580-02	-0.7980-01	-0.6240-01	0.101	19.2
0.800	0.4430-01	100.	0.2270-02	-0.3020-02	-0.7640-01	-0.3830-01	0.8550-01	16.2
0.900	0.1280-01	66.1	-0.1160-03	-0.8840-03	-0.6700-01	-0.1970-01	0.6980-01	13.2
1.00	0.2370-01	84.2	0.1880-04	-0.1440-02	-0.6030-01	-0.6920-02	0.6070-01	11.5

TABLE XXVII

RUN ID F-06

CONTD.

OMEGA RAD/SEC	DEAD TIME=	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
				REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00	0.0000 00	0.2740-01	155.	-0.2420-04	-0.2770-03	-0.3410-02	0.9560-02	0.1020-01	1.92
3.00		0.345	-98.6	0.5040-03	-0.3120-03	0.6750-03	0.1580-02	0.1720-02	0.326
4.00		3.50	85.7	-0.6060-03	-0.1730-03	-0.6240-04	0.1690-03	0.1800-03	0.3410-01
5.00		0.345	-43.4	-0.7400-04	0.9650-05	-0.1750-03	-0.1270-03	0.2160-03	0.4100-01
6.00		1.50	-21.2	-0.1790-03	0.8040-04	-0.1310-03	0.6850-05	0.1310-03	0.2490-01
7.00		0.311	-30.3	-0.1220-03	-0.4360-04	-0.2670-03	-0.3180-03	0.4160-03	0.7870-01
8.00		0.649	44.0	-0.1560-03	-0.1050-03	-0.2860-03	0.5130-04	0.2900-03	0.5500-01
9.00		0.286	16.8	-0.4450-04	0.6690-04	-0.8160-04	0.2690-03	0.2810-03	0.5330-01
10.0		0.447	152.	-0.1310-04	0.1400-04	0.4060-04	-0.1410-04	0.4300-04	0.8140-02

TABLE XXVII CONTD.

RUN ID F-06

1/6/69

COMMENTS F-12 PACKED RED HT 7 1/4 IN AIR RATE 2.0 CM SMP LOOP 3 LINE APP

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			RFAL	IFAL	REAL	IMAGINARY		
0.0000-00	0.971	0.0000 00	184.	0.0000 00	189.	0.0000 00	1.00	189.
0.1000-02	1.00	-1.73	0.999	-0.4610-01	1.00	-0.1590-01	1.00	189.
0.2000-02	1.00	-3.46	0.995	-0.9210-01	0.999	-0.3180-01	1.00	189.
0.3000-02	1.00	-5.20	0.990	-0.138	0.998	-0.4760-01	0.999	189.
0.4000-02	1.00	-6.93	0.982	-0.183	0.996	-0.6340-01	0.998	189.
0.5000-02	1.00	-8.66	0.972	-0.228	0.994	-0.7910-01	0.997	189.
0.6000-02	1.00	-10.4	0.960	-0.273	0.992	-0.9480-01	0.996	189.
0.7000-02	1.00	-12.1	0.945	-0.316	0.989	-0.110	0.995	188.
0.8000-02	1.00	-13.9	0.929	-0.359	0.985	-0.126	0.993	188.
0.9000-02	1.00	-15.6	0.910	-0.401	0.981	-0.141	0.991	188.
0.1000-01	1.00	-17.4	0.890	-0.442	0.977	-0.156	0.989	187.
0.2000-01	1.02	-34.9	0.590	-0.775	0.913	-0.293	0.959	182.
0.3000-01	1.03	-53.0	0.182	-0.925	0.821	-0.398	0.913	173.
0.4000-01	1.05	-71.6	-0.228	-0.872	0.719	-0.469	0.858	163.
0.5000-01	1.06	-90.7	-0.549	-0.653	0.620	-0.508	0.802	152.
0.6000-01	1.07	-110.	-0.724	-0.339	0.532	-0.527	0.749	142.
0.7000-01	1.06	-130.	-0.743	-0.9550-02	0.455	-0.535	0.702	133.
0.8000-01	1.04	-149.	-0.632	0.268	0.387	-0.535	0.661	125.
0.9000-01	1.02	-167.	-0.439	0.456	0.324	-0.531	0.622	118.
0.100	0.999	174.	-0.213	0.543	0.265	-0.520	0.584	111.
0.200	0.876	-14.2	-0.4650-01	-0.271	0.2450-01	-0.313	0.314	59.5
0.300	0.598	159.	0.6280-01	0.121	-0.2760-01	-0.226	0.228	43.1
0.400	0.404	-20.2	-0.4500-01	-0.5250-01	-0.5970-01	-0.161	0.171	32.4
0.500	0.236	157.	0.2560-01	0.2100-01	-0.6580-01	-0.124	0.140	26.6
0.600	0.113	-18.0	-0.1170-01	-0.6900-02	-0.7910-01	-0.8980-01	0.120	22.7
0.700	0.6250-01	165.	0.5840-02	0.2450-02	0.7980-01	-0.6240-01	0.101	19.2
0.800	0.4430-01	-11.4	-0.3650-02	-0.9920-03	-0.7640-01	-0.3830-01	0.8550-01	16.2
0.900	0.1280-01	165.	0.8910-03	0.2830-04	-0.6700-01	-0.1970-01	0.6980-01	13.2
1.00	0.2370-01	34.5	-0.1090-02	-0.9470-03	-0.6030-01	-0.6920-02	0.6070-01	11.5



TABLE XXVII

RUN ID F-06

CONTD.

OMEGA RAD/SEC	DEAD TIME=	26.0	PULSES NORMALIZED		PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
			AMPLITUDE RATIO	AMPLITUDE RATIO		REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00			0.2740-01	56.0	-0.2700-03	0.6910-04	-0.3410-02	0.9560-02	0.1020-01	1.92	
3.00			0.345	112.	-0.5930-03	0.7990-05	0.6750-03	0.1580-02	0.1720-02	0.326	
4.00			3.50	-113.	0.6290-03	-0.3090-04	-0.6240-04	0.1690-03	0.1800-03	0.3410-01	
5.00			0.345	68.1	0.1820-04	-0.7240-04	-0.1750-03	-0.1270-03	0.2160-03	0.4100-01	
6.00			1.50	40.7	-0.1550-03	-0.1200-03	-0.1310-03	0.6850-05	0.1310-03	0.2490-01	
7.00			0.311	-18.1	-0.1100-03	-0.6830-04	-0.2670-03	-0.3180-03	0.4160-03	0.7870-01	
8.00			0.649	6.51	-0.1880-03	0.1210-04	-0.2860-03	0.5130-04	0.2900-03	0.5500-01	
9.00			0.286	-70.4	0.6470-04	0.4770-04	-0.8160-04	0.2690-03	0.2810-03	0.5330-01	
10.0			0.447	15.5	0.1920-04	-0.1240-05	0.4060-04	-0.1410-04	0.4300-04	0.8140-02	

ORTRAN \*\* STOP

TABLE XXVIII

RUN 10 F-07

COMMENTS F-12 PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 3 LINE APP 1/7/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	0.849	0.0000 00	302.	0.0000 00	356.	0.0000 00	1.00	356.
0.1000-02	1.00	-0.312	1.00	-0.1810-01	1.00	-0.1270-01	1.00	356.
0.2000-02	1.00	-0.625	0.999	-0.3620-01	0.999	-0.2530-01	1.00	356.
0.3000-02	1.00	-0.937	0.998	-0.5430-01	0.999	-0.3790-01	0.999	356.
0.4000-02	1.00	-1.25	0.996	-0.7230-01	0.998	-0.5060-01	0.999	356.
0.5000-02	1.00	-1.56	0.994	-0.9020-01	0.997	-0.6310-01	0.999	355.
0.6000-02	0.999	-1.87	0.991	-0.108	0.995	-0.7570-01	0.998	355.
0.7000-02	0.999	-2.18	0.988	-0.126	0.993	-0.8820-01	0.997	355.
0.8000-02	0.999	-2.49	0.985	-0.143	0.991	-0.101	0.996	355.
0.9000-02	0.998	-2.80	0.981	-0.161	0.989	-0.113	0.995	354.
0.1000-01	0.998	-3.11	0.976	-0.178	0.986	-0.125	0.994	354.
0.2000-01	0.993	-6.14	0.909	-0.340	0.947	-0.243	0.977	348.
0.3000-01	0.985	-9.02	0.808	-0.473	0.885	-0.346	0.950	338.
0.4000-01	0.976	-11.7	0.687	-0.570	0.807	-0.429	0.914	325.
0.5000-01	0.968	-14.2	0.560	-0.631	0.720	-0.490	0.871	310.
0.6000-01	0.962	-16.5	0.437	-0.661	0.630	-0.530	0.823	293.
0.7000-01	0.960	-18.9	0.324	-0.668	0.544	-0.549	0.773	275.
0.8000-01	0.961	-21.3	0.224	-0.658	0.466	-0.553	0.723	257.
0.9000-01	0.964	-24.0	0.137	-0.636	0.398	-0.545	0.675	240.
0.100	0.967	-27.0	0.6200-01	-0.607	0.342	-0.530	0.631	224.
0.200	0.845	-55.1	0.224	-0.236	0.7730-01	-0.378	0.385	137.
0.300	0.693	-80.8	-0.193	-0.2780-01	0.5120-02	-0.282	0.282	100.
0.400	0.538	-106.	-0.108	0.5610-01	-0.4630-01	-0.221	0.226	80.4
0.500	0.401	-128.	-0.3680-01	0.6570-01	-0.7290-01	-0.173	0.188	66.8
0.600	0.279	-151.	0.4790-02	0.4460-01	-0.9160-01	-0.132	0.161	57.2
0.700	0.178	-176.	0.1700-01	0.1780-01	-0.102	-0.9330-01	0.138	49.1
0.800	0.115	164.	0.1280-01	0.3980-02	-0.5840-01	-0.6340-01	0.117	41.7
0.900	0.4420-01	141.	0.4270-02	-0.1320-02	-0.9410-01	-0.3720-01	0.101	36.0
1.00	0.1020-01	122.	0.5860-03	-0.6350-03	-0.6370-01	-0.1540-01	0.8510-01	30.3

TABLE XXVIII

KUN 10 F-07

(CONT'D.)

OMEGA RAD/SEC	DEAD TIME*	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
				REAL	IMAGINARY	PEAK	IMAGINARY		
2.00	0.0000 00	0.6310-01	144.	-0.3120-03	-0.1110-02	-0.6220-02	0.1710-01	0.1820-01	6.49
3.00		0.131	-53.5	0.4540-03	0.7870-04	0.1580-02	0.3160-02	0.3530-02	1.26
4.00		0.161	65.0	0.1680-04	0.1290-03	0.7720-03	0.2450-03	0.8100-03	0.288
5.00		0.249	87.7	0.8670-04	-0.5330-04	-0.2000-03	-0.3570-03	0.4090-03	0.146
6.00		1.24	124.	0.1490-03	-0.3530-03	-0.3040-03	0.5750-04	0.3090-03	0.110
7.00		1.86	-16.8	0.2120-03	0.2200-03	0.7510-04	0.1460-03	0.1640-03	0.5850-01
8.00		0.173	-50.7	-0.1740-04	-0.2260-04	0.3730-04	-0.1600-03	0.1650-03	0.5860-01
9.00		1.46	-33.6	-0.1520-04	-0.8360-04	0.2300-04	-C.5340-04	0.5810-04	0.2070-01
10.0		0.608	28.5	-0.4810-04	-0.9640-04	-0.1450-03	-0.1020-03	0.1770-03	0.6310-01

TABLE XXVIII CONT'D.

RUN ID F-07

COMMENTS F-12 PACKED RED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 3 LINE APP 1/7/69

DEAD TIME= 12.8 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	COEFFICIENT ACTUAL
0.000D 00	0.849	0.000D 00	302.	0.000D 00	356.	0.000D 00	1.00	356.
0.100D-02	1.00	-1.05	0.999	-0.309D-01	1.00	-0.127D-01	1.00	356.
0.200D-02	1.00	-2.09	0.998	-0.618D-01	0.999	-0.253D-01	1.00	356.
0.300D-02	1.00	-3.14	0.995	-0.925D-01	0.999	-0.379D-01	0.999	356.
0.400D-02	1.00	-4.18	0.991	-0.123	0.998	-0.506D-01	0.999	356.
0.500D-02	1.00	-5.23	0.986	-0.154	0.997	-0.631D-01	0.999	355.
0.600D-02	0.999	-6.27	0.980	-0.184	0.995	-0.757D-01	0.998	355.
0.700D-02	0.999	-7.32	0.973	-0.214	0.993	-0.882D-01	0.997	355.
0.800D-02	0.999	-8.36	0.965	-0.243	0.991	-0.101	0.996	355.
0.900D-02	0.998	-9.40	0.956	-0.273	0.989	-0.113	0.995	354.
0.100D-01	0.998	-10.4	0.946	-0.301	0.986	-0.125	0.994	354.
0.200D-01	0.993	-20.8	0.793	-0.559	0.947	-0.243	0.977	348.
0.300D-01	0.985	-31.0	0.572	-0.741	0.885	-0.346	0.950	338.
0.400D-01	0.976	-41.0	0.320	-0.833	0.807	-0.429	0.914	325.
0.500D-01	0.968	-50.9	0.719D-01	-0.840	0.720	-0.490	0.871	310.
0.600D-01	0.962	-60.5	-0.145	-0.779	0.630	-0.530	0.823	293.
0.700D-01	0.960	-70.2	-0.319	-0.670	0.544	-0.549	0.773	275.
0.800D-01	0.961	-80.0	-0.445	-0.534	0.466	-0.553	0.723	257.
0.900D-01	0.964	-90.0	-0.525	-0.384	0.398	-0.545	0.675	240.
0.100	0.967	-100.	-0.563	-0.233	0.342	-0.530	0.631	224.
0.200	0.845	158.	0.577D-01	0.321	0.773D-01	-0.378	0.385	137.
0.300	0.693	59.2	0.166	-0.103	-0.512D-02	-0.282	0.282	100.
0.400	0.538	-39.0	-0.942D-01	-0.768D-01	-0.463D-01	-0.221	0.226	80.4
0.500	0.401	-135.	-0.289D-01	0.695D-01	-0.729D-01	-0.173	0.188	66.8
0.600	0.279	129.	0.448D-01	0.301D-02	-0.116D-01	-0.132	0.161	57.2
0.700	0.178	30.4	-0.722D-02	-0.235D-01	-0.102	-0.933D-01	0.138	49.1
0.800	0.115	-62.2	-0.117D-01	0.662D-02	-0.984D-01	-0.634D-01	0.117	41.7
0.900	0.442D-01	-159.	0.329D-02	0.304D-02	-0.41D-01	-0.372D-01	0.101	36.0
1.00	0.102D-01	109.	0.423D-03	-0.754D-03	-0.837D-01	-0.154D-01	0.851D-01	30.3

TABLE XXVIII

RUN ID F-07

LUNTO.

OMEGA RAD/SEC	DEAD TIME=	12.8	PULSES NORMALIZED		PHASE ANGLE DEGREES	INPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
			AMPLITUDE RATIO	PHASE ANGLE DEGREES		OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00	0.6310-01	118.	-0.7770-03	-0.8490-03	-0.6220-02	0.1710-01	0.1820-01	6.49			
3.00	0.131	-93.7	0.3980-03	-0.2330-03	0.1580-02	0.3160-02	0.3530-02	1.26			
4.00	0.161	11.4	0.1140-03	0.6330-04	0.7720-03	0.2450-03	0.8100-03	0.288			
5.00	0.249	20.8	-0.1510-04	-0.1010-03	-0.2000-03	-0.3570-03	0.4090-03	0.146			
6.00	1.24	43.3	-0.3230-03	-0.2060-03	-0.3040-03	0.5750-04	0.3090-03	0.110			
7.00	1.86	-110.	0.2060-03	-0.2260-03	0.7510-04	0.1460-03	0.1640-03	0.5850-01			
8.00	0.173	-158.	-0.1650-04	0.2320-04	0.3730-04	-0.1600-03	0.1650-03	0.5860-01			
9.00	1.46	-154.	-0.6440-04	0.5550-04	0.2300-04	-0.5340-04	0.5810-04	0.2070-01			
10.0	0.608	-105.	-0.3620-04	0.1010-03	-0.1450-03	-0.1020-03	0.1770-03	0.6310-01			

ORTRAN \*\* STOP

TABLE XXIX

RUN ID F-09

COMMENTS F-12 PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 4 LINE APP 1/7/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	1.53	0.0000 00	671.	0.0000 00	439.	0.0000 00	1.00	439.
0.1000-02	1.00	-0.261	1.00	-0.1750-01	1.00	-0.1300-01	1.00	439.
0.2000-02	1.00	-0.522	0.999	-0.3500-01	0.999	-0.2590-01	1.00	439.
0.3000-02	1.00	-0.782	0.998	-0.5250-01	0.999	-0.3890-01	0.999	439.
0.4000-02	1.00	-1.04	0.996	-0.6990-01	0.998	-0.5180-01	0.999	439.
0.5000-02	1.00	-1.30	0.994	-0.8730-01	0.996	-0.6470-01	0.998	439.
0.6000-02	0.999	-1.56	0.992	-0.105	0.995	-0.7750-01	0.998	438.
0.7000-02	0.999	-1.82	0.989	-0.122	0.993	-0.9030-01	0.997	438.
0.8000-02	0.999	-2.08	0.985	-0.139	0.991	-0.103	0.996	437.
0.9000-02	0.999	-2.34	0.981	-0.156	0.988	-0.116	0.995	437.
0.1000-01	0.998	-2.59	0.977	-0.172	0.985	-0.128	0.994	436.
0.2000-01	0.994	-5.08	0.912	-0.328	0.943	-0.247	0.975	428.
0.3000-01	0.988	-7.39	0.816	-0.454	0.878	-0.349	0.945	415.
0.4000-01	0.984	-9.52	0.704	-0.547	0.798	-0.430	0.906	398.
0.5000-01	0.982	-11.5	0.587	-0.608	0.710	-0.488	0.861	378.
0.6000-01	0.983	-13.5	0.474	-0.643	0.622	-0.523	0.813	357.
0.7000-01	0.988	-15.7	0.369	-0.659	0.540	-0.541	0.764	336.
0.8000-01	0.994	-18.1	0.272	-0.658	0.466	-0.545	0.717	315.
0.9000-01	0.998	-20.8	0.184	-0.646	0.402	-0.539	0.673	295.
0.100	0.998	-23.6	0.106	-0.622	0.347	-0.529	0.632	278.
0.200	0.954	-49.6	-0.223	-0.285	0.7600-01	-0.372	0.380	167.
0.300	0.842	-76.4	-0.227	-0.5090-01	-0.4320-02	-0.276	0.276	121.
0.400	0.684	-101.	-0.138	0.5960-01	-0.4610-01	0.215	0.220	96.6
0.500	0.522	-124.	-0.5250-01	0.8330-01	-0.7610-01	-0.173	0.189	82.9
0.600	0.390	-147.	0.2440-02	0.6270-01	-0.9220-01	-0.132	0.161	70.7
0.700	0.278	-167.	0.2150-01	0.3170-01	-0.101	-0.9390-01	0.138	60.5
0.800	0.184	175.	0.1990-01	0.9890-02	-0.103	-0.6210-01	0.121	53.0
0.900	0.117	153.	0.1190-01	-0.1540-02	-0.9680-01	-0.3400-01	0.103	45.1
1.00	0.7570-01	142.	0.5740-02	-0.3280-02	-0.8640-01	-0.1240-01	0.8730-01	38.3

TABLE XXIX

RUN ID F-09

CONTD.

DEAD TIME= 0.000D 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ		CONTENT	
			REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL	NORMALIZED	ACTUAL
2.00	0.204D-01	36.5	-0.286D-03	0.191D-03	-0.569D-02	0.159D-01	0.168D-01	0.168D-01	7.40	
3.00	0.137	-144.	-0.326D-04	-0.335D-03	0.161D-02	0.184D-02	0.245D-02	0.245D-02	1.08	
4.00	0.340	-83.6	-0.370D-04	-0.211D-03	0.607D-03	-0.178D-03	0.632D-03	0.632D-03	0.278	
5.00	0.646	130.	-0.125D-03	0.874D-04	0.228D-03	0.616D-04	0.236D-03	0.236D-03	0.104	
6.00	0.120	-173.	-0.457D-04	-0.329D-04	0.412D-03	0.224D-03	0.469D-03	0.469D-03	0.206	
7.00	0.227	42.5	-0.859D-04	-0.570D-04	-0.449D-03	0.709D-04	0.455D-03	0.455D-03	0.200	
8.00	0.961D-01	35.2	-0.538D-04	-0.328D-04	-0.655D-03	0.441D-04	0.656D-03	0.656D-03	0.288	
9.00	0.747D-01	110.	-0.519D-05	-0.349D-04	-0.414D-03	0.228D-03	0.473D-03	0.473D-03	0.208	
10.0	0.722D-01	-2.60	0.960D-05	-0.772D-05	0.138D-03	-0.101D-03	0.171D-03	0.171D-03	0.750D-01	

TABLE XXIX CONTD.

RUN ID F-09

1/7/69

COMMENTS F-12 PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 4 LINE APP

DEAD TIME= 11.2 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000-00	1.53	0.0000 00	671.	0.0000 00	439.	0.0000 00	1.00	439.
0.1000-02	1.00	-0.903	1.00	-0.2870-01	1.00	-0.1300-01	1.00	439.
0.2000-02	1.00	-1.81	0.998	-0.5740-01	0.999	-0.2590-01	1.00	439.
0.3000-02	1.00	-2.71	0.996	-0.8600-01	0.999	-0.3890-01	0.999	439.
0.4000-02	1.00	-3.61	0.992	-0.114	0.998	-0.5180-01	0.999	439.
0.5000-02	1.00	-4.51	0.988	-0.143	0.996	-0.6470-01	0.998	439.
0.6000-02	0.999	-5.41	0.982	-0.171	0.995	-0.7750-01	0.998	438.
0.7000-02	0.999	-6.31	0.976	-0.199	0.993	-0.9030-01	0.997	438.
0.8000-02	0.999	-7.21	0.969	-0.226	0.991	-0.103	0.996	437.
0.9000-02	0.999	-8.11	0.961	-0.254	0.988	-0.116	0.995	437.
0.1000-01	0.998	-9.01	0.951	-0.280	0.985	-0.128	0.994	436.
0.2000-01	0.994	-17.9	0.816	-0.522	0.943	-0.247	0.975	428.
0.3000-01	0.988	-26.6	0.621	-0.698	0.878	-0.349	0.945	415.
0.4000-01	0.984	-35.2	0.397	-0.798	0.798	-0.430	0.906	398.
0.5000-01	0.982	-43.6	0.174	-0.827	0.710	-0.488	0.861	378.
0.6000-01	0.983	-52.0	-0.2950-01	-0.799	0.622	-0.523	0.813	357.
0.7000-01	0.988	-60.6	-0.204	-0.727	0.540	-0.541	0.764	336.
0.8000-01	0.994	-69.4	-0.344	-0.624	0.466	-0.545	0.717	315.
0.9000-01	0.998	-78.5	-0.448	-0.500	0.402	-0.539	0.673	295.
0.100	0.998	-87.7	-0.514	-0.367	0.347	-0.529	0.632	278.
0.200	0.954	-178.	-0.8510-01	0.352	0.7600-01	-0.372	0.380	167.
0.300	0.842	91.0	0.232	0.5830-03	-0.4320-02	-0.276	0.276	121.
0.400	0.684	2.06	-0.2620-01	-0.148	-0.4610-01	-0.215	0.220	96.6
0.500	0.522	-84.8	-0.9330-01	0.3140-01	-0.7610-01	-0.173	0.189	82.9
0.600	0.390	-172.	0.2870-01	0.5580-01	-0.9220-01	-0.132	0.161	70.7
0.700	0.278	104.	0.3200-01	-0.2100-01	-0.101	-0.9390-01	0.138	60.5
0.800	0.184	22.0	-0.1340-01	-0.1780-01	-0.103	-0.6210-01	0.121	53.0
0.900	0.117	-64.2	-0.8530-02	0.8500-02	-0.9680-01	-0.3400-01	0.103	45.1
1.000	0.7570-01	-140.	0.4380-02	0.4950-02	-0.8640-01	-0.1240-01	0.8730-01	38.3



TABLE XXIX

RUN ID F-09

CONTD.

OMEGA RAD/SEC	DEAD TIME	11.2	PULSES NORMALIZED		PHASE ANGLE DEGREES		OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
			AMPLITUDE RATIO	PHASE ANGLE DEGREES	REAL	IMAGINARY	REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00	0.2040-01	-167.	0.1860-03	-0.2890-03	-0.5690-02	0.1590-01	0.1680-01	7.40				
3.00	0.137	90.5	-0.2550-03	0.2190-03	0.1610-02	0.1840-02	0.2450-02	1.08				
4.00	0.340	-130.	-0.1800-03	-0.1180-03	0.6070-03	-0.1780-03	0.6320-03	0.278				
5.00	0.646	161.	-0.1520-03	0.9240-05	0.2280-03	0.6160-04	0.2360-03	0.104				
6.00	0.120	-63.0	0.4640-04	-0.3190-04	0.4120-03	0.2240-03	0.4690-03	0.206				
7.00	0.227	-129.	0.7710-04	0.6840-04	-0.4490-03	0.7090-04	0.4550-03	0.200				
8.00	0.9610-01	-58.5	-0.2930-04	0.5590-04	-0.6550-03	0.4410-04	0.6560-03	0.288				
9.00	0.7470-01	94.9	-0.1430-04	-0.3230-04	-0.4140-03	0.2280-03	0.4730-03	0.208				
10.0	0.7220-01	60.3	0.1120-04	0.5020-05	0.1380-03	-0.1010-03	0.1710-03	0.7500-01				

TABLE XXX

RUN ID F-10

1/7/69

COMMENTS F-12 PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 3 LINE APP

DEAD TIME= 0.0000 00 PULSES NOKMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
0.0000 00	0.992	0.0000 00	359.	0.0000 00	361.	0.0000 00	1.00	361.
0.1000-02	1.00	-0.272	1.00	-0.1770-01	1.00	-0.1290-01	1.00	361.
0.2000-02	1.00	-0.543	0.999	-0.3530-01	0.999	-0.2590-01	1.00	361.
0.3000-02	1.00	-0.815	0.998	-0.5300-01	0.999	-0.3880-01	0.999	361.
0.4000-02	1.00	-1.09	0.997	-0.7050-01	0.998	-0.5160-01	0.999	361.
0.5000-02	1.00	-1.36	0.995	-0.8810-01	0.996	-0.6450-01	0.998	361.
0.6000-02	1.00	-1.63	0.992	-0.106	0.995	-0.7720-01	0.998	360.
0.7000-02	1.00	-1.90	0.990	-0.123	0.993	-0.9000-01	0.997	360.
0.8000-02	1.00	-2.18	0.986	-0.140	0.991	-0.103	0.996	360.
0.9000-02	1.00	-2.45	0.983	-0.157	0.988	-0.115	0.995	359.
0.1000-01	1.00	-2.72	0.979	-0.175	0.985	-0.128	0.994	359.
0.2000-01	1.00	-5.48	0.917	-0.336	0.943	-0.246	0.975	352.
0.3000-01	1.01	-8.32	0.823	-0.474	0.878	-0.349	0.945	341.
0.4000-01	1.01	-11.3	0.704	-0.581	0.797	-0.429	0.905	327.
0.5000-01	1.01	-14.3	0.573	-0.654	0.709	-0.486	0.859	310.
0.6000-01	1.01	-17.5	0.441	-0.693	0.621	-0.520	0.810	293.
0.7000-01	1.01	-20.9	0.316	-0.702	0.538	-0.536	0.759	274.
0.8000-01	1.01	-24.3	0.205	-0.689	0.465	-0.538	0.711	257.
0.9000-01	1.00	-27.7	0.110	-0.659	0.402	-0.531	0.666	241.
0.100	0.993	-31.1	0.3150-01	-0.621	0.350	-0.519	0.626	226.
0.200	0.890	-62.1	-0.254	-0.218	0.8290-01	-0.367	0.376	136.
0.300	0.722	-91.3	-0.199	0.2140-02	0.3470-02	-0.276	0.276	99.7
0.400	0.545	-119.	-0.9430-01	0.7610-01	-0.3730-01	-0.219	0.222	80.4
0.500	0.380	-145.	-0.1810-01	0.6940-01	-0.6530-01	-0.177	0.189	68.2
0.600	0.240	-167.	0.1280-01	0.3750-01	-0.8820-01	-0.140	0.165	59.6
0.700	0.150	171.	0.1670-01	0.1260-01	-0.9730-01	-0.100	0.140	50.5
0.800	0.7660-01	144.	0.9260-02	-0.4900-04	-0.9800-01	-0.7070-01	0.121	43.7
0.900	0.3120-01	160.	0.3280-02	0.2590-03	-0.9580-01	-0.4390-01	0.105	38.1
1.00	0.5160-02	-18.2	-0.4600-03	0.4230-04	-0.8720-01	-0.2000-01	0.8940-01	32.3

## TABLE XXX

RUN ID F-10

CONTD.

OMEGA RAD/SEC	DEAD TIME=	0.0000	00	PULSES NORMALIZED				PULSES NORMALIZED				INPUT FREQ NORMALIZED	CONTENT ACTUAL
				AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT REAL	OUTPUT IMAGINARY	INPUT REAL	INPUT IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL		
2.00	0.552D-01	-75.4	0.797D-03	0.755D-03	-0.958D-02	0.174D-01	0.199D-01	7.18					
3.00	0.239	-141.	0.626D-03	-0.821D-03	0.139D-03	0.432D-02	0.433D-02	1.56					
4.00	0.984	150.	-0.225D-03	-0.109D-02	-0.363D-03	0.108D-02	0.114D-02	0.410					
5.00	0.635	65.0	-0.695D-03	0.566D-03	-0.455D-03	0.996D-03	0.109D-02	0.395					
6.00	0.563	50.8	-0.238D-03	0.314D-03	0.165D-03	0.681D-03	0.700D-03	0.253					
7.00	1.45	61.4	0.389D-03	0.366D-03	0.352D-03	-0.115D-03	0.370D-03	0.134					
8.00	3.61	-45.4	0.346D-03	-0.247D-03	0.116D-03	0.203D-04	0.118D-03	0.425D-01					
9.00	0.667	-103.	0.516D-04	-0.215D-03	0.297D-03	0.146D-03	0.331D-03	0.120					
10.0	0.210	-147.	-0.930D-04	-0.435D-04	0.484D-03	-0.658D-04	0.488D-03	0.176					

TABLE XXX CONTD.

RUN ID F-10

COMMENTS F-12 PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 3 LINE APP 1/7/69

DEAD TIME= 12.2 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
0.0000-00	0.992	0.0000-00	359.	0.0000-00	361.	0.0000-00	1.00	361.
0.1000-02	1.00	-0.971	0.999	-0.2990-01	1.00	-0.1290-01	1.00	361.
0.2000-02	1.00	-1.94	0.998	-0.5970-01	0.999	-0.2590-01	1.00	361.
0.3000-02	1.00	-2.91	0.995	-0.8940-01	0.999	-0.3880-01	0.999	361.
0.4000-02	1.00	-3.88	0.992	-0.119	0.998	-0.5160-01	0.999	361.
0.5000-02	1.00	-4.85	0.987	-0.149	0.996	-0.6450-01	0.998	361.
0.6000-02	1.00	-5.83	0.982	-0.178	0.995	-0.7720-01	0.998	360.
0.7000-02	1.00	-6.80	0.975	-0.207	0.993	-0.9000-01	0.997	360.
0.8000-02	1.00	-7.77	0.968	-0.236	0.991	-0.103	0.996	360.
0.9000-02	1.00	-8.74	0.960	-0.264	0.988	-0.115	0.995	359.
0.1000-01	1.00	-9.71	0.950	-0.292	0.985	-0.128	0.994	359.
0.2000-01	1.00	-19.5	0.809	-0.548	0.943	-0.246	0.975	352.
0.3000-01	1.01	-29.3	0.598	-0.737	0.878	-0.349	0.945	341.
0.4000-01	1.01	-39.2	0.350	-0.844	0.797	-0.429	0.905	327.
0.5000-01	1.01	-49.3	0.9550-01	-0.865	0.709	-0.486	0.859	310.
0.6000-01	1.01	-59.5	-0.135	-0.810	0.621	-0.520	0.810	293.
0.7000-01	1.01	-69.8	-0.322	-0.700	0.538	-0.536	0.759	274.
0.8000-01	1.01	-80.2	-0.456	-0.555	0.465	-0.538	0.711	257.
0.9000-01	1.00	-90.6	-0.537	-0.398	0.402	-0.531	0.666	241.
0.100	0.993	-101.	-0.572	-0.243	0.350	-0.519	0.626	226.
0.200	0.890	158.	0.5350-01	0.330	0.8290-01	-0.367	0.376	136.
0.300	0.722	59.0	0.172	-0.101	0.3470-02	-0.276	0.276	99.7
0.400	0.545	-38.9	-0.9080-01	-0.8030-01	-0.3730-01	-0.219	0.222	80.4
0.500	0.380	-135.	-0.3040-01	0.6490-01	-0.6530-01	-0.177	0.189	68.2
0.600	0.240	134.	0.3890-01	0.8050-02	-0.8820-01	-0.140	0.165	59.6
0.700	0.150	41.8	-0.8500-03	-0.2090-01	-0.9730-01	-0.100	0.140	50.5
0.800	0.7660-01	-55.3	-0.8730-02	0.3090-02	-0.9800-01	-0.7070-01	0.121	43.7
0.900	0.3120-01	-109.	-0.3100-03	0.3270-02	-0.9580-01	-0.4390-01	0.105	38.1
1.00	0.5160-02	2.83	-0.4450-03	-0.1250-03	-0.8720-01	-0.2000-01	0.8940-01	32.3

## TABLE XXX

RUN 10 F-10

CONTD.

OMEGA RAD/SEC	DEAD TIME=	12.2	PULSES NORMALIZED				PULSES NORMALIZED				INPUT FREQ-CONTENT	
			AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ-CONTENT NORMALIZED	INPUT FREQ-CONTENT ACTUAL		
2.00	0.5520-01	-33.4	0.8740-04	0.1090-02	-0.9580-02	0.1740-01	0.1990-01	7.18				
3.00	0.239	-77.9	0.1020-02	0.1850-03	0.1390-03	0.4320-02	0.4330-02	1.56				
4.00	0.984	-126.	0.1060-02	-0.3390-03	-0.3630-03	0.1080-02	0.1140-02	0.410				
5.00	0.635	170.	0.1740-03	-0.6730-03	-0.4550-03	0.9960-03	0.1090-02	0.395				
6.00	0.563	177.	-0.1140-03	-0.3780-03	0.1650-03	0.6810-03	0.7000-03	0.253				
7.00	1.45	-152.	-0.5260-03	-0.9480-04	0.3520-03	-0.1150-03	0.3700-03	0.134				
8.00	3.61	122.	-0.2870-03	0.3130-03	0.1160-03	0.2030-04	0.1180-03	0.4250-01				
9.00	0.667	86.3	-0.8430-04	0.2040-03	0.2970-03	0.1460-03	0.3310-03	0.120				
10.0	0.210	62.7	0.5900-04	0.8400-04	0.4840-03	-0.6580-04	0.4880-03	0.176				

TABLE XXXI

RUN ID F-11

COMMENTS F-12 FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 5 LINE APP 1/9/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
0.0000 00	1.00	0.0000 00	160.	0.0000 00	160.	0.0000 00	1.00	160.
0.1000-02	1.00	-0.726	1.00	-0.2520-01	1.00	-0.1250-01	1.00	160.
0.2000-02	1.00	-1.45	0.998	-0.5040-01	0.999	-0.2510-01	1.00	160.
0.3000-02	0.999	-2.18	0.996	-0.7550-01	0.999	-0.3760-01	0.999	160.
0.4000-02	0.999	-2.90	0.993	-0.100	0.998	-0.5010-01	0.999	160.
0.5000-02	0.998	-3.63	0.989	-0.125	0.997	-0.6260-01	0.998	160.
0.6000-02	0.997	-4.35	0.984	-0.150	0.995	-0.7500-01	0.998	160.
0.7000-02	0.996	-5.08	0.978	-0.174	0.993	-0.8730-01	0.997	160.
0.8000-02	0.995	-5.80	0.971	-0.198	0.991	-0.9970-01	0.996	160.
0.9000-02	0.994	-6.53	0.964	-0.222	0.989	-0.112	0.995	160.
0.1000-01	0.993	-7.25	0.956	-0.246	0.986	-0.124	0.994	159.
0.2000-01	0.971	-14.4	0.832	-0.454	0.946	-0.240	0.976	157.
0.3000-01	0.935	-21.4	0.654	-0.599	0.885	-0.341	0.948	152.
0.4000-01	0.886	-28.2	0.455	-0.668	0.808	-0.422	0.911	146.
0.5000-01	0.827	-34.5	0.267	-0.666	0.722	-0.481	0.868	139.
0.6000-01	0.761	-40.3	0.114	-0.613	0.635	-0.518	0.820	131.
0.7000-01	0.689	-45.4	0.4450-02	-0.531	0.553	-0.536	0.770	124.
0.8000-01	0.617	-49.5	-0.6220-01	-0.441	0.478	-0.540	0.722	116.
0.9000-01	0.548	-52.7	-0.9540-01	-0.358	0.414	-0.534	0.676	108.
0.100	0.483	-54.8	-0.106	-0.288	0.360	-0.523	0.635	102.
0.200	0.273	-11.0	0.3780-02	-0.106	0.8780-01	-0.379	0.389	62.4
0.300	0.360	-20.5	-0.3180-01	-0.9650-01	0.1080-01	-0.282	0.282	45.2
0.400	0.314	-21.4	-0.3610-01	-0.6200-01	-0.3500-01	-0.226	0.228	36.6
0.500	0.370	-28.6	-0.5210-01	-0.4770-01	-0.6200-01	-0.181	0.191	30.6
0.600	0.303	-34.4	-0.4510-01	-0.2220-01	-0.8140-01	-0.144	0.166	26.6
0.700	0.333	-46.3	-0.4670-01	-0.2130-02	-0.9220-01	-0.106	0.140	22.5
0.800	0.224	-47.8	-0.2760-01	0.4460-02	-0.9740-01	-0.7770-01	0.125	20.0
0.900	0.270	-37.0	-0.2810-01	0.4620-02	-0.9370-01	-0.4910-01	0.106	17.0
1.00	0.266	-57.2	-0.1910-01	0.1520-01	-0.8680-01	-0.2930-01	0.9170-01	14.7

TABLE XXXI

RUN ID F-11

CONTD.

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
			REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00	0.8980-01	-119.	0.1780-02	-0.3400-04	-0.9310-02	0.1750-01	0.1980-01	3.18
3.00	0.184	26.2	-0.5280-04	0.6260-03	0.1250-02	0.3180-02	0.3410-02	0.547
4.00	0.601	74.6	-0.3930-03	0.2490-03	0.2270-03	0.7390-03	0.7730-03	0.124
5.00	0.367	51.8	-0.1130-03	-0.2310-05	-0.1950-03	0.2380-03	0.3080-03	0.4940-01
6.00	0.256	-86.8	0.4560-04	0.6320-04	-0.2370-03	0.1920-03	0.3050-03	0.4890-01
7.00	0.219	-47.0	-0.1090-03	0.2070-04	-0.4080-03	-0.3000-03	0.5060-03	0.8120-01
8.00	0.9900-01	92.8	-0.7820-05	-0.3960-04	-0.3960-03	0.9810-04	0.4080-03	0.6540-01
9.00	0.145	38.7	-0.4660-04	0.2890-05	-0.2380-03	0.2170-03	0.3220-03	0.5170-01
10.0	0.240	76.8	-0.3920-04	0.8580-05	-0.2490-05	0.1670-03	0.1670-03	0.2680-01

TABLE XXXI CONTD.

RUN ID F-11

COMMENTS F-12 FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 5 LINE APP 1/9/69

DEAD TIME= 0.700 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.000D 00	1.00	0.000D 00	160.	0.000D 00	160.	0.000D 00	1.00	160.
0.100D-02	1.00	-0.766	1.00	-0.259D-01	1.00	-0.125D-01	1.00	160.
0.200D-02	1.00	-1.53	0.998	-0.518D-01	0.999	-0.251D-01	1.00	160.
0.300D-02	0.999	-2.30	0.996	-0.776D-01	0.999	-0.376D-01	0.999	160.
0.400D-02	0.999	-3.06	0.992	-0.103	0.998	-0.501D-01	0.999	160.
0.500D-02	0.998	-3.83	0.988	-0.129	0.997	-0.626D-01	0.998	160.
0.600D-02	0.997	-4.59	0.983	-0.154	0.995	-0.750D-01	0.998	160.
0.700D-02	0.996	-5.36	0.977	-0.179	0.993	-0.873D-01	0.997	160.
0.800D-02	0.995	-6.12	0.970	-0.204	0.991	-0.997D-01	0.996	160.
0.900D-02	0.994	-6.89	0.962	-0.228	0.989	-0.112	0.995	160.
0.100D-01	0.993	-7.65	0.954	-0.252	0.986	-0.124	0.994	159.
0.200D-01	0.971	-15.2	0.825	-0.466	0.946	-0.240	0.976	157.
0.300D-01	0.935	-22.6	0.641	-0.612	0.885	-0.341	0.948	152.
0.400D-01	0.886	-29.8	0.436	-0.680	0.808	-0.422	0.911	146.
0.500D-01	0.827	-36.5	0.244	-0.675	0.722	-0.481	0.868	139.
0.600D-01	0.761	-42.7	0.878D-01	-0.617	0.635	-0.518	0.820	131.
0.700D-01	0.689	-48.2	-0.216D-01	-0.531	0.553	-0.536	0.770	124.
0.800D-01	0.617	-52.8	-0.868D-01	-0.437	0.478	-0.540	0.722	116.
0.900D-01	0.548	-56.3	-0.118	-0.351	0.414	-0.534	0.676	108.
0.100	0.483	-58.9	-0.126	-0.280	0.360	-0.523	0.635	102.
0.200	0.273	-19.0	-0.111D-01	-0.106	0.878D-01	-0.379	0.389	62.4
0.300	0.360	-32.5	-0.513D-01	-0.877D-01	0.108D-01	-0.282	0.282	45.2
0.400	0.314	-37.5	-0.519D-01	-0.496D-01	-0.350D-01	-0.226	0.228	36.6
0.500	0.370	-48.7	-0.653D-01	-0.269D-01	-0.620D-01	-0.181	0.191	30.6
0.600	0.303	-58.5	-0.502D-01	-0.186D-02	-0.814D-01	-0.144	0.166	26.6
0.700	0.333	-74.3	-0.422D-01	0.201D-01	-0.922D-01	-0.106	0.140	22.5
0.800	0.224	-79.9	-0.210D-01	0.184D-01	-0.974D-01	-0.777D-01	0.125	20.0
0.900	0.270	-73.0	-0.200D-01	0.203D-01	-0.937D-01	-0.491D-01	0.106	17.0
1.00	0.266	-97.3	-0.480D-02	0.239D-01	-0.868D-01	-0.293D-01	0.917D-01	14.7



TABLE XXXI

RUN 10 F-11

CONTD.

OMEGA RAD/SEC	DEAD TIME	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT REAL	INPUT IMAGINARY	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT	
				OUTPUT REAL	OUTPUT IMAGINARY					ACTUAL	ACTUAL
2.00	0.700	0.898D-01	161.	0.269D-03	-0.176D-02	-0.931D-02	0.175D-01	0.198D-01	0.198D-01	3.18	
3.00		0.184	-94.1	0.567D-03	-0.271D-03	0.125D-02	0.318D-02	0.341D-02	0.341D-02	0.547	
4.00		0.601	-85.8	0.454D-03	-0.103D-03	0.227D-03	0.739D-03	0.773D-03	0.773D-03	0.124	
5.00		0.367	-149.	0.107D-03	-0.375D-04	-0.195D-03	0.238D-03	0.308D-03	0.308D-03	0.494D-01	
6.00		0.256	32.6	-0.774D-04	0.874D-05	-0.237D-03	0.192D-03	0.305D-03	0.305D-03	0.489D-01	
7.00		0.219	32.2	-0.406D-04	-0.103D-03	-0.408D-03	-0.300D-03	0.506D-03	0.506D-03	0.812D-01	
8.00		0.990D-01	132.	0.189D-04	-0.356D-04	-0.396D-03	0.981D-04	0.408D-03	0.408D-03	0.654D-01	
9.00		0.145	37.8	-0.465D-04	0.367D-05	-0.238D-03	0.217D-03	0.322D-03	0.322D-03	0.517D-01	
10.0		0.240	35.7	-0.239D-04	0.322D-04	-0.249D-05	0.167D-03	0.167D-03	0.167D-03	0.268D-01	

ORTRAN \*\* STOP

TABLE XXXII

RUN ID F-12

COMMENTS F-12 FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 4 LINE APP 1/9/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	0.897	0.0000 00	336.	0.0000 00	374.	0.0000 00	1.00	374.
0.1000-02	1.00	-0.674	1.00	-0.2420-01	1.00	-0.1240-01	1.00	374.
0.2000-02	1.00	-1.35	0.998	-0.4830-01	0.999	-0.2480-01	1.00	374.
0.3000-02	0.999	-2.02	0.996	-0.7240-01	0.999	-0.3720-01	0.999	374.
0.4000-02	0.999	-2.70	0.994	-0.9630-01	0.998	-0.4950-01	0.999	374.
0.5000-02	0.999	-3.37	0.990	-0.120	0.997	-0.6190-01	0.999	374.
0.6000-02	0.998	-4.04	0.985	-0.144	0.995	-0.7410-01	0.998	374.
0.7000-02	0.997	-4.72	0.980	-0.167	0.993	-0.8640-01	0.997	373.
0.8000-02	0.996	-5.39	0.974	-0.191	0.991	-0.9860-01	0.996	373.
0.9000-02	0.995	-6.06	0.968	-0.214	0.989	-0.111	0.995	373.
0.1000-01	0.994	-6.74	0.960	-0.236	0.987	-0.123	0.994	372.
0.2000-01	0.977	-13.5	0.847	-0.442	0.948	-0.238	0.977	366.
0.3000-01	0.949	-20.1	0.681	-0.592	0.888	-0.339	0.950	356.
0.4000-01	0.910	-26.8	0.488	-0.674	0.812	-0.420	0.915	342.
0.5000-01	0.860	-33.3	0.296	-0.689	0.727	-0.481	0.872	326.
0.6000-01	0.800	-39.6	0.130	-0.647	0.640	-0.520	0.825	309.
0.7000-01	0.732	-45.5	0.3650-02	-0.567	0.557	-0.540	0.775	290.
0.8000-01	0.656	-50.9	0.7840-01	-0.470	0.481	-0.544	0.726	272.
0.9000-01	0.576	-55.5	0.120	-0.373	0.415	-0.538	0.679	254.
0.100	0.495	-58.8	0.130	-0.287	0.360	-0.525	0.637	238.
0.200	0.304	-4.78	0.1720-01	-0.118	0.8840-01	-0.380	0.391	146.
0.300	0.412	-21.1	0.3950-01	-0.114	0.1000-01	-0.292	0.292	109.
0.400	0.352	-33.3	0.5490-01	-0.6270-01	-0.3240-01	-0.234	0.236	88.5
0.500	0.393	-31.7	0.6170-01	-0.4710-01	-0.7040-01	-0.184	0.197	73.9
0.600	0.338	-50.6	0.5630-01	-0.7350-02	-0.8890-01	-0.142	0.168	62.8
0.700	0.332	-49.5	0.4840-01	0.2360-02	-0.100	-0.106	0.146	54.7
0.800	0.301	-68.8	0.3140-01	0.2060-01	-0.101	-0.7250-01	0.125	46.6
0.900	0.276	-54.4	0.2530-01	0.1430-01	-0.9540-01	-0.4440-01	0.105	39.4
1.000	0.284	-70.6	0.1490-01	0.2160-01	-0.8910-01	-0.2400-01	0.9230-01	34.5

TABLE XXXII

RUN 10 F-12

CONTD.

OMEGA RAD/SEC	DEAD TIME= 0.0000 00	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
2.00	0.114	-146.	0.181D-02	-0.105D-02	-0.787D-02	0.165D-01	0.183D-01	6.85
3.00	0.378	110.	-0.119D-02	0.422D-03	0.211D-02	0.258D-02	0.334D-02	1.25
4.00	2.09	-57.2	-0.267D-03	0.121D-02	-0.556D-03	0.207D-03	0.593D-03	0.222
5.00	1.06	-73.1	0.783D-03	0.400D-04	0.179D-03	0.720D-03	0.742D-03	0.278
6.00	2.73	-138.	-0.678D-03	-0.139D-03	0.219D-03	-0.127D-03	0.253D-03	0.949D-01
7.00	0.885	-146.	-0.203D-04	0.681D-03	-0.408D-03	-0.653D-03	0.770D-03	0.288
8.00	0.852	-171.	0.279D-03	-0.102D-03	-0.306D-03	0.167D-03	0.349D-03	0.131
9.00	0.542	80.6	-0.167D-03	-0.857D-04	-0.206D-03	0.278D-03	0.347D-03	0.130
10.0	0.799	-107.	-0.102D-03	0.123D-04	0.234D-04	-0.127D-03	0.129D-03	0.482D-01

TABLE XXXII CONTD.

KUN ID F-12

COMMENTS F-12 FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP & LINE APP 1/9/69

DEAD TIME= 0.600 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
0.0000-00	0.897	0.0000 00	336..	0.0000 00	374.	0.0000 00	1.00	374.
0.1000-02	1.00	-0.708	1.00	-0.2480-01	1.00	-0.1240-01	1.00	374.
0.2000-02	1.00	-1.42	0.998	-0.4950-01	0.999	-0.2480-01	1.00	374.
0.3000-02	0.999	-2.12	0.996	-0.7410-01	0.999	-0.3720-01	0.999	374.
0.4000-02	0.999	-2.83	0.993	-0.9870-01	0.998	-0.4950-01	0.999	374.
0.5000-02	0.999	-3.54	0.990	-0.123	0.997	-0.6190-01	0.999	374.
0.6000-02	0.998	-4.25	0.985	-0.147	0.995	-0.7410-01	0.998	374.
0.7000-02	0.997	-4.96	0.980	-0.171	0.993	-0.8640-01	0.997	373.
0.8000-02	0.996	-5.67	0.973	-0.195	0.991	-0.9860-01	0.996	373.
0.9000-02	0.995	-6.37	0.966	-0.219	0.989	-0.111	0.995	373.
0.1000-01	0.994	-7.08	0.959	-0.242	0.987	-0.123	0.994	372.
0.2000-01	0.977	-14.1	0.842	-0.452	0.948	-0.238	0.977	366.
0.3000-01	0.949	-21.2	0.670	-0.604	0.888	-0.339	0.950	356.
0.4000-01	0.910	-28.1	0.471	-0.686	0.812	-0.420	0.915	342.
0.5000-01	0.860	-35.0	0.276	-0.698	0.727	-0.481	0.872	326.
0.6000-01	0.800	-41.6	0.107	-0.651	0.640	-0.520	0.825	309.
0.7000-01	0.732	-47.9	-0.2020-01	-0.567	0.557	-0.540	0.775	290.
0.8000-01	0.656	-53.7	-0.101	-0.466	0.481	-0.544	0.726	272.
0.9000-01	0.576	-58.6	-0.140	-0.366	0.415	-0.538	0.679	254.
0.100	0.495	-62.2	-0.147	-0.279	0.360	-0.525	0.637	238.
0.200	0.304	-11.7	0.2970-02	-0.119	0.8840-01	-0.380	0.391	146.
0.300	0.412	-31.4	-0.5930-01	-0.105	0.1000-01	-0.292	0.292	109.
0.400	0.352	-47.1	-0.6820-01	-0.4780-01	-0.3240-01	-0.234	0.236	88.5
0.500	0.393	-48.9	-0.7290-01	-0.2680-01	-0.7040-01	-0.184	0.197	73.9
0.600	0.338	-71.2	-0.5530-01	0.1300-01	-0.8890-01	-0.142	0.168	62.8
0.700	0.332	-73.6	-0.4320-01	0.2190-01	-0.100	-0.106	0.146	54.7
0.800	0.301	-96.3	-0.1830-01	0.3270-01	-0.101	-0.7250-01	0.125	46.6
0.900	0.276	-85.3	-0.1430-01	0.2520-01	-0.9540-01	-0.4440-01	0.105	39.4
1.00	0.284	-105.	-0.7730-04	0.2630-01	-0.8910-01	-0.2400-01	0.9230-01	34.5

TABLE XXXII

KUN ID F-12

CONTO.

OMEGA RAD/SEC	DEAD TIME=	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED				INPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	INPUT FREQ CONTENT ACTUAL
				0.600	REAL	IMAGINARY	REAL					
2.00		0.114	146.	-0.323D-03	-0.207D-02	-0.787D-02	0.165D-01	0.183D-01	6.85			
3.00		0.378	6.57	0.682D-03	0.106D-02	0.211D-02	0.258D-02	0.334D-02	1.25			
4.00		2.09	165.	0.102D-02	-0.714D-03	-0.556D-03	0.207D-03	0.593D-03	0.222			
5.00		1.06	115.	-0.770D-03	-0.150D-03	0.179D-03	0.720D-03	0.742D-03	0.278			
6.00		2.73	15.5	0.670D-03	-0.175D-03	0.219D-03	-0.127D-03	0.253D-03	0.949D-01			
7.00		0.885	-27.0	-0.584D-03	-0.352D-03	-0.408D-03	-0.653D-03	0.770D-03	0.288			
8.00		0.852	-86.4	0.126D-03	0.269D-03	-0.306D-03	0.167D-03	0.349D-03	0.131			
9.00		0.542	131.	-0.399D-04	-0.184D-03	-0.206D-03	0.278D-03	0.347D-03	0.130			
10.0		0.799	-91.1	-0.101D-03	-0.167D-04	0.234D-04	-0.127D-03	0.129D-03	0.482D-01			

TABLE XXXIII

RUN ID F-13

COMMENTS F-12 FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SHP LOOP 4 LINE APP 1/9/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	1.02	0.0000 00	381.	0.0000 00	373.	0.0000 00	1.00	373.
0.1000-02	1.00	-0.562	1.00	-0.2220-01	1.00	-0.1240-01	1.00	373.
0.2000-02	1.00	-1.12	0.999	-0.4440-01	0.999	-0.2480-01	1.00	373.
0.3000-02	1.00	-1.68	0.997	-0.6650-01	0.999	-0.3720-01	0.999	373.
0.4000-02	0.999	-2.25	0.994	-0.8850-01	0.998	-0.4950-01	0.999	373.
0.5000-02	0.999	-2.81	0.991	-0.110	0.997	-0.6180-01	0.999	373.
0.6000-02	0.998	-3.37	0.987	-0.132	0.995	-0.7410-01	0.998	372.
0.7000-02	0.997	-3.93	0.983	-0.154	0.993	-0.8630-01	0.997	372.
0.8000-02	0.997	-4.49	0.977	-0.175	0.991	-0.9850-01	0.996	372.
0.9000-02	0.996	-5.05	0.971	-0.196	0.989	-0.111	0.995	371.
0.1000-01	0.995	-5.61	0.965	-0.217	0.987	-0.123	0.994	371.
0.2000-01	0.979	-11.2	0.865	-0.408	0.948	-0.238	0.977	365.
0.3000-01	0.953	-16.7	0.718	-0.552	0.888	-0.338	0.950	354.
0.4000-01	0.917	-22.1	0.545	-0.637	0.812	-0.419	0.914	341.
0.5000-01	0.872	-27.4	0.371	-0.663	0.728	-0.479	0.871	325.
0.6000-01	0.817	-32.3	0.216	-0.637	0.641	-0.518	0.824	308.
0.7000-01	0.754	-36.8	0.9380-01	-0.577	0.558	-0.543	0.775	289.
0.8000-01	0.686	-40.7	0.8770-02	-0.499	0.483	-0.537	0.726	271.
0.9000-01	0.616	-43.5	-0.4140-01	-0.417	0.417	-0.525	0.680	254.
0.100	0.547	-45.1	-0.6390-01	-0.343	0.362	-0.377	0.638	238.
0.200	0.347	-5.81	0.1840-01	-0.133	0.9160-01	-0.283	0.388	145.
0.300	0.539	-13.3	-0.2920-01	-0.150	0.1120-01	-0.229	0.284	106.
0.400	0.434	-32.3	-0.6250-01	-0.7810-01	-0.2560-01	-0.186	0.231	86.1
0.500	0.406	-24.1	-0.5430-01	-0.5840-01	-0.6350-01	-0.144	0.197	73.4
0.600	0.459	-38.4	-0.7040-01	-0.2830-01	-0.8190-01	-0.109	0.165	61.7
0.700	0.317	-52.1	-0.4490-01	0.1470-02	-0.9060-01	-0.109	0.142	52.9
0.800	0.321	-37.3	-0.3840-01	-0.2260-02	-0.9110-01	-0.7820-01	0.120	44.8
0.900	0.321	-48.4	-0.3270-01	0.1080-01	-0.9270-01	-0.5350-01	0.107	39.9
1.00	0.238	-56.7	-0.1820-01	0.1260-01	-0.8610-01	-0.3470-01	0.9280-01	34.6

TABLE XXXIII

RUN ID F-13

CONTD.

DEAD TIME= 0.000D 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
2.00	0.399D-01	41.7	-0.761D-03	0.146D-03	-0.118D-01	0.154D-01	0.194D-01	7.25
3.00	0.125	-142.	0.268D-03	-0.437D-03	0.467D-03	0.409D-02	0.411D-02	1.53
4.00	0.771	50.2	-0.467D-03	0.126D-03	-0.262D-03	0.569D-03	0.626D-03	0.234
5.00	2.87	131.	-0.150D-03	-0.149D-04	0.301D-04	0.430D-04	0.525D-04	0.196D-01
6.00	2.34	-140.	-0.405D-03	0.569D-04	0.117D-03	-0.130D-03	0.175D-03	0.653D-01
7.00	0.774D-01	111.	0.714D-04	-0.362D-04	-0.763D-03	-0.699D-03	0.103D-02	0.386
8.00	0.441	11.5	-0.223D-03	0.681D-05	-0.493D-03	0.116D-03	0.506D-03	0.189
9.00	0.163	42.4	-0.844D-04	0.186D-04	-0.305D-03	0.433D-03	0.530D-03	0.198
10.0	0.491	3.00	-0.987D-04	0.351D-05	-0.201D-03	0.177D-04	0.201D-03	0.751D-01

TABLE XXXIII CONTD.

RUN 10 F-13

COMMENTS F-12 FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 4 LINE APP 1/9/69

DEAD TIME= 0.600 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000-00	1.02	0.0000 00	381.	0.0000 00	373.	0.0000 00	1.00	373.
0.1000-02	1.00	-0.596	1.00	-0.2280-01	1.00	-0.1240-01	1.00	373.
0.2000-02	1.00	-1.19	0.999	-0.4560-01	0.999	-0.2480-01	1.00	373.
0.3000-02	1.00	-1.79	0.997	-0.6830-01	0.999	-0.3720-01	0.999	373.
0.4000-02	0.999	-2.38	0.994	-0.9090-01	0.998	-0.4950-01	0.999	373.
0.5000-02	0.999	-2.98	0.991	-0.113	0.997	-0.6180-01	0.999	373.
0.6000-02	0.998	-3.58	0.987	-0.136	0.995	-0.7410-01	0.998	372.
0.7000-02	0.997	-4.17	0.982	-0.158	0.993	-0.8630-01	0.997	372.
0.8000-02	0.997	-4.77	0.977	-0.180	0.991	-0.9850-01	0.996	372.
0.9000-02	0.996	-5.36	0.970	-0.202	0.989	-0.111	0.995	371.
0.1000-01	0.995	-5.96	0.964	-0.223	0.987	-0.123	0.994	371.
0.2000-01	0.979	-11.9	0.860	-0.419	0.948	-0.238	0.977	365.
0.3000-01	0.953	-17.8	0.708	-0.565	0.888	-0.338	0.950	354.
0.4000-01	0.917	-23.5	0.530	-0.650	0.812	-0.419	0.914	341.
0.5000-01	0.872	-29.1	0.351	-0.673	0.728	-0.479	0.871	325.
0.6000-01	0.817	-34.4	0.193	-0.645	0.641	-0.518	0.824	308.
0.7000-01	0.754	-39.2	0.6950-01	-0.580	0.558	-0.538	0.775	289.
0.8000-01	0.686	-43.4	-0.1520-01	-0.498	0.483	-0.543	0.726	271.
0.9000-01	0.616	-46.6	-0.6380-01	-0.414	0.417	-0.537	0.680	254.
0.100	0.547	-48.6	-0.8440-01	-0.339	0.362	-0.525	0.638	238.
0.200	0.347	-12.7	0.2270-02	-0.135	0.9160-01	-0.377	0.388	145.
0.300	0.539	-23.6	-0.5550-01	-0.142	0.1120-01	-0.283	0.284	106.
0.400	0.434	-46.1	-0.7930-01	-0.6100-01	-0.2560-01	-0.229	0.231	86.1
0.500	0.406	-41.2	-0.6910-01	-0.3980-01	-0.6350-01	-0.186	0.197	73.4
0.600	0.459	-59.1	-0.7590-01	-0.1660-02	-0.8190-01	-0.144	0.165	61.7
0.700	0.317	-76.2	-0.4040-01	0.1960-01	-0.9060-01	-0.109	0.142	52.9
0.800	0.321	-64.8	-0.3510-01	0.1570-01	-0.9110-01	-0.7820-01	0.120	44.8
0.900	0.321	-79.3	-0.2240-01	0.2610-01	-0.9270-01	-0.5350-01	0.107	39.9
1.00	0.238	-91.1	-0.7880-02	0.2070-01	-0.8610-01	-0.3470-01	0.9280-01	34.6



TABLE XXXIII

RUN ID F-13

CONTD.

OMEGA RAD/SEC	DEAD TIME*	0.600	PHASE ANGLE DEGREES	PULSES NORMALIZED				INPUT PULSE		INPUT FREQ CONTENT	
				AMPLITUDE RATIO	OUTPUT REAL	OUTPUT IMAGINARY	INPUT REAL	INPUT IMAGINARY	NORMALIZED	ACTUAL	
2.00	0.399D-01	-27.1	-0.140D-03	0.762D-03	-0.118D-01	0.154D-01	0.194D-01	7.25			
3.00	0.125	115.	-0.486D-03	-0.162D-03	0.467D-03	0.409D-02	0.411D-02	1.53			
4.00	0.771	-87.4	0.429D-03	0.222D-03	-0.262D-03	0.569D-03	0.626D-03	0.234			
5.00	2.87	-41.2	0.146D-03	0.359D-04	0.301D-04	0.430D-04	0.525D-04	0.196D-01			
6.00	2.34	13.7	0.338D-03	-0.230D-03	0.117D-03	-0.130D-03	0.175D-03	0.653D-01			
7.00	0.774D-01	-130.	-0.345D-05	0.800D-04	-0.763D-03	-0.699D-03	0.103D-02	0.386			
8.00	0.441	96.5	-0.263D-04	-0.222D-03	-0.493D-03	0.116D-03	0.506D-03	0.189			
9.00	0.163	93.0	-0.679D-04	-0.534D-04	-0.305D-03	0.433D-03	0.530D-03	0.198			
10.0	0.491	19.2	-0.958D-04	-0.242D-04	-0.201D-03	0.177D-04	0.201D-03	0.751D-01			

TABLE XXXIV

KUN ID F-14

COMMENTS F-12 FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CH SMP LOOP 5 LINE APP 1/22/69

DEAD TIME= 0.000D 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.000D 00	1.14	0.000D 00	153.	0.000D 00	135.	0.000D 00	1.00	135.
0.100D-02	1.00	-0.560	1.00	-0.218D-01	1.00	-0.121D-01	1.00	135.
0.200D-02	1.00	-1.12	0.999	-0.436D-01	0.999	-0.241D-01	1.00	135.
0.300D-02	0.999	-1.68	0.997	-0.654D-01	0.999	-0.361D-01	1.00	135.
0.400D-02	0.999	-2.24	0.994	-0.870D-01	0.998	-0.482D-01	0.999	135.
0.500D-02	0.998	-2.80	0.991	-0.109	0.997	-0.601D-01	0.999	135.
0.600D-02	0.997	-3.36	0.987	-0.130	0.995	-0.721D-01	0.998	134.
0.700D-02	0.996	-3.91	0.982	-0.151	0.994	-0.840D-01	0.997	134.
0.800D-02	0.995	-4.47	0.976	-0.172	0.992	-0.958D-01	0.997	134.
0.900D-02	0.994	-5.02	0.970	-0.193	0.990	-0.108	0.996	134.
0.100D-01	0.992	-5.58	0.963	-0.213	0.987	-0.119	0.995	134.
0.200D-01	0.969	-11.0	0.862	-0.396	0.951	-0.232	0.979	132.
0.300D-01	0.932	-16.0	0.716	-0.526	0.894	-0.331	0.953	128.
0.400D-01	0.884	-20.5	0.553	-0.596	0.821	-0.413	0.919	124.
0.500D-01	0.830	-24.2	0.398	-0.611	0.740	-0.475	0.879	118.
0.600D-01	0.773	-27.0	0.270	-0.585	0.654	-0.516	0.834	112.
0.700D-01	0.720	-28.8	0.173	-0.538	0.571	-0.539	0.786	106.
0.800D-01	0.673	-29.7	0.107	-0.484	0.494	-0.547	0.737	99.3
0.900D-01	0.635	-30.0	0.616D-01	-0.434	0.426	-0.543	0.690	92.9
0.100	0.605	-30.2	0.307D-01	-0.389	0.367	-0.531	0.645	87.0
0.200	0.451	-22.8	-0.214D-01	-0.175	0.107	-0.375	0.390	52.6
0.300	0.418	-20.0	-0.309D-01	-0.116	0.257D-01	-0.286	0.288	38.7
0.400	0.458	-21.8	-0.474D-01	-0.954D-01	-0.188D-01	-0.232	0.233	31.3
0.500	0.421	-31.5	-0.599D-01	-0.560D-01	-0.518D-01	-0.153	0.195	26.3
0.600	0.368	-29.7	-0.503D-01	-0.359D-01	-0.704D-01	-0.158	0.168	22.6
0.700	0.340	-40.3	-0.485D-01	-0.134D-01	-0.833D-01	-0.122	0.148	19.9
0.800	0.269	-31.8	-0.334D-01	-0.852D-02	-0.889D-01	-0.923D-01	0.128	17.3
0.900	0.200	-35.3	-0.228D-01	-0.526D-03	-0.916D-01	-0.681D-01	0.114	15.4
1.00	0.228	-19.4	-0.223D-01	-0.258D-02	-0.887D-01	-0.432D-01	0.987D-01	13.3

TABLE XXXIV

RUN ID F-14

CONTD.

DEAD TIME= 0.0000 00 PULSES NORMALIZED											
OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ		CONTENT		
			REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL	NORMALIZED	ACTUAL	
2.00	0.213	24.4	-0.436D-02	0.188D-02	-0.150D-01	0.165D-01	0.223D-01	3.00			
3.00	0.447	11.9	-0.576D-03	0.200D-02	-0.339D-03	0.465D-02	0.466D-02	0.628			
4.00	0.684	-65.0	0.649D-03	0.256D-03	0.620D-04	0.102D-02	0.102D-02	0.137			
5.00	4.12	66.1	-0.453D-03	-0.471D-03	-0.149D-03	0.544D-04	0.159D-03	0.214D-01			
6.00	3.95	-124.	-0.399D-03	0.289D-03	-0.359D-05	-0.125D-03	0.125D-03	0.168D-01			
7.00	0.148	154.	0.102D-03	0.260D-04	-0.540D-03	-0.464D-03	0.712D-03	0.959D-01			
8.00	0.345	80.3	-0.409D-04	-0.186D-03	-0.552D-03	0.258D-04	0.552D-03	0.744D-01			
9.00	0.430	34.6	-0.164D-03	0.391D-05	-0.309D-03	0.224D-03	0.382D-03	0.515D-01			
10.0	0.461	108.	-0.263D-04	-0.693D-04	-0.126D-03	0.101D-03	0.161D-03	0.217D-01			

TABLE XXXIV CONTD.

KUN 10 F-14

COMMENTS F-12 FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CM SMP LOOP 5 LINE APP 1/22/69

DEAD TIME= 0.450 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
			REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
0.0000-00	1.14	0.0000 00	153.	0.0000 00	135.	0.0000 00	1.00	135.
0.1000-02	1.00	-0.586	1.00	-0.2230-01	1.00	-0.1210-01	1.00	135.
0.2000-02	1.00	-1.17	0.998	-0.4450-01	0.999	-0.2410-01	1.00	135.
0.3000-02	0.999	-1.76	0.997	-0.6670-01	0.999	-0.3610-01	1.00	135.
0.4000-02	0.999	-2.34	0.994	-0.8880-01	0.998	-0.4820-01	0.999	135.
0.5000-02	0.998	-2.93	0.990	-0.111	0.997	-0.6010-01	0.999	135.
0.6000-02	0.997	-3.51	0.986	-0.133	0.995	-0.7210-01	0.998	134.
0.7000-02	0.996	-4.09	0.981	-0.154	0.994	-0.8400-01	0.997	134.
0.8000-02	0.995	-4.68	0.976	-0.175	0.992	-0.9580-01	0.997	134.
0.9000-02	0.994	-5.26	0.969	-0.197	0.990	-0.108	0.996	134.
0.1000-01	0.992	-5.83	0.962	-0.217	0.987	-0.119	0.995	134.
0.2000-01	0.969	-11.5	0.858	-0.403	0.951	-0.232	0.979	132.
0.3000-01	0.932	-16.8	0.708	-0.536	0.894	-0.331	0.953	128.
0.4000-01	0.884	-21.5	0.542	-0.606	0.821	-0.413	0.919	124.
0.5000-01	0.830	-25.5	0.385	-0.619	0.740	-0.475	0.879	118.
0.6000-01	0.773	-28.5	0.254	-0.592	0.654	-0.516	0.834	112.
0.7000-01	0.720	-30.6	0.156	-0.543	0.571	-0.539	0.786	106.
0.8000-01	0.673	-31.7	0.8910-01	-0.488	0.494	-0.547	0.737	99.3
0.9000-01	0.635	-32.4	0.4400-01	-0.436	0.426	-0.543	0.690	92.9
0.100	0.605	-32.8	0.1310-01	-0.390	0.367	-0.531	0.645	87.0
0.200	0.451	-28.0	-0.3700-01	-0.172	0.107	-0.375	0.390	52.6
0.300	0.418	-27.8	-0.4620-01	-0.111	0.2570-01	-0.286	0.288	38.7
0.400	0.458	-32.1	-0.6370-01	-0.8540-01	-0.1880-01	-0.232	0.233	31.3
0.500	0.421	-44.4	-0.7090-01	-0.4120-01	-0.5180-01	-0.188	0.195	26.3
0.600	0.368	-45.2	-0.5800-01	-0.2120-01	-0.7040-01	-0.153	0.168	22.6
0.700	0.340	-58.3	-0.5030-01	0.2290-02	-0.8330-01	-0.122	0.148	19.9
0.800	0.269	-52.4	-0.3430-01	0.3800-02	-0.8890-01	-0.9230-01	0.128	17.3
0.900	0.200	-58.5	-0.2120-01	0.8520-02	-0.9160-01	-0.6810-01	0.114	15.4
1.000	0.228	-45.1	-0.2120-01	0.7400-02	-0.8870-01	-0.4320-01	0.9870-01	13.3

TABLE XXXIV

RUN ID F-14

CONTD.

OMEGA RAD/SEC	DEAD TIME	AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED				INPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT FREQ NORMALIZED	CONTENT ACTUAL
				OUTPUT REAL	OUTPUT IMAGINARY	INPUT REAL	INPUT IMAGINARY				
2.00	0.450	0.213	-27.2	-0.1240-02	0.4580-02	-0.1500-01	0.1650-01	0.2230-01	3.00		
3.00		0.447	-65.5	0.1830-02	0.1000-02	-0.3390-03	0.4650-02	0.4660-02	0.628		
4.00		0.684	-168.	0.1020-03	-0.6900-03	0.6200-04	0.1020-02	0.1020-02	0.137		
5.00		4.12	-62.8	-0.8180-04	0.6480-03	-0.1490-03	0.5440-04	0.1590-03	0.2140-01		
6.00		3.95	81.0	0.4840-03	-0.9120-04	-0.3590-05	-0.1250-03	0.1250-03	0.1680-01		
7.00		0.148	-26.9	-0.1020-03	-0.2510-04	-0.5400-03	-0.4640-03	0.7120-03	0.9590-01		
8.00		0.345	-126.	0.1190-03	0.1490-03	-0.5520-03	0.2580-04	0.5520-03	0.7440-01		
9.00		0.430	163.	0.9780-04	-0.1320-03	-0.3090-03	0.2240-03	0.3820-03	0.5150-01		
10.0		0.461	-150.	0.7330-04	-0.1110-04	-0.1260-03	0.1010-03	0.1610-03	0.2170-01		

TABLE XXXV

RUN ID F-16

COMMENTS F-12 FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CM SMP LOOP 4 LINE APP 1/22/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	0.999	0.0000 00	317.	0.0000 00	318.	0.0000 00	1.00	318.
0.1000-02	0.965	17.1	1.00	-0.2120-01	0.983	-0.326	1.04	329.
0.2000-02	1.00	7.94	0.999	-0.4250-01	0.983	-0.180	0.999	317.
0.3000-02	1.01	4.38	0.997	-0.6360-01	0.982	-0.139	0.992	315.
0.4000-02	1.01	2.31	0.995	-0.8470-01	0.981	-0.124	0.989	314.
0.5000-02	1.01	0.839	0.992	-0.106	0.980	-0.119	0.988	314.
0.6000-02	1.01	-0.330	0.988	-0.127	0.979	-0.120	0.987	313.
0.7000-02	1.01	-1.32	0.984	-0.147	0.978	-0.123	0.986	313.
0.8000-02	1.01	-2.21	0.979	-0.168	0.976	-0.129	0.985	313.
0.9000-02	1.01	-3.02	0.973	-0.188	0.974	-0.135	0.984	313.
0.1000-01	1.01	-3.78	0.967	-0.208	0.972	-0.143	0.983	312.
0.2000-01	0.989	-10.2	0.875	-0.392	0.941	-0.233	0.969	308.
0.3000-01	0.959	-15.8	0.738	-0.531	0.891	-0.324	0.948	301.
0.4000-01	0.919	-20.9	0.578	-0.616	0.826	-0.403	0.919	292.
0.5000-01	0.872	-25.4	0.418	-0.648	0.751	-0.466	0.884	281.
0.6000-01	0.820	-29.3	0.275	-0.635	0.671	-0.512	0.844	268.
0.7000-01	0.767	-32.4	0.160	-0.592	0.590	-0.540	0.800	254.
0.8000-01	0.716	-34.7	0.1980-01	-0.535	0.513	-0.554	0.754	240.
0.9000-01	0.670	-36.2	0.1980-01	-0.474	0.442	-0.554	0.709	225.
0.100	0.632	-37.1	-0.1610-01	-0.419	0.379	-0.545	0.664	211.
0.200	0.411	-38.6	-0.6520-01	-0.152	0.107	-0.388	0.402	128.
0.300	0.386	-28.5	-0.4570-01	-0.104	0.2460-01	-0.293	0.294	93.5
0.400	0.393	-39.1	-0.6610-01	-0.6560-01	-0.2530-01	-0.236	0.237	75.3
0.500	0.381	-40.8	-0.6580-01	-0.4030-01	-0.6170-01	-0.193	0.203	64.3
0.600	0.326	-56.7	-0.5560-01	-0.6620-02	-0.7650-01	-0.153	0.172	54.5
0.700	0.291	-61.8	-0.4280-01	0.6530-02	-0.8930-01	-0.119	0.149	47.3
0.800	0.227	-59.7	-0.2910-01	0.9090-02	-0.9940-01	-0.9040-01	0.134	42.7
0.900	0.238	-65.7	-0.2220-01	0.1500-01	-0.9590-01	-0.5920-01	0.113	35.8
1.00	0.198	-78.0	-0.1080-01	0.1600-01	-0.9020-01	-0.3650-01	0.9730-01	30.9

TABLE XXXV

RUN ID F-16

CONTD.

OMEGA RAD/SEC	DEAD TIME	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
				REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00	0.0000 00	0.223	-10.3	-0.1990-02	0.4590-02	-0.1250-01	0.1870-01	0.2250-01	7.14
3.00		0.182	-102.	0.6450-03	-0.5120-03	0.2030-02	0.4050-02	0.4530-02	1.44
4.00		0.634	99.2	-0.4350-03	0.2750-04	0.1530-03	0.6700-03	0.6870-03	0.218
5.00		0.297	32.2	-0.2060-03	0.5560-04	-0.4860-03	0.5280-03	0.7180-03	0.228
6.00		0.381	-70.5	-0.4520-04	-0.1120-04	-0.1190-04	-0.1220-03	0.1220-03	0.3880-01
7.00		0.121	-151.	0.2970-04	0.7150-04	-0.4990-03	-0.3970-03	0.6380-03	0.203
8.00		0.107	16.5	-0.3510-04	0.2390-04	-0.2520-03	0.3090-03	0.3990-03	0.127
9.00		0.424	-28.8	-0.4680-04	0.6200-04	-0.1670-03	0.7510-04	0.1830-03	0.5830-01
10.0		0.894	46.8	0.7840-04	-0.5690-04	0.1360-04	-0.1080-03	0.1080-03	0.3440-01

TABLE XXXV CONTD.

RUN ID F-16

COMMENTS F-12 FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CM SMP LOOP 4 LINE APP 1/22/69

DEAD TIME= 0.600 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
0.0000 00	0.999	0.0000 00	317.	0.0000 00	318.	0.0000 00	1.00	318.
0.1000-02	0.965	17.1	1.00	-0.2180-01	0.983	-0.326	1.04	329.
0.2000-02	1.00	7.87	0.999	-0.4370-01	0.983	-0.180	0.999	317.
0.3000-02	1.01	4.28	0.997	-0.6540-01	0.982	-0.139	0.992	315.
0.4000-02	1.01	2.17	0.994	-0.8710-01	0.981	-0.124	0.989	314.
0.5000-02	1.01	0.667	0.991	-0.109	0.980	-0.119	0.988	314.
0.6000-02	1.01	-0.536	0.988	-0.130	0.979	-0.120	0.987	313.
0.7000-02	1.01	-1.56	0.983	-0.151	0.978	-0.123	0.986	313.
0.8000-02	1.01	-2.48	0.978	-0.172	0.976	-0.129	0.985	313.
0.9000-02	1.01	-3.33	0.972	-0.193	0.974	-0.135	0.984	313.
0.1000-01	1.01	-4.13	0.966	-0.214	0.972	-0.143	0.983	312.
0.2000-01	0.989	-10.9	0.870	-0.402	0.941	-0.233	0.969	308.
0.3000-01	0.959	-16.8	0.728	-0.544	0.891	-0.324	0.948	301.
0.4000-01	0.919	-22.2	0.563	-0.630	0.826	-0.403	0.919	292.
0.5000-01	0.872	-27.1	0.398	-0.660	0.751	-0.466	0.884	281.
0.6000-01	0.820	-31.4	0.252	-0.645	0.671	-0.512	0.844	268.
0.7000-01	0.767	-34.8	0.135	-0.599	0.590	-0.540	0.800	254.
0.8000-01	0.716	-37.4	0.5040-01	-0.538	0.513	-0.554	0.754	240.
0.9000-01	0.670	-39.3	-0.5840-02	-0.475	0.442	-0.554	0.709	225.
0.100	0.632	-40.5	-0.4120-01	-0.417	0.379	-0.545	0.664	211.
0.200	0.411	-45.5	-0.8300-01	-0.143	0.107	-0.388	0.402	128.
0.300	0.386	-38.8	-0.6360-01	-0.9410-01	0.2460-01	-0.293	0.294	93.5
0.400	0.393	-52.8	-0.7980-01	-0.4800-01	-0.2530-01	-0.236	0.237	75.3
0.500	0.381	-58.0	-0.7480-01	-0.1910-01	-0.6170-01	-0.193	0.203	64.3
0.600	0.326	-77.3	-0.5430-01	0.1340-01	-0.7650-01	-0.153	0.172	54.5
0.700	0.291	-85.9	-0.3640-01	0.2340-01	-0.8930-01	-0.119	0.149	47.3
0.800	0.227	-87.2	-0.2160-01	0.2150-01	-0.9940-01	-0.9040-01	0.134	42.7
0.900	0.238	-96.6	-0.1140-01	0.2430-01	-0.9590-01	-0.5920-01	0.113	35.8
1.00	0.198	-112.	0.1130-03	0.1930-01	-0.9020-01	-0.3650-01	0.9730-01	30.9



TABLE XXXV

RUN ID F-16

CONTD.

OMEGA RAD/SEC	DEAD TIME=	0.600	PHASE ANGLE DEGREES	PULSES NORMALIZED				INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
				AMPLITUDE RATIO	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL				
2.00	0.223	-79.1	0.3560-02	0.3520-02	-0.1250-01	0.1870-01	0.2250-01	7.14			
3.00	0.182	155.	-0.6450-03	-0.5120-03	0.2030-02	0.4050-02	0.4530-02	1.44			
4.00	0.634	-38.3	0.3390-03	0.2730-03	0.1530-03	0.6700-03	0.6870-03	0.218			
5.00	0.297	-140.	0.2120-03	-0.2610-04	-0.4860-03	0.5280-03	0.7180-03	0.228			
6.00	0.381	83.2	0.4550-04	-0.9970-05	-0.1190-04	-0.1220-03	0.1220-03	0.3880-01			
7.00	0.121	-31.7	-0.7690-04	-0.9130-05	-0.4990-03	-0.3970-03	0.6380-03	0.203			
8.00	0.107	102.	-0.2690-04	-0.3290-04	-0.2520-03	0.3090-03	0.3990-03	0.127			
9.00	0.424	21.8	-0.7770-04	0.3210-05	-0.1670-03	0.7510-04	0.1830-03	0.5830-01			
10.0	0.894	63.0	0.9110-04	-0.3280-04	0.1360-04	-0.1080-03	0.1080-03	0.3440-01			

TABLE XXXVI

RUN ID F-18

COMMENTS F-12 FLUIDIZED BED HT 7 5/8 IN AIR RATE 8.0 CM SMP LOOP 4 LINE APP 1/22/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			RFAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	1.30	0.0000 00	281.	0.0000 00	216.	0.0000 00	1.00	216.
0.1000-02	1.00	-0.538	1.00	-0.2030-01	1.00	-0.1090-01	1.00	216.
0.2000-02	1.00	-1.08	0.999	-0.4060-01	1.00	-0.2190-01	1.00	216.
0.3000-02	0.999	-1.61	0.997	-0.6090-01	0.999	-0.3280-01	1.00	216.
0.4000-02	0.999	-2.15	0.995	-0.8110-01	0.998	-0.4370-01	0.999	216.
0.5000-02	0.998	-2.69	0.992	-0.101	0.998	-0.5460-01	0.999	215.
0.6000-02	0.997	-3.23	0.989	-0.121	0.997	-0.6540-01	0.999	215.
0.7000-02	0.997	-3.76	0.985	-0.141	0.995	-0.7630-01	0.998	215.
0.8000-02	0.995	-4.30	0.980	-0.161	0.994	-0.8710-01	0.998	215.
0.9000-02	0.994	-4.83	0.975	-0.180	0.992	-0.9780-01	0.997	215.
0.1000-01	0.993	-5.36	0.969	-0.199	0.990	-0.109	0.996	215.
0.2000-01	0.972	-10.6	0.882	-0.375	0.962	-0.213	0.986	213.
0.3000-01	0.939	-15.5	0.753	-0.510	0.917	-0.309	0.968	209.
0.4000-01	0.896	-20.0	0.603	-0.593	0.858	-0.393	0.944	204.
0.5000-01	0.846	-23.8	0.452	-0.627	0.789	-0.463	0.914	197.
0.6000-01	0.792	-26.8	0.318	-0.620	0.712	-0.517	0.880	190.
0.7000-01	0.739	-29.0	0.210	-0.586	0.632	-0.556	0.842	182.
0.8000-01	0.691	-30.2	0.128	-0.539	0.553	-0.580	0.801	173.
0.9000-01	0.652	-30.7	0.7120-01	-0.490	0.478	-0.590	0.759	164.
0.100	0.622	-30.7	0.3070-01	-0.444	0.408	-0.589	0.717	155.
0.200	0.411	-32.6	-0.6230-01	-0.161	0.8300-01	-0.411	0.419	90.4
0.300	0.327	-21.2	-0.4140-01	-0.9190-01	0.1630-01	-0.308	0.308	66.4
0.400	0.320	-12.8	-0.3420-01	-0.6760-01	-0.5740-01	-0.230	0.237	51.0
0.500	0.314	-9.62	-0.3620-01	-0.5220-01	-0.8590-01	-0.183	0.203	43.7
0.600	0.341	-8.83	-0.4260-01	-0.4040-01	-0.105	-0.136	0.172	37.2
0.700	0.341	-7.62	-0.4180-01	-0.2720-01	-0.111	-0.9540-01	0.146	31.6
0.800	0.293	-8.48	-0.3450-01	-0.1230-01	-0.110	-0.5900-01	0.125	27.0
0.900	0.299	-5.03	-0.3020-01	-0.6970-02	-0.9850-01	-0.3210-01	0.104	22.3
1.00	0.287	-0.895	-0.2650-01	-0.2450-02	-0.9220-01	-0.9980-02	0.9270-01	20.0

TABLE XXXVI

RUN ID F-18

CONTD.

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
2.00	0.169	53.2	-0.2240-02	0.1030-02	-0.3080-02	0.1430-01	0.1460-01	3.15
3.00	0.306	116.	-0.4800-03	0.1430-03	0.1100-02	0.1210-02	0.1640-02	0.353
4.00	0.571	108.	-0.4530-03	-0.4290-03	-0.4680-03	0.9880-03	0.1090-02	0.236
5.00	0.726	107.	-0.5130-03	-0.7060-04	0.1170-03	0.7040-03	0.7140-03	0.154
6.00	0.696	-177.	-0.1750-03	0.7450-04	0.2440-03	-0.1210-03	0.2730-03	0.5880-01
7.00	0.506	-47.7	-0.2710-03	-0.1000-03	-0.2130-03	-0.5290-03	0.5700-03	0.123
8.00	2.81	40.5	-0.2450-03	0.8430-04	-0.4680-04	0.7950-04	0.9220-04	0.1990-01
9.00	0.181	90.4	-0.4210-04	0.1560-04	0.8810-04	0.2320-03	0.2480-03	0.5360-01
10.0	0.452	53.0	-0.3930-04	-0.8260-04	-0.1980-03	-0.4060-04	0.2020-03	0.4360-01

TABLE XXXVI CONTD.

RUN ID F-18

COMMENTS F-12 FLUIDIZED BED HT 7 5/8 IN AIR RATE 8.0 CM SMP LOOP 4 LINE APP 1/22/69

DEAD TIME= 1.10 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
0.0000-00	1.30	0.0000 00	281.	0.0000 00	216.	0.0000 00	1.00	216.
0.1000-02	1.00	-0.602	1.00	-0.2140-01	1.00	-0.1090-01	1.00	216.
0.2000-02	1.00	-1.20	0.999	-0.4280-01	1.00	-0.2190-01	1.00	216.
0.3000-02	0.999	-1.80	0.997	-0.6420-01	0.999	-0.3280-01	1.00	216.
0.4000-02	0.999	-2.40	0.995	-0.8540-01	0.998	-0.4370-01	0.999	216.
0.5000-02	0.998	-3.00	0.992	-0.107	0.998	-0.5460-01	0.999	215.
0.6000-02	0.997	-3.60	0.988	-0.128	0.997	-0.6540-01	0.999	215.
0.7000-02	0.997	-4.20	0.984	-0.148	0.995	-0.7630-01	0.998	215.
0.8000-02	0.995	-4.80	0.979	-0.169	0.994	-0.8710-01	0.998	215.
0.9000-02	0.994	-5.40	0.973	-0.190	0.992	-0.9780-01	0.997	215.
0.1000-01	0.993	-5.99	0.967	-0.210	0.990	-0.109	0.996	215.
0.2000-01	0.972	-11.8	0.873	-0.394	0.962	-0.213	0.986	213.
0.3000-01	0.939	-17.4	0.736	-0.534	0.917	-0.309	0.968	209.
0.4000-01	0.896	-22.5	0.576	-0.619	0.858	-0.393	0.944	204.
0.5000-01	0.846	-26.9	0.417	-0.651	0.789	-0.463	0.914	197.
0.6000-01	0.792	-30.6	0.277	-0.640	0.712	-0.517	0.880	190.
0.7000-01	0.739	-33.4	0.164	-0.601	0.632	-0.556	0.842	182.
0.8000-01	0.691	-35.3	0.8060-01	-0.548	0.553	-0.580	0.801	173.
0.9000-01	0.652	-36.4	0.2240-01	-0.494	0.478	-0.590	0.759	164.
0.100	0.622	-37.0	-0.1830-01	-0.445	0.408	-0.589	0.717	155.
0.200	0.411	-45.2	-0.9580-01	-0.143	0.8300-01	-0.411	0.419	90.4
0.300	0.327	-40.1	-0.6900-01	-0.7360-01	-0.1630-01	-0.308	0.308	66.4
0.400	0.320	-38.0	-0.5970-01	-0.4660-01	-0.5740-01	-0.230	0.237	51.0
0.500	0.314	-41.1	-0.5810-01	-0.2560-01	-0.8590-01	-0.183	0.203	43.7
0.600	0.341	-46.6	-0.5840-01	-0.5820-02	-0.105	-0.136	0.172	37.2
0.700	0.341	-51.7	-0.4900-01	0.9590-02	-0.111	-0.9540-01	0.146	31.6
0.800	0.293	-58.9	-0.3150-01	0.1880-01	-0.110	-0.5900-01	0.125	27.0
0.900	0.299	-61.8	-0.2240-01	0.2140-01	-0.9850-01	-0.3210-01	0.104	22.3
1.000	0.287	-63.9	-0.1420-01	0.2250-01	-0.9220-01	-0.9980-02	0.9270-01	20.0

TABLE XXXVI

KUN 10 F-18

CONTO.

OMEGA RAD/SEC	DEAD TIME = AMPLITUDE RATIO	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT PULSE REAL	INPUT PULSE IMAGINARY	INPUT FREQ NORMALIZED	CONTENT ACTUAL
			OUTPUT PULSE REAL	OUTPUT PULSE IMAGINARY						
2.00	0.169	-72.9	0.2150-02	0.1210-02	-0.3080-02	0.1430-01	0.1460-01	0.1460-01	3.15	
3.00	0.306	-73.5	0.4510-03	-0.2170-03	0.1100-02	0.1210-02	0.1640-02	0.1640-02	0.353	
4.00	0.571	-144.	0.5470-03	-0.3000-03	-0.4680-03	0.9880-03	0.1090-02	0.1090-02	0.236	
5.00	0.726	152.	-0.3140-03	-0.4120-03	0.1170-03	0.7040-03	0.7140-03	0.7140-03	0.154	
6.00	0.696	165.	-0.1430-03	0.1250-03	0.2440-03	-0.1210-03	0.2730-03	0.2730-03	0.5880-01	
7.00	0.506	-129.	-0.1410-03	0.2520-03	-0.2130-03	-0.5290-03	0.5700-03	0.5700-03	0.123	
8.00	2.81	-104.	0.2480-03	0.7520-04	-0.4680-04	0.7950-04	0.9220-04	0.9220-04	0.1990-01	
9.00	0.181	-117.	0.3030-04	-0.3310-04	0.8810-04	0.2320-03	0.2480-03	0.2480-03	0.5360-01	
10.0	0.452	143.	0.8240-04	-0.3960-04	-0.1980-03	-0.4060-04	0.2020-03	0.2020-03	0.4360-01	

TABLE XXXVII

RUN ID F-20

COMMENTS F-12 FLUIDIZED BED HT 7 5/8 IN AIR RATE 8.0 CM SMP LOOP 5 LINE APP 1/22/69

DEAD TIME= 0.0000 00 PULSES NORMALIZED

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	1.12	0.0000 00	510.	0.0000 00	454.	0.0000 00	1.00	454.
0.1000-02	1.00	-0.507	1.00	-0.2270-01	-1.00	-0.1390-01	1.00	454.
0.2000-02	1.00	-1.01	0.998	-0.4540-01	0.999	-0.2780-01	1.00	454.
0.3000-02	0.999	-1.52	0.996	-0.6800-01	0.998	-0.4160-01	0.999	454.
0.4000-02	0.999	-2.03	0.993	-0.9050-01	0.997	-0.5540-01	0.999	454.
0.5000-02	0.998	-2.53	0.990	-0.113	0.996	-0.6920-01	0.998	454.
0.6000-02	0.997	-3.03	0.985	-0.135	0.994	-0.8290-01	0.997	453.
0.7000-02	0.996	-3.53	0.980	-0.157	0.992	-0.9650-01	0.996	453.
0.8000-02	0.995	-4.03	0.974	-0.178	0.989	-0.110	0.995	452.
0.9000-02	0.993	-4.53	0.967	-0.200	0.986	-0.124	0.994	452.
0.1000-01	0.992	-5.02	0.960	-0.221	0.983	-0.137	0.993	451.
0.2000-01	0.969	-9.74	0.850	-0.404	0.935	-0.263	0.971	442.
0.3000-01	0.935	-13.9	0.701	-0.528	0.863	-0.369	0.938	426.
0.4000-01	0.897	-17.3	0.544	-0.591	0.774	-0.449	0.895	407.
0.5000-01	0.861	-19.9	0.402	-0.606	0.680	-0.503	0.845	384.
0.6000-01	0.831	-22.2	0.285	-0.594	0.588	-0.532	0.793	361.
0.7000-01	0.807	-24.5	0.189	-0.568	0.506	-0.543	0.742	337.
0.8000-01	0.784	-27.2	0.109	-0.534	0.434	-0.542	0.695	316.
0.9000-01	0.756	-30.3	0.4120-01	-0.491	0.375	-0.534	0.653	297.
0.100	0.717	-33.3	-0.1140-01	-0.442	0.325	-0.524	0.616	280.
0.200	0.428	-36.6	-0.8240-01	-0.142	0.4270-01	-0.381	0.383	174.
0.300	0.331	-27.9	-0.5570-01	-0.7160-01	-0.4760-01	-0.270	0.274	125.
0.400	0.294	-13.2	-0.3930-01	-0.5020-01	-0.9100-01	-0.197	0.217	98.5
0.500	0.309	-4.65	-0.3800-01	-0.4050-01	-0.112	-0.141	0.180	81.7
0.600	0.331	-2.56	-0.4100-01	-0.2840-01	-0.120	-0.9100-01	0.150	68.4
0.700	0.358	-5.83	-0.4370-01	-0.1260-01	-0.118	-0.4750-01	0.127	57.7
0.800	0.297	-10.4	-0.3190-01	0.1540-02	-0.107	-0.1420-01	0.108	48.9
0.900	0.248	-19.4	-0.1970-01	0.9110-02	-0.8720-01	0.8230-02	0.8760-01	39.8
1.00	0.199	-17.0	-0.1200-01	0.8960-02	-0.7110-01	0.2540-01	0.7550-01	34.3

TABLE XXXVII

RUN ID F-20

CONTD.

OMEGA RAD/SEC	DEAD TIME=	0.0000 00	PULSES NORMALIZED		PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT	
			AMPLITUDE RATIO	0.0000 00		REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED	ACTUAL
2.00	0.269		-0.1980-02	-0.1060-02	154.	0.4870-02	0.6790-02	0.8350-02	3.80		
3.00	0.228		-0.2980-03	0.2330-03	155.	0.1620-02	-0.3770-03	0.1660-02	0.754		
4.00	0.581		-0.4820-03	-0.2430-03	-5.11	-0.7890-03	-0.4910-03	0.9300-03	0.423		
5.00	0.642		-0.2270-03	0.2980-03	-2.15	-0.3710-03	0.4510-03	0.5830-03	0.265		
6.00	0.773		-0.1700-03	-0.2890-04	-91.4	0.4290-04	-0.2190-03	0.2230-03	0.101		
7.00	0.184		-0.6250-04	-0.2320-04	-34.8	-0.2070-03	-0.2970-03	0.3620-03	0.164		
8.00	0.279		-0.1610-03	0.3650-04	-11.9	-0.5920-03	0.8710-05	0.5920-03	0.269		
9.00	0.227		-0.6770-04	-0.3580-05	49.7	-0.2050-03	0.2170-03	0.2990-03	0.136		
10.0	0.727		-0.8740-04	-0.8610-05	118.	0.4690-04	0.1110-03	0.1210-03	0.5490-01		

TABLE XXXVII CONTD.

RUN ID F-20

COMMENTS F-12 FLUIDIZED BED HT 7 5/8 IN AIR RATE 8.0 CM SHP LOOP 5 LINE APP 1/22/69

OMEGA RAD/SEC	AMPLITUDE RATIO	PHASE ANGLE DEGREES	OUTPUT PULSE		INPUT PULSE		INPUT FREQ CONTENT NORMALIZED	CONTENT ACTUAL
			REAL	IMAGINARY	REAL	IMAGINARY		
0.0000 00	1.12	0.0000 00	510.	0.0000 00	454.	0.0000 00	1.00	454.
0.1000-02	1.00	-0.548	1.00	-0.2340-01	1.00	-0.1390-01	1.00	454.
0.2000-02	1.00	-1.09	0.998	-0.4680-01	0.999	-0.2780-01	1.00	454.
0.3000-02	0.999	-1.64	0.996	-0.7010-01	0.998	-0.4160-01	0.999	454.
0.4000-02	0.999	-2.19	0.993	-0.9330-01	0.997	-0.5540-01	0.999	454.
0.5000-02	0.998	-2.73	0.989	-0.116	0.996	-0.6920-01	0.998	454.
0.6000-02	0.997	-3.27	0.985	-0.139	0.994	-0.8290-01	0.997	453.
0.7000-02	0.996	-3.82	0.979	-0.162	0.992	-0.9650-01	0.996	453.
0.8000-02	0.995	-4.35	0.973	-0.184	0.989	-0.110	0.995	452.
0.9000-02	0.993	-4.89	0.966	-0.206	0.986	-0.124	0.994	452.
0.1000-01	0.992	-5.42	0.958	-0.227	0.983	-0.137	0.993	451.
0.2000-01	0.969	-10.5	0.844	-0.416	0.935	-0.263	0.971	442.
0.3000-01	0.935	-15.1	0.689	-0.543	0.863	-0.369	0.938	426.
0.4000-01	0.897	-18.9	0.527	-0.606	0.774	-0.449	0.895	407.
0.5000-01	0.861	-22.0	0.381	-0.620	0.680	-0.503	0.845	384.
0.6000-01	0.831	-24.6	0.260	-0.606	0.588	-0.532	0.793	361.
0.7000-01	0.807	-27.3	0.161	-0.577	0.506	-0.543	0.742	337.
0.8000-01	0.784	-30.4	0.7870-01	-0.539	0.434	-0.542	0.695	316.
0.9000-01	0.756	-33.9	0.1020-01	-0.493	0.375	-0.534	0.653	297.
0.100	0.717	-37.3	-0.4230-01	-0.440	0.325	-0.524	0.616	280.
0.200	0.428	-44.6	-0.101	-0.129	0.4270-01	-0.381	0.383	174.
0.300	0.331	-39.9	-0.6940-01	-0.5840-01	-0.4760-01	-0.270	0.274	125.
0.400	0.294	-29.2	-0.5160-01	-0.3740-01	-0.9100-01	-0.197	0.217	98.5
0.500	0.309	-24.7	-0.4960-01	-0.2510-01	-0.112	-0.141	0.180	81.7
0.600	0.331	-26.6	-0.4900-01	-0.9190-02	-0.120	-0.9100-01	0.150	68.4
0.700	0.358	-33.9	-0.4450-01	0.9390-02	-0.118	-0.4750-01	0.127	57.7
0.800	0.297	-42.5	-0.2620-01	0.1830-01	-0.107	-0.1420-01	0.108	48.9
0.900	0.248	-55.5	-0.1060-01	0.1900-01	-0.8720-01	0.8230-02	0.8760-01	39.8
1.000	0.199	-57.1	-0.3430-02	0.1460-01	-0.7110-01	0.2540-01	0.7550-01	34.3



TABLE XXXVII

RUN ID F-20

CONTD.

OMEGA RAD/SEC	DEAD TIME = 0.700	PHASE ANGLE DEGREES	PULSES NORMALIZED		INPUT PULSE		INPUT FREQ CONTENT	
			AMPLITUDE RATIO	OUTPUT REAL	IMAGINARY	REAL	IMAGINARY	NORMALIZED
2.00	0.269	73.6	-0.138D-02	0.177D-02	0.487D-02	0.679D-02	0.835D-02	3.80
3.00	0.228	34.7	0.352D-03	0.139D-03	0.162D-02	-0.377D-03	0.166D-02	0.754
4.00	0.581	-166.	0.372D-03	0.391D-03	-0.789D-03	-0.491D-03	0.930D-03	0.423
5.00	0.642	157.	0.108D-03	-0.359D-03	-0.371D-03	0.451D-03	0.583D-03	0.265
6.00	0.773	27.9	0.108D-03	-0.134D-03	0.429D-04	-0.219D-03	0.223D-03	0.101
7.00	0.184	44.5	0.111D-04	-0.657D-04	-0.207D-03	-0.297D-03	0.362D-03	0.164
8.00	0.279	27.2	-0.148D-03	-0.736D-04	-0.592D-03	0.871D-05	0.592D-03	0.269
9.00	0.227	48.7	-0.677D-04	-0.244D-05	-0.205D-03	0.217D-03	0.299D-03	0.136
10.0	0.727	77.4	-0.715D-04	0.509D-04	0.469D-04	0.111D-03	0.121D-03	0.549D-01

JRTRAN \*\* STOP

?.607

?.264, .241, 0.6, 0.22, 0., 0.542, 46.8, 4.25, 0.599, 1.0, 1.0, 0.052  
3.1889427E-01

0.264	0.241	0.319	0.220
0.542	0.542	46.8	4.25
0.599	0.241	1.00	1.00

FREQUENCY	MAGNITUDE	ANGLE
0.100E-01	0.992	-5.61
0.150E-01	0.982	-8.35
0.200E-01	0.969	-11.0
0.250E-01	0.953	-13.6
0.300E-01	0.934	-16.0
0.400E-01	0.889	-20.5
0.500E-01	0.839	-24.5
0.600E-01	0.787	-27.8
0.700E-01	0.735	-30.4
0.800E-01	0.685	-32.5
0.900E-01	0.637	-34.0
0.100	0.592	-35.0
0.150	0.425	-32.2
0.200	0.354	-20.3
0.250	0.358	-8.96
0.300	0.391	-4.49
0.400	0.423	-7.49
0.500	0.391	-9.30
0.600	0.374	-4.99
0.700	0.386	-2.85
0.800	0.390	-3.68
0.900	0.381	-3.86
1.00	0.376	-3.16
1.50	0.355	-2.17
2.00	0.325	-1.79?0

 $V_f = .319$  $V_d = .281$  $V_b = 0.4$ 

PROGRAM STOP AT 860

MM GE RECOMM GE RECOMM GE RI

? .646  
 ? .399, .241, 0.37, 0.22, 0., 0.542, 46.8, 4.25, 0.599, 0.5, 1.0, 0.05

0.399	0.241	0.370	0.220
0.521	0.542	46.8	4.25
0.599	0.326	0.500	1.00

I

FREQUENCY	MAGNITUDE	ANGLE
0.100E-01	0.995	-4.51
0.150E-01	0.989	-6.72
0.200E-01	0.981	-8.90
0.250E-01	0.971	-11.0
0.300E-01	0.959	-13.1
0.400E-01	0.930	-17.0
0.500E-01	0.897	-20.6
0.600E-01	0.861	-23.8
0.700E-01	0.823	-26.7
0.800E-01	0.785	-29.2
0.900E-01	0.748	-31.4
0.100	0.712	-33.2
0.150	0.559	-38.7
0.200	0.449	-39.6
0.250	0.372	-37.0
0.300	0.322	-31.6
0.400	0.288	-17.8
0.500	0.305	-9.63
0.600	0.325	-8.44
0.700	0.329	-9.94
0.800	0.319	-11.0
0.900	0.305	-10.3
1.00	0.297	-8.53
1.50	0.289	-5.19
2.00	0.269	-4.2170

$$-V_p = 0.370$$

$$V_b = .630$$

$$V_d = 0.0.$$

PROGRAM STOP AT 860

E COM M GE RE COM M GE RE COM M GE

ECOMM GE RECOMM GE RECOMM

? .620  
 ? .309, .241, 0.5, 0.22, 0., 0.542, 46.8, 4.25, 0.599, 0.8, 1.0, 0.052  
 3.4897843E-01

✓

0.309	0.241	0.349	0.220
0.542	0.542	46.8	4.25
0.599	0.241	0.800	1.00

FREQUENCY	MAGNITUDE	ANGLE
0.100E-01	0.993	-5.37
0.150E-01	0.983	-8.00
0.200E-01	0.971	-10.6
0.250E-01	0.956	-13.0
0.300E-01	0.938	-15.4
0.400E-01	0.897	-19.7
0.500E-01	0.851	-23.5
0.600E-01	0.803	-26.7
0.700E-01	0.755	-29.3
0.800E-01	0.708	-31.5
0.900E-01	0.664	-33.1
0.100	0.623	-34.4
0.150	0.461	-34.7
0.200	0.367	-27.5
0.250	0.334	-16.5
0.300	0.345	-7.77
0.400	0.397	-3.91
0.500	0.406	-7.66
0.600	0.379	-8.67
0.700	0.362	-5.52
0.800	0.368	-3.08
0.900	0.374	-3.01
1.00	0.372	-3.50
1.50	0.351	-2.36
2.00	0.327	-1.92?1

$V_p = .349$   
 $V_d = .151$   
 $V_b = 0.5$

APPENDIX VI  
RAW DATA

TABLE XXXVIII

TOTAL LAG TIMES BETWEEN PULSES  
(AS MEASURED FROM THE CHARTS)

<u>FLOW RATE READING, CM</u>	<u>RUN ID</u>	<u>TOTAL LAG TIME SECONDS</u>
2.0	H-03	3.5
	H-04	3.5
	H-05	3.5
	H-06	3.5
	<u>AVG.</u>	<u>3.5</u>
4.0	F-03	27.8
	F-04	27.4
	F-05	27.4
	F-06	27.4
	<u>AVG.</u>	<u>27.5</u>
5.0	H-08	2.5
	H-09	2.5
	H-10	2.6
	H-11	2.7
	<u>AVG.</u>	<u>2.6</u>
	F-07	14.2
	F-08	14.0
	F-09	12.6
	F-10	13.7
	F-11	13.7
	<u>AVG.</u>	<u>13.6</u>
H-07	1.9	
H-12	2.2	
H-13	2.2	
H-14	2.2	
<u>AVG.</u>	<u>2.1</u>	
F-02	2.0	
F-11	2.1	
F-12	2.1	
F-13	1.4	
<u>AVG.</u>	<u>1.9</u>	

TABLE XXXVIII CONTD.

<u>FLOW RATE READING, CM</u>	<u>RUN ID</u>	<u>TOTAL LAG TIME SECONDS</u>
6.0	H-15	2.3
	H-16	1.9
	H-17	2.2
	H-18	2.4
	AVG.	2.2
8.0	F-14	1.9
	F-15	2.0
	F-16	2.0
	F-17	2.1
	AVG.	2.0
8.0	H-19	2.3
	H-20	2.0
	H-21	1.9
	H-22	1.9
	AVG.	2.0
8.0	F-18	1.1
	F-19	0.8
	F-20	0.7
	F-21	0.9
	AVG.	0.9









206100.25301.0000206100.25321.000112.060.01 101.0 0.5 0.5 HI-04

HE TRACER BED HT 7 1/4 IN PACKED AIR FLOW 2.0 CM SMP LOOP 1 LINE APP 1/6/69

0.6	0.6	4.1	16.3	29.6	40.5	46.2	47.5	46.2	43.0	39.8	35.5
32.2	28.8	25.3	22.5	20.3	18.3	16.5	15.0	13.5	12.2	11.2	10.3
9.4	8.8	8.0	7.5	7.0	6.6	6.2	6.0	5.0	4.2	3.7	3.2
2.8	2.6	2.3	2.1	1.9	1.8	1.7	1.5	1.3	1.25	1.2	1.15
1.1	1.05	1.0	1.0	1.0	1.0	1.0	1.0	0.9	0.9	0.9	0.8
0.8	0.75	0.75	0.75	0.75	0.70	0.70	0.65	0.65	0.60		
0.6	0.6	1.3	5.5	13.1	24.9	35.0	41.1	43.9	43.9	42.1	39.1
36.3	33.0	29.5	26.2	23.8	21.3	19.1	17.2	15.6	14.0	12.6	11.5
10.3	9.6	8.7	8.0	7.5	7.0	6.5	6.2	5.8	5.5	4.6	3.9
3.4	3.0	2.7	2.4	2.2	2.0	1.8	1.7	1.6	1.5	1.4	1.3
1.25	1.2	1.2	1.1	1.0	1.0	1.0	0.95	0.9	0.9	0.85	0.8
0.8	0.8	0.8	0.8	0.8	0.75	0.70	0.70	0.65	0.60		



206020.25241.0000206030.25261.000112.050.01 101.0 0.2 0.2 H-06

HE TRACER BED HT 7 1/4 IN PACKED AIR FLOW 2.0 CM SMP LOOP 2 LINE APP 1/6/69

0.0	0.0	3.8	12.0	19.1	25.0	27.8	28.1	27.0	24.8	22.7	20.2
18.2	16.1	14.2	12.7	11.3	10.2	9.2	8.3	7.6	6.8	6.1	5.7
5.1	4.8	3.6	2.9	2.3	2.0	1.8	1.5	1.3	1.2	1.1	1.0
0.9	0.8	0.75	0.7	0.7	0.6	0.6	0.5	0.5	0.45	0.4	0.4
0.4	0.4	0.35	0.35	0.3	0.3	0.25	0.25	0.2	0.2	0.2	0.2
0.1	0.0										
0.0	0.0	0.8	4.0	9.5	16.8	23.0	26.4	28.0	27.6	26.3	24.2
22.3	20.2	18.0	15.9	14.2	12.8	11.3	10.2	9.2	8.2	7.3	6.7
6.0	5.5	5.0	4.6	3.3	2.7	2.2	1.8	1.6	1.3	1.2	1.0
0.9	0.8	0.75	0.7	0.6	0.55	0.5	0.45	0.4	0.4	0.3	0.3
0.25	0.25	0.25	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.05	0.05
0.05	0.05	0.0									



205040.25231.0000205060.25301.000111.100.001 10.0 0.5 0.5 H-03  
 HE PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 2 LINE APP 1/7/69

0.0	0.0	4.8	16.9	28.6	37.6	41.7	42.0	40.0	36.3	33.0	29.3
26.3	23.4	20.4	17.9	16.0	14.2	12.7	11.4	10.3	9.2	8.2	7.4
6.6	6.0	5.4	4.9	4.5	4.1	2.9	2.2	1.6	1.3	1.1	0.9
0.75	0.65	0.5	0.5	0.4	0.35	0.3	0.25	0.25	0.2	0.2	0.1
0.1	0.05	0.05	0.0								
0.5	0.5	3.5	13.0	24.5	33.8	38.2	38.7	37.1	34.0	31.2	27.9
25.0	22.2	19.4	17.0	15.1	13.5	11.9	10.6	9.5	8.4	7.5	6.8
6.1	5.5	5.0	4.5	4.2	3.8	3.5	3.2	2.4	2.0	1.7	1.4
1.25	1.2	1.1	1.0	0.95	0.9	0.8	0.8	0.8	0.75	0.7	0.7
0.7	0.6	0.6	0.55	0.55	0.5						

H-09  
1/7/69

206060.25401.0000205040.25281.000111.100.001 10.0 0.5 0.5

HE PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 2 LINE APP

0.0	0.0	4.0	16.0	28.0	37.0	41.3	41.6	39.9	36.2	33.0	29.3
26.2	23.2	20.2	17.8	16.0	14.2	12.7	11.3	10.1	9.1	8.2	7.4
6.6	6.0	5.4	5.0	4.5	4.2	3.8	3.5	3.2	3.0	2.75	2.5
2.25	2.1	2.0	1.9	1.8	1.7	1.4	1.1	0.9	0.8	0.7	0.6
0.55	0.45	0.4	0.35	0.35	0.3	0.3	0.25	0.25	0.25	0.2	0.2
0.1	0.1	0.1	0.05	0.05	0.0						
0.4	0.4	3.6	15.0	28.0	38.0	42.9	43.4	41.8	38.1	34.8	31.0
27.8	24.8	21.8	19.0	16.9	15.0	13.1	11.7	10.3	9.2	8.2	7.3
6.6	5.9	5.3	4.9	4.4	4.0	3.0	2.2	1.8	1.5	1.3	1.2
1.1	1.0	1.0	0.9	0.9	0.8	0.8	0.75	0.7	0.7	0.7	0.65
0.6	0.5	0.45	0.4								



H-10

1/7/69

204100.25281.0000205010.25301.000111.200.001 10.0 0.5 0.5

HE PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 3 LINE APP

0.4	0.4	6.0	18.5	29.5	37.4	40.6	40.4	38.0	34.1	30.8	27.1
24.1	21.2	18.6	16.2	14.3	12.8	11.3	10.2	9.1	8.2	7.3	6.6
5.9	5.3	4.8	4.4	4.0	3.7	2.7	2.0	1.6	1.3	1.25	1.0
0.9	0.8	0.75	0.7	0.6	0.55	0.5	0.5	0.45	0.4		
0.7	0.7	3.7	14.8	27.0	38.2	43.7	44.4	42.9	39.2	35.8	31.9
28.6	25.2	22.0	19.1	16.9	14.9	13.0	11.6	10.2	9.0	8.0	7.2
6.3	5.7	5.0	4.6	4.2	3.8	3.4	3.2	2.3	1.8	1.5	1.3
1.2	1.1	1.0	0.9	0.8	0.8	0.8	0.75	0.75	0.75	0.75	0.75
0.7											

204110.25281.0000204110.25291.000111.300.001 10.0 0.5 0.5 H-11

HE PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SMP LOOP 3 LINE APP 1/7/69

0.4	0.4	4.8	16.5	28.0	31.5	40.3	40.3	33.3	34.6	31.2	27.6
24.6	21.8	18.8	16.3	14.6	13.0	11.6	10.4	9.2	8.3	7.4	6.7
6.0	5.4	4.9	4.5	4.1	3.8	2.7	2.1	1.7	1.4	1.2	1.0
0.9	0.8	0.75	0.7	0.7	0.65	0.6	0.55	0.5	0.45	0.4	
0.75	0.75	5.0	17.0	29.5	39.0	43.0	43.1	41.0	37.3	34.0	30.1
27.0	23.9	20.9	17.2	16.1	14.2	12.5	11.0	8.7	7.8	7.0	6.2
5.6	5.0	4.5	4.1	3.8	3.5	3.2	2.4	1.9	1.6	1.4	1.3
1.2	1.1	1.0	1.0	1.0	0.9	0.85	0.85	0.8	0.8	0.8	0.75

204120.25281.000205110.25361.000111.300.001 10.0 0.5 0.5 H-12

HE FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 2 LINE APP 1/9/69

1.1	1.1	6.4	19.0	30.0	38.5	42.0	42.0	39.8	35.9	32.5	28.9
25.9	23.0	20.4	18.1	16.2	14.8	13.2	12.0	11.0	10.0	9.0	8.3
7.6	7.0	6.2	5.9	5.5	5.2	4.0	3.3	2.9	2.5	2.2	2.0
1.9	1.8	1.8	1.7	1.6	1.5	1.4	1.4	1.3	1.3	1.2	1.1
1.0	1.0	2.5	5.9	9.8	14.5	19.2	22.8	25.9	29.1	30.9	31.1
30.3	28.9	26.7	24.2	22.2	20.2	18.0	16.2	14.5	13.0	11.7	10.6
9.5	8.7	7.8	7.1	6.4	6.0	5.4	5.0	4.6	4.3	4.0	3.7
3.4	3.2	2.7	2.2	2.0	1.8	1.7	1.6	1.5	1.5	1.4	1.4
1.3	1.3	1.25	1.2	1.2	1.15	1.15	1.1	1.05	1.05	1.0	1.0

H-13

1/9/69

204050.25231.0000204120.25321.000110.800.001 10.0 0.2 0.2

HE FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SLP LOOP 3 LINE APP

0.7	0.7	4.5	13.9	23.0	30.0	33.0	33.0	31.2	28.2	27.4	22.5
20.0	17.8	15.4	13.5	12.1	10.8	9.7	8.8	7.2	6.4	5.9	5.2
4.8	3.4	2.6	2.0	1.6	1.5	1.3	1.1	1.0	1.0	0.9	0.9
0.8	0.8	0.8	0.75	0.7							
1.0	1.0	1.5	2.2	3.5	5.8	8.1	11.5	17.0	23.0	27.1	30.0
30.9	30.7	29.2	27.0	24.9	22.4	20.0	17.9	15.9	13.9	12.2	11.0
9.7	8.8	7.7	7.0	6.3	5.7	5.2	4.7	4.3	3.9	2.9	2.3
2.0	1.7	1.6	1.5	1.4	1.35	1.3	1.25	1.2	1.1	1.05	1.0

204070.25261.0000204120.25301.000110.800.001 10.0 0.2 0.2 H-14  
HE FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SHP LOOP 3 LINE APP 1/9/69

22.0	19.4	16.9	14.9	13.2	11.9	10.5	9.5	8.5	7.6	6.9	6.3
5.6	5.2	4.7	4.2	3.1	2.4	1.8	1.6	1.4	1.25	1.1	1.05
1.0	1.0	0.9	0.9	0.8	0.8	0.7					
1.1	1.1	1.8	3.5	6.0	9.7	13.2	16.0	17.9	22.1	24.7	26.8
27.5	27.2	25.9	24.0	22.0	20.0	18.0	16.1	14.4	12.9	11.4	10.3
9.1	8.2	7.3	6.6	6.0	5.5	5.0	4.6	3.3	2.6	2.2	1.8
1.7	1.6	1.5	1.4	1.35	1.3	1.2	1.2	1.2	1.15	1.15	1.1

204020.25241.0000204070.25221.000110.900.001 10.0 0.5 0.5 H-15

HE FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CM SMP LOOP 2 LINE APP 1/22/69

0.5	0.5	5.8	16.0	25.0	31.2	33.5	33.2	31.4	28.3	25.8	22.7
20.1	17.8	15.5	13.6	12.2	11.0	9.9	8.9	8.0	7.3	6.6	6.0
5.3	5.0	3.4	2.6	1.9	1.5	1.2	1.1	0.9	0.8	0.7	0.7
0.6	0.5										
0.5	0.5	1.8	6.8	12.6	19.0	23.9	26.7	28.6	29.8	29.9	29.1
27.9	2.61	23.9	21.7	19.8	17.8	15.8	14.1	12.5	11.1	9.8	8.8
7.8	6.9	6.1	5.4	4.9	4.3	2.8	2.0	1.4	1.1	0.9	0.8
0.75	0.7	0.65	0.6	0.55	0.55	0.5					

H-17

204040.25241.0000204020.25261.000110.600.001 10.0 0.2 0.2

1/22/69

HE FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CM SMP LOOP 3 LINE APP

0.6 0.6 5.9 16.0 24.5 30.3 32.5 32.2 30.2 27.2 24.6 21.7

19.2 17.0 14.8 12.9 11.5 10.3 9.2 8.3 7.5 6.7 6.0 5.5

5.0 4.5 3.2 2.3 1.8 1.4 1.2 1.0 1.0 0.8 0.8 0.75

0.75 0.7 0.65 0.6

0.6 0.6 1.5 3.3 7.2 13.2 18.9 22.8 25.3 26.5 26.2 25.0

23.7 22.0 20.0 17.9 16.1 14.3 12.8 11.3 10.0 8.9 7.9 7.1

6.2 5.6 4.9 4.4 2.9 2.0 1.5 1.2 1.0 0.9 0.8 0.7

0.65 0.6

203100.25201.0000203070.25221.000110.850.001 10.0 0.2 0.2 H-19

HE FLUIDIZED BED HT 7 5/8 IN AIR RATE 8.0 CM SMP LOOP 3 LINE APP 1/22/69

1.1	1.1	5.0	6.8	16.7	19.9	20.9	20.5	19.2	17.2	15.5	13.8
12.3	11.0	9.7	8.5	7.7	7.0	6.2	5.7	5.2	4.8	3.5	2.7
2.2	1.9	1.6	1.4	1.3	1.25	1.2	1.2	1.15	1.1		
1.1	1.1	3.0	7.1	11.6	16.0	19.0	20.2	20.3	19.3	18.0	16.4
15.0	13.5	11.9	10.5	9.4	8.5	7.5	6.8	6.1	5.5	4.9	4.4
3.0	2.25	1.8	1.5	1.4	1.2	1.1					



203120.25221.0000204020.25261.000110.450.001 10.0 0.2 0.2 H-21

HE FLUIDIZED BED HT 7 5/8 IN AIR RATE 8.0 CM SMP LOOP 4 LINE APP 1/22/69

1.1	1.1	5.4	14.9	21.0	25.8	27.2	26.9	25.2	22.9	20.6	18.2
16.2	14.3	12.7	11.1	10.0	9.0	8.1	7.4	6.8	6.0	5.5	5.1
3.8	2.9	2.4	2.0	1.8	1.6	1.5	1.4	1.3	1.2	1.05	1.1
1.2	1.2	3.2	8.5	14.0	20.0	24.1	26.6	27.6	27.3	26.2	24.8
23.0	21.1	19.0	16.9	15.2	13.7	12.0	10.9	9.7	8.5	7.7	6.9
6.2	5.6	5.0	4.6	3.3	2.5	2.0	1.8	1.6	1.5	1.4	1.3

207020.25221.0000205030.25232.000111.850.01 101.0 1.0 1.0 F-01  
 FREDI-12 TRACER BED IN AIR RATE 6.3 CM 12/27/68

0.0	0.0	1.3	4.8	9.0	14.6	19.5	24.1	28.0	30.3	31.0	30.9
30.2	29.1	27.7	26.3	25.0	24.0	22.7	21.7	20.9	20.1	19.3	19.0
17.0	15.5	14.3	13.2	12.5	11.6	10.8	10.1	9.4	8.7	8.3	7.5
7.0	6.3	6.0	5.7	5.1	4.7	4.2	4.0	3.9	3.4	3.4	2.8
2.6	2.3	2.2	2.0	1.9	1.8	1.5	1.5	1.4	1.3	1.3	1.1
1.0	0.9	0.9	0.8	0.7	0.5	0.4	0.3	0.3	0.2	0.2	0.1
0.1	0.0										
1.0	1.0	1.2	1.5	2.0	2.5	3.0	3.7	4.3	5.0	6.0	6.7
7.4	8.1	8.8	9.2	9.6	9.9	10.0	10.1	10.1	10.0	9.9	9.7
9.5	8.1	7.6	7.5	7.2	7.1	7.0	6.9	6.8	6.6	6.3	6.2
6.1	6.0	5.8	5.6	5.5	5.4	5.2	4.8	4.6	4.3	4.0	3.7
3.5	3.2	3.0	2.8	2.6	2.4	2.3	2.2	2.0	1.9	1.8	1.7
1.6	1.5	1.4	1.3	1.2	1.2	1.1	1.0				



F-03

1/6/69

205049.25342.0000203120.25612.0001126.40.001 10.0 0.5 0.5

7-12 PACKED BED HT 7 1/4 III AIR FLOW 2.0 CM SHIP LOOP 2 LINE APP

0.0	0.0	0.5	1.5	3.0	4.8	7.0	9.2	11.8	14.3	16.2	17.8
19.0	19.8	20.4	20.5	20.4	20.2	19.7	19.2	18.6	18.0	17.3	16.7
16.1	15.6	15.0	14.6	14.1	13.0	13.3	13.0	12.7	12.3	12.1	11.9
10.2	8.9	7.7	6.8	5.9	5.1	4.4	3.8	3.25	2.9	2.4	2.1
1.8	1.6	1.3	1.1	1.0	0.8	0.7	0.6	0.5	0.4	0.3	0.25
0.2	0.15	0.1	0.05	0.0							
0.6	0.6	0.7	0.75	0.8	0.85	0.9	0.95	1.0	1.1	1.2	1.25
1.3	1.5	1.7	1.8	2.0	2.1	2.3	2.5	2.75	3.0	3.25	3.5
3.7	4.0	4.3	4.6	4.9	5.2	5.4	5.7	6.0	6.3	6.6	6.8
7.1	7.3	7.5	7.7	8.0	8.2	8.35	8.5	8.6	8.75	8.9	9.0
9.05	9.1	9.2	9.2	9.2	9.25	9.25	9.25	9.2	9.15	9.1	9.05
9.0	8.95	8.9	8.2	7.4	6.7	6.0	5.3	4.7	4.1	3.7	3.2
2.8	2.5	2.2	2.0	1.8	1.6	1.4	1.3	1.2	1.15	1.1	1.0
1.0	0.9	0.9	0.9	0.8	0.8	0.75	0.75	0.7	0.7	0.65	0.6

F-04  
1/5/69

205050.25362.0000206120.50302.0001125.00.001 10.0 0.5 0.5

7-12 PACKED BED HT 7 1/4 IN AIR FLOW 2.0 CM SMP LOOP 2 LINE APP

0.0	0.0	0.7	1.5	2.5	4.2	6.3	8.4	10.8	13.0	14.8	16.3
17.3	18.1	18.6	18.9	18.8	18.6	18.2	17.75	17.2	16.6	15.9	15.3
14.8	14.3	13.9	13.3	13.0	12.7	12.3	12.0	11.7	11.5	11.2	11.0
10.8	10.6	9.1	8.2	7.0	6.1	5.2	4.5	4.0	3.5	3.0	2.5
2.1	1.9	1.65	1.4	1.2	1.1	1.0	0.9	0.8	0.7	0.6	0.5
0.4	0.3	0.2	0.1	0.05	0.0						
0.6	0.6	0.7	0.9	1.0	1.2	1.3	1.7	2.0	2.3	2.9	3.4
4.0	4.6	5.2	5.9	6.5	7.1	7.75	8.2	8.8	9.2	9.5	9.8
10.0	10.2	10.2	10.2	10.15	10.1	10.0	9.8	9.65	9.5	9.3	9.1
8.9	8.7	8.4	8.0	7.2	6.3	5.7	5.0	4.3	3.8	3.4	3.0
2.7	2.4	2.1	1.9	1.75	1.6	1.45	1.3	1.2	1.1	1.05	1.0
1.0	1.0	0.9	0.9	0.8	0.8	0.75	0.75	0.75	0.7	0.65	0.6

206070.25342.0000206070.50332.0001123.80.001 10.0 0.5 0.5 F-05

F- 12 PACKED RED HT 7 1/4 IN AIR RATE 2.0 CH SHP LOOP 3 LINE APP 1/6/69

0.5	0.5	0.8	1.5	2.5	4.5	7.3	10.5	14.1	18.0	20.8	23.1
24.6	25.5	26.0	25.9	25.5	24.9	24.0	23.2	22.4	21.5	20.7	20.0
19.2	18.7	18.0	17.5	17.1	16.8	16.3	16.0	15.7	15.4	15.2	15.0
13.4	11.9	10.5	9.2	8.0	6.9	6.0	5.2	4.5	4.0	3.45	2.9
2.4	2.2	1.9	1.7	1.5	1.3	1.0	1.0	0.9	0.9	0.8	0.8
0.75	0.7	0.7	0.6	0.6	0.6	0.55	0.5				
0.6	0.6	0.9	1.1	1.3	1.7	2.1	2.6	3.3	4.2	5.2	6.3
7.5	8.8	10.2	11.4	12.8	14.2	15.4	16.6	17.5	18.3	19.0	19.5
19.7	20.0	20.1	20.1	20.05	19.9	19.7	19.3	18.9	18.5	18.0	17.5
17.0	16.5	16.0	15.5	13.5	11.8	10.2	8.8	7.6	6.6	5.6	4.9
4.25	3.7	3.2	2.8	2.5	2.2	2.0	1.7	1.6	1.4	1.25	1.2
1.1	1.0	0.9	0.85	0.80	0.7	0.6					

207120.25422.0000206070.50372.0001126.00.001 10.0 0.5 0.5 F-06

F-12 PACKED BED HT 7 1/4 IN AIR RATE 2.0 CM SMP LOOP 3 LINE APP 1/6/69

0.0	0.0	1.0	2.5	4.4	7.2	10.8	13.9	17.1	20.0	21.9	23.4
24.3	24.7	24.8	24.5	24.2	23.7	23.0	22.3	21.7	21.0	20.4	19.9
19.3	18.8	18.3	17.9	17.4	17.1	16.8	16.4	16.1	15.9	15.6	15.3
15.1	14.9	14.7	14.4	14.2	14.0	13.8	13.6	12.1	10.5	9.2	8.0
7.0	6.4	5.5	4.9	4.2	3.3	2.7	2.4	2.0	1.8	1.6	1.3
1.1	1.0	0.9	0.8	0.7	0.6	0.6	0.6	0.5	0.5	0.5	0.4
0.4	0.35	0.3	0.3	0.3	0.25	0.25	0.25	0.2	0.1	0.1	0.0
0.5	0.5	1.0	1.1	1.2	1.6	2.0	2.3	3.0	3.8	4.5	5.5
6.6	7.8	9.0	10.1	11.3	12.5	13.6	14.6	15.4	16.2	16.8	17.2
17.5	17.8	17.8	17.8	17.65	17.4	17.2	16.8	16.4	16.0	15.6	15.2
14.8	14.3	13.9	12.1	10.6	9.2	8.0	6.8	5.9	5.1	4.4	3.8
3.3	2.9	2.5	2.2	2.0	1.7	1.5	1.3	1.2	1.1	1.0	0.9
0.8	0.7	0.6	0.55	0.55	0.55	0.5					

205100.25442.0000203070.25522.0001112.80.001 10.0 1.0 1.0 F-07

F-12 PACKED BED HT 7 1/4 IH AIR RATE 4.0 CM SWP LOOP 3 LINE APP 1/7/69

1.3	1.3	2.1	3.6	6.3	10.2	14.4	19.5	23.5	26.9	29.1	30.7
31.4	31.4	31.0	30.2	29.2	28.2	27.1	26.0	24.9	24.0	23.0	22.3
21.4	20.7	20.1	19.6	19.1	18.6	18.1	17.8	17.4	17.0	16.6	16.3
16.0	15.8	15.4	15.2	14.9	14.7	14.4	14.2	14.0	13.8	12.0	10.6
9.2	8.0	7.1	6.3	5.6	4.9	4.3	4.0	3.6	3.1	3.0	2.6
2.45	2.3	2.0	2.0	1.9	1.8	1.6	1.5	1.4	1.3		
0.7	0.7	0.9	1.0	1.1	1.2	1.4	1.6	1.9	2.1	2.5	2.9
3.2	3.7	4.3	5.0	5.5	6.2	6.9	7.6	8.3	9.1	9.9	10.6
11.4	12.1	12.9	13.5	14.0	14.6	15.2	15.6	16.1	16.3	16.7	16.9
17.1	17.2	17.25	17.25	17.25	17.2	17.1	17.0	16.8	16.4	16.0	15.8
15.5	15.2	15.0	14.8	14.5	14.2	12.3	10.7	9.3	8.0	7.0	6.0
5.3	4.6	4.0	3.5	3.0	2.7	2.4	2.1	1.9	1.75	1.6	1.4
1.3	1.25	1.2	1.1	1.0	1.0	1.0	0.9	0.9	0.9	0.85	0.85
0.8	0.8	0.8	0.75	0.75	0.75	0.7					



207050.25632.0000206070.50332.3001111.60.001 10.0 1.0 1.0

F-08

1/7/69

F-12 PACKED BED HT 7 1/4 III AIR RATE 4.0 CH SIP LOOP 4 LINE APP

0.7	0.7	1.7	4.2	7.3	12.3	17.8	23.0	27.8	32.2	34.7	36.6
37.3	37.3	36.8	35.7	34.7	33.3	32.1	30.8	29.7	28.3	27.2	26.3
25.3	24.6	23.8	23.1	22.5	21.9	21.3	20.9	20.4	20.0	19.65	19.3
19.0	18.6	18.2	14.3	12.3	10.7	9.3	8.1	7.0	6.0	5.2	4.6
4.0	3.4	3.1	2.7	2.3	2.0	1.8	1.6	1.5	1.35	1.2	1.2
1.1	1.05	1.0	1.0	0.9	0.9	0.85	0.8	0.8	0.8	0.8	0.8
0.8	0.8	0.75	0.75	0.7							
0.75	0.75	1.0	1.6	2.3	3.8	5.5	7.7	10.8	14.0	17.9	21.9
25.8	29.3	32.7	35.2	37.2	38.5	39.2	39.3	39.0	38.3	37.3	36.1
34.8	33.4	32.0	30.7	29.4	28.3	27.1	26.0	25.0	24.0	23.0	19.6
16.6	14.2	12.0	10.3	8.8	7.5	6.4	5.5	4.7	4.1	3.6	3.1
2.75	2.4	2.2	2.0	1.8	1.6	1.4	1.3	1.2	1.1	1.05	1.0
0.95	0.9	0.85	0.85	0.8	0.8	0.8	0.8	0.8	0.8	0.75	

F-09

1/7/69

206120.25392.0000207050.50322.0001111.20.001 10.0 1.0 1.0

F-12 PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SHP LOOP 4 LINE APP

0.6	0.6	1.5	3.5	6.3	11.0	16.5	21.7	26.9	31.6	34.4	36.6
37.5	37.8	37.3	36.3	35.2	34.0	32.7	31.3	30.0	28.9	27.7	25.7
24.9	24.0	23.2	22.6	22.1	21.5	21.1	20.6	20.2	19.9	19.5	19.1
18.8	18.4	18.1	17.9	17.5	15.2	13.2	11.4	9.9	8.5	7.3	6.3
5.5	4.8	4.1	3.6	3.1	2.7	2.3	2.1	1.9	1.8	1.5	1.3
1.2	1.1	1.1	1.0	1.0	0.9	0.8	0.8	0.7	0.7	0.65	0.6
0.6	0.6	1.0	1.4	2.1	3.3	4.9	7.1	10.0	13.4	17.5	21.9
26.0	30.0	33.8	36.7	38.9	40.3	41.1	41.1	40.7	39.7	38.5	37.1
35.5	34.0	32.3	30.9	29.5	28.1	26.9	25.7	24.6	23.5	19.9	16.8
14.3	12.2	10.4	9.0	7.8	6.7	5.7	5.0	4.2	3.7	3.2	2.8
2.5	2.1	2.0	1.8	1.6	1.4	1.3	1.2	1.1	1.05	1.0	1.0
1.0	1.0	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.75	0.75	0.7
0.7	0.65	0.65	0.65	0.65	0.6						

F-10

1/7/69

206050.25352.0000206020.50372.0001112.20.001 10.0 1.0 1.0

F-12 PACKED BED HT 7 1/4 IN AIR RATE 4.0 CM SHP LOOP 3 LINE APP

0.3	0.3	1.4	3.3	6.1	10.2	15.0	19.4	23.8	27.3	29.3	30.6
31.1	31.0	30.4	29.5	28.5	27.3	26.1	25.1	24.0	23.1	22.1	21.4
20.6	19.3	18.8	17.2	16.8	17.3	17.0	16.5	16.2	15.9	15.6	15.2
15.0	13.0	11.2	9.9	8.5	7.1	6.2	5.4	4.7	4.0	3.4	2.9
2.6	2.2	1.9	1.7	1.4	1.3	1.2	1.0	1.0	0.9	0.75	0.75
0.7	0.6	0.5	0.4	0.3							
1.1	1.1	1.2	1.5	1.8	2.3	3.0	4.0	5.2	6.5	8.1	9.9
11.6	13.3	15.2	16.7	17.0	19.2	20.1	20.7	21.0	21.0	20.9	20.6
20.1	19.6	19.0	18.3	17.8	17.1	16.4	15.9	15.2	14.8	14.2	13.7
13.2	12.8	12.2	10.6	9.2	8.0	7.0	6.1	5.2	4.7	4.1	3.6
3.2	2.9	2.6	2.3	2.2	2.0	1.8	1.7	1.6	1.5	1.4	1.3
1.2	1.1										

205110.25282.0000205030.50142.000110.700.001 10.0 0.5 0.5 F-11

F-12 FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 5 LINE APP 1/9/69

1.0	1.0	2.0	4.0	6.8	10.8	15.1	19.2	23.0	26.1	27.9	29.0
29.2	28.9	28.0	27.0	26.0	24.9	23.8	22.8	21.9	20.9	20.0	19.3
18.8	18.2	17.6	17.1	16.8	16.2	13.9	12.1	10.6	9.2	8.0	7.0
6.1	5.3	4.7	4.1	3.5	3.1	3.0	2.6	2.4	2.2	2.0	2.0
1.7	1.6	1.5	1.4	1.4	1.2	1.2	1.1	1.1	1.05	1.0	
0.0	0.0	0.5	1.4	2.7	4.5	6.4	8.2	9.4	9.9	9.7	9.3
8.9	8.5	8.1	7.8	7.0	6.6	6.3	7.2	7.2	7.0	7.1	7.5
7.3	6.9	7.0	6.8	6.0	5.2	4.8	4.2	4.0	3.5	3.0	2.6
2.3	2.0	1.8	1.5	1.3	1.2	1.0	0.95	0.8	0.6	0.5	0.4
0.4	0.3	0.25	0.2	0.2	0.1	0.05	0.0				

F-12

1/9/69

205070.25272.0000205070.50172.000110.600.001 10.0 1.0 1.0

F-12 FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SHP LOOP 4 LINE APP

1.0	1.0	2.2	4.3	7.3	11.8	16.8	21.4	26.0	30.3	32.7	34.0
34.1	33.8	33.0	32.0	31.0	29.9	28.3	27.3	26.0	24.9	23.8	23.0
22.1	21.4	20.7	20.2	19.5	16.0	14.1	12.2	10.8	9.3	8.3	7.1
6.2	5.3	4.6	4.3	3.6	3.3	3.0	2.4	2.4	2.1	2.0	1.9
1.9	1.7	1.6	1.3	1.2	1.1	1.0					
-0.1	-0.1	0.2	1.2	2.5	3.2	6.2	8.0	9.8	10.9	11.2	11.0
10.5	10.2	9.3	8.9	8.4	8.1	7.8	7.0	6.8	7.0	7.2	7.3
7.3	7.8	7.8	7.6	8.0	7.5	6.4	5.8	5.3	5.0	4.3	3.7
3.2	2.7	2.2	1.9	1.7	1.3	1.0	0.9	0.8	0.6	0.4	0.3
0.2	0.1	0.0	0.0	0.0	0.0	-0.05	-0.1				

205080.25262.0000205070.50192.000110.600.001 10.0 1.0 1.0 F-13

F-12 FLUIDIZED BED HT 7 1/4 IN AIR RATE 5.0 CM SMP LOOP 4 LINE APP 1/9/69

1.0	1.0	2.6	4.9	8.1	13.2	18.5	23.1	27.2	30.9	32.6	33.5
33.6	33.3	32.4	31.2	30.1	29.0	27.5	26.2	25.2	24.1	23.2	22.5
21.6	21.0	20.1	19.7	16.6	14.1	12.5	11.0	9.8	8.2	7.2	6.2
5.2	4.9	4.1	3.8	3.5	2.8	2.6	2.4	2.1	1.9	1.9	1.8
1.6	1.5	1.4	1.3	1.2	1.1	1.05	1.0				
0.0	0.0	1.2	2.9	4.9	7.5	10.0	12.0	13.7	14.5	14.7	14.1
13.4	12.8	12.1	11.6	11.1	10.8	10.3	10.0	9.2	8.7	8.4	8.7
8.6	8.5	8.4	9.2	9.8	8.6	7.6	6.8	6.1	5.5	4.9	4.2
3.9	3.4	3.0	2.5	2.2	1.8	1.5	1.2	1.0	0.9	0.75	0.5
0.4	0.3	0.25	0.2	0.1	0.05	0.0					

205030.25282.0000205110.50172.000110.450.001 10.0 0.5 0.5 F-14

F-12 FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CM SMP LOOP 5 LINE APP 1/22/69

1.5	1.5	2.8	4.9	7.7	11.7	15.8	19.2	22.2	24.4	25.5	25.9
25.8	25.2	24.3	23.2	22.2	21.2	20.2	19.3	18.5	17.8	17.1	16.6
16.0	15.6	15.1	14.9	14.5	14.2	12.3	10.7	9.4	8.3	7.5	6.5
5.9	5.2	4.6	4.1	3.8	3.4	3.1	2.8	2.6	2.4	2.2	2.1
2.0	1.9	1.8	1.7	1.6	1.6	1.6	1.6	1.5			
0.7	0.7	2.0	4.2	6.8	8.8	10.1	11.0	11.6	12.0	12.1	12.0
11.8	11.6	11.3	11.0	10.8	10.6	9.5	9.0	8.8	8.6	8.4	8.0
7.8	7.2	6.7	6.0	5.7	5.3	5.1	4.4	4.0	3.8	3.6	3.2
2.8	2.6	2.4	2.2	2.0	1.9	1.8	1.7	1.5	1.4	1.3	1.25
1.2	1.1	1.0	1.0	1.0	0.9	0.9	0.8	0.8	0.75	0.7	

205070.25302.0000205050.50162.000110.600.001 10.0 1.0 1.0 F-16

F-12 FLUIDIZED BED HT 7 3/8 IN AIR RATE 6.0 CM SMP LOOP 4 LINE APP 1/22/69

1.0	1.0	2.2	4.3	7.6	12.0	16.9	21.2	25.0	28.1	29.7	30.2
30.1	29.6	28.6	27.3	26.3	25.1	24.0	23.0	21.9	20.8	20.0	19.3
18.8	18.2	17.7	17.3	16.9	16.4	15.9	15.5	13.4	11.7	10.0	8.8
7.8	6.9	5.8	5.1	4.4	4.0	3.4	3.0	2.8	2.3	2.1	1.9
1.8	1.8	1.4	1.3	1.2	1.1	1.05	1.0				
1.0	1.0	1.5	2.5	4.2	6.3	8.0	9.1	10.2	11.5	12.6	13.0
13.0	12.6	12.0	11.6	11.2	11.0	10.4	10.1	9.9	10.0	9.8	9.1
8.5	8.2	7.4	6.8	6.2	5.5	5.0	4.5	4.3	4.1	3.8	3.3
3.0	2.7	2.5	2.3	2.1	1.9	1.8	1.7	1.6	1.5	1.4	1.35
1.3	1.2	1.1	1.05	1.0							





206040.25302.0000207040.50272.000110.700.001 10.0 1.0 1.0 F-20

F-12 FLUIDIZED BED HT 7 5/8 IN AIR RATE 8.0 CM SMP LOOP 5 LINE APP 1/22/69

1.1	1.1	2.0	3.0	4.1	6.5	9.8	13.1	17.8	22.8	26.8	30.5
33.2	35.5	37.0	37.9	37.9	37.4	36.6	35.5	34.1	32.8	31.4	30.2
29.0	28.0	26.8	25.9	25.1	24.4	23.8	23.0	19.5	16.8	14.5	12.6
10.7	9.3	8.2	7.1	6.2	5.5	5.0	4.2	4.0	3.6	3.2	3.0
2.8	2.6	2.3	2.1	2.0	2.0	1.8	1.8	1.7	1.6	1.5	1.4
1.3	1.2	1.15	1.1								
0.1	0.1	2.0	4.2	6.4	8.8	10.9	13.0	15.0	16.1	16.7	16.6
16.2	15.9	15.5	15.2	15.0	14.9	15.0	15.0	15.2	15.6	15.8	16.0
16.2	16.4	16.6	16.5	16.2	15.1	14.1	13.2	12.1	11.2	10.0	9.0
8.1	7.3	6.4	5.8	5.0	4.5	4.0	3.4	3.0	2.8	2.5	2.1
1.9	1.8	1.6	1.2	1.1	1.05	1.0	1.0	0.9	0.8	0.7	0.7
0.7	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.4	0.3	0.2
0.2	0.2	0.15	0.1								

VITA

William Charles Zalewski was born in \_\_\_\_\_, \_\_\_\_\_, in \_\_\_\_\_. He received his B.S.Ch.E. from Newark College of Engineering in 1963. Upon graduation, he was the recipient of a Menninger Fellowship at the University of Virginia. He received the M.Ch.E. in 1965.

He was employed by the Chevron Oil Company from 1964 to 1967. In 1967, he was awarded a teaching fellowship and pursued his doctoral program full time at Newark College of Engineering. In the fall of 1967, he was awarded a N.D.E.A. Title IV Fellowship.

He is a member of Omega Chi Epsilon. He is married and has one daughter.

Presently he is employed by the Insulating Department, General Electric Company in Schenectady, New York.